

**Regulatory Information**

<i>Permit No.</i>	EGLE Renewable Operating Permit (ROP) No. MI-ROP-N1395-2021
<i>Regulatory Citation</i>	40 CFR Part 60 & 40 CFR Part 75
<i>Regulatory Agency</i>	US EPA Region 5

**Source Information**

<i>Source Name</i>	<i>Source ID</i>	<i>Target Parameters</i>
Wood-Fired Boiler	EUBLR	Volumetric Flow Rate, Moisture, O <sub>2</sub> , CO, NO <sub>x</sub>

**Contact Information**

<i>Test Location</i>	<i>Test Company</i>	<i>Analytical Laboratory</i>
Cadillac Renewable Energy 1525 Miltner Street Cadillac, Michigan 49601	Alliance Technical Group, LLC 20 Parkway View Drive Pittsburgh, PA 15205	Not Applicable
<i>Facility Contact</i> Ryan Putvin rputvin@atlanticpower.com (231) 779-8609	<i>Project Manager/Field Team Leader</i> Kenji Kinoshita kenji.kinoshita@alliancetg.com (412) 676-9415	
<i>Apex Contact</i> Derek Wong derek.wong@apexc.com (284) 875-7581	<i>QA/QC Manager</i> Kathleen Shonk katie.shonk@alliancetg.com (812) 452-4785	
	<i>Report Coordinator</i> Hailey Adamik hailey.adamik@alliancetg.com (724) 610-2808	

Alliance Technical Group, LLC (Alliance) has completed the source testing as described in this report. Results apply only to the source(s) tested and operating condition(s) for the specific test date(s) and time(s) identified within this report. All results are intended to be considered in their entirety, and Alliance is not responsible for use of less than the complete test report without written consent. This report shall not be reproduced in full or in part without written approval from the customer.

To the best of my knowledge and abilities, all information, facts and test data are correct. Data presented in this report has been checked for completeness and is accurate, error-free and legible. Onsite testing was conducted in accordance with approved internal Standard Operating Procedures. Any deviations or problems are detailed in the relevant sections in the test report.

This report is only considered valid once an authorized representative of Alliance has signed in the space provided below; any other version is considered draft. This document was prepared in portable document format (.pdf) and contains pages as identified in the bottom footer of this document.



**Kenji Kinoshita**  
Alliance Technical Group, LLC

12/19/23

Date

**TABLE OF CONTENTS**

1.0 Introduction ..... 1-1

    1.1 Facility, Process & Control Equipment Descriptions..... 1-1

    1.2 CEMS Descriptions..... 1-1

    1.3 Project Team ..... 1-1

    1.4 Site Specific Test Plan & Notification ..... 1-1

2.0 Summary of Results ..... 2-1

3.0 Testing Methodology..... 3-1

    3.1 U.S. EPA Reference Test Methods 1 and 2 – Volumetric Flow Rate ..... 3-1

    3.2 U.S. EPA Reference Test Method 3 – Oxygen/Carbon Dioxide..... 3-1

    3.3 U.S. EPA Reference Test Method 3A – Oxygen/Carbon Dioxide..... 3-2

    3.4 U.S. EPA Reference Test Method 4 – Moisture Content..... 3-2

    3.5 U.S. EPA Reference Test Method 7E – Nitrogen Oxides ..... 3-2

    3.6 U.S. EPA Reference Test Method 10 – Carbon Monoxide..... 3-2

    3.7 U.S. EPA Reference Test Method 19 – Mass Emission Factors ..... 3-2

    3.8 Quality Assurance/Quality Control – U.S. EPA Reference Test Methods 3A, 7E and 10..... 3-3

**LIST OF TABLES**

Table 1-1: Project Team ..... 1-1

Table 2-1: Summary of P75 Performance Specification Test Results – EUBLR..... 2-1

Table 2-2: Summary of P60 Performance Specification Test Results – EUBLR..... 2-1

Table 3-1: Source Testing Methodology ..... 3-1

**APPENDICES**

- Appendix A Sample Calculations
- Appendix B RATA Calculations & Field Data
- Appendix C Quality Assurance/Quality Control Data
- Appendix D CEMS Data
- Appendix E CSV Data

**1.0 Introduction**

Alliance Technical Group, LLC (Alliance) conducted performance specification (PS) testing at the Cadillac Renewable Energy facility in Cadillac, Michigan. Portions of the facility are subject to provisions of the 40 CFR Part 60 and 40 CFR Part 75. The facility operates under Michigan Department of Environment, Great Lakes, and Energy (EGLE) Renewable Operating Permit (ROP) No. MI-ROP-N1395-2021. PS testing consisted of performing Relative Accuracy Test Audits (RATAs) on one flowrate analyzer, one moisture analyzer, one oxygen (O<sub>2</sub>) analyzer, one carbon monoxide (CO) analyzer, and one nitrogen oxides (NO<sub>x</sub>) analyzer, that service the wood-fired boiler (EUBLR).

**1.1 Facility, Process & Control Equipment Descriptions**

Cadillac Renewable Energy operates a spreader-stoker design boiler (EUBLR), with a steam rating of 334,085 pound per hour (lb/hr) at 1,025 pound per square inch gage (psig) firing on wood fuel. The steam turbine/generator has a rated output of 39.6 megawatt (MW). Natural gas is used as a startup fuel.

A selective non-catalytic reduction (SNCR) system, a multiclone dust collector, and an electrostatic precipitator (ESP) serve as pollution control equipment for the EUBLR source. Air flow rates are monitored by a Dwyer Flow Gauge, serial number N44P-E.

**1.2 CEMS Descriptions**

*EUBLR*

	<u>Pollutant</u>	<u>Pollutant</u>	<u>Pollutant</u>
Parameter:	O <sub>2</sub> (Dry)	CO	NO <sub>x</sub>
Make:	Teledyne	Teledyne	Teledyne
Model:	T802	T300M	T200H
Serial No.:	247	925	898
Span:	0-25 %	0-500 PPM	0-100 PPM

**1.3 Project Team**

Personnel involved in this project are identified in the following table.

**Table 1-1: Project Team**

<b>Facility Personnel</b>	Ryan Putvin
<b>Apex Personnel</b>	Derek Wong
<b>Regulatory Personnel - EGLE</b>	Jeremy Howe Dave Bowman Daniel Droste
<b>Alliance Personnel</b>	Kenji Kinoshita Moritz Stuehn

**1.4 Site Specific Test Plan & Notification**

Testing was conducted in accordance with the Site-Specific Test Plan (SSTP), submitted to EGLE on October 30, 2023.

## 2.0 Summary of Results

Alliance conducted PS testing at the Cadillac Renewable Energy facility in Cadillac, Michigan on November 29, 2023. Testing consisted of performing RATAs on one flowrate analyzer, one moisture analyzer, one O<sub>2</sub> analyzer, one CO analyzer, and one NO<sub>x</sub> analyzer, that service the wood-fired boiler (EUBLR).

Tables 2-1 and 2-2 provide a summary of the emission testing results with comparisons to the applicable NESHAP and EGLE permit limits. Any difference between the summary results listed in the following tables and the detailed results contained in appendices is due to rounding for presentation.

**Table 2-1: Summary of P75 Performance Specification Test Results – EUBLR**

CEMS	Performance Test Data		Relative Accuracy		BAF
	Reference Method Data	CEMS Data	Performance Required	Performance Demonstrated	
<b>Moisture Data</b>					
Moisture Content, %	20.9	20.9	≤ 7.5% <sup>1</sup>	4.31 %	1.000
<b>Nitrogen Oxides Data</b>					
Emission Factor, lb/MMBtu (O <sub>2</sub> dry)	0.153	0.145	≤ 7.5% <sup>1</sup>	6.23 %	1.060
<b>Oxygen Data</b>					
Concentration, % dry	6.83	6.73	≤ 7.5% <sup>1</sup>	1.56 %	1.000
<b>Volumetric Flow Rate</b>					
High Load Flow Rate, kscfh (wet)	7,550,771	7,549,607	≤ 7.5% <sup>1</sup>	0.82 %	1.000
Low Load Flow Rate, kscfh (wet)	4,853,920	4,851,573	≤ 7.5% <sup>1</sup>	2 %	1.000

<sup>1</sup> RATA frequency of four (4) operating quarters.

**Table 2-2: Summary of P60 Performance Specification Test Results – EUBLR**

CEMS	Performance Test Data		Relative Accuracy	
	Reference Method Data	CEMS Data	Performance Required	Performance Demonstrated
<b>Nitrogen Oxides Data</b>				
Concentration, ppmvd	93.6	88.9	≤ 10 %	5.53 % <sup>1</sup>
<b>Carbon Monoxide Data</b>				
Emission Rate, lb/hr	10.3	10.9	≤ 10 %	0.42 % <sup>2</sup>
Emission Factor, lb/MMBtu	0.037	0.038	≤ 10 %	0.47 % <sup>2</sup>

<sup>1</sup> Calculated using the mean reference method.

<sup>2</sup> Calculated using the applicable source standard for carbon monoxide (CO).

### 3.0 Testing Methodology

The emission testing program was conducted in accordance with the test methods listed in Table 3-1. Method descriptions are provided below while quality assurance/quality control data is provided in Appendix C.

**Table 3-1: Source Testing Methodology**

Parameter	U.S. EPA Reference Test Methods	Notes/Remarks
Volumetric Flow Rate	1, 2	Full Velocity Traverses
Oxygen/Carbon Dioxide	3	Fyrite Analysis
Oxygen/Carbon Dioxide	3A	Instrumental Analysis
Moisture Content	4	Gravimetric Analysis
Nitrogen Oxides	7E	Instrumental Analysis
Carbon Monoxide	10	Instrumental Analysis
Mass Emission Factors	19	Fuel Factors/Heat Inputs

#### 3.1 U.S. EPA Reference Test Methods 1 and 2 – Volumetric Flow Rate

The sampling location and number of traverse (sampling) points were selected in accordance with U.S. EPA Reference Test Method 1. To determine the minimum number of traverse points, the upstream and downstream distances were equated into equivalent diameters and compared to Figure 1-2 (measuring velocity alone) in U.S. EPA Reference Test Method 1.

Full velocity traverses were conducted in accordance with U.S. EPA Reference Test Method 2 to determine the average stack gas velocity pressure, static pressure and temperature. The velocity and static pressure measurement system consisted of a pitot tube and inclined manometer. The stack gas temperature was measured with a K-type thermocouple and pyrometer.

Stack gas velocity pressure and temperature readings were recorded before and after each test run. The data collected before and after each test run was averaged. The averages were utilized to calculate the volumetric flow rate in accordance with U.S. EPA Reference Test Method 2.

The relative accuracy of the CERMS was determined based on procedures found in 40 CFR 75, Appendices A & B.

#### 3.2 U.S. EPA Reference Test Method 3 – Oxygen/Carbon Dioxide

The oxygen (O<sub>2</sub>) and carbon dioxide (CO<sub>2</sub>) testing was conducted in accordance with U.S. EPA Reference Test Method 3. One (1) integrated Tedlar bag sample was collected during each test run. The bag samples were analyzed on site with a Fyrite O<sub>2</sub>/CO<sub>2</sub> analyzer. The Fyrite solutions were verified by conducting a calibration check with EPA Protocol 1 O<sub>2</sub>/CO<sub>2</sub> gas. The remaining stack gas constituent was assumed to be nitrogen for the stack gas molecular weight determination.

RECEIVED

JAN 05 2024

### **3.3 U.S. EPA Reference Test Method 3A – Oxygen/Carbon Dioxide**

The oxygen (O<sub>2</sub>) and carbon dioxide (CO<sub>2</sub>) testing was conducted in accordance with U.S. EPA Reference Test Method 3A. Data was collected online and reported in one-minute averages. The sampling system consisted of a stainless-steel probe, Teflon sample line(s), gas conditioning system and the identified gas analyzer. The gas conditioning system was a non-contact condenser used to remove moisture from the stack gas. If an unheated Teflon sample line was used, then a portable non-contact condenser was placed in the system directly after the probe. Otherwise, a heated Teflon sample line was used. The quality control measures are described in Section 3.8.

The relative accuracy of the O<sub>2</sub> CEMS was determined based on procedures found in 40 CFR 75, Appendices A & B.

### **3.4 U.S. EPA Reference Test Method 4 – Moisture Content**

The stack gas moisture content (BWS) was determined in accordance with U.S. EPA Reference Test Method 4. The gas conditioning train consisted of a series of chilled impingers. Prior to testing, each impinger was filled with a known quantity of water or silica gel. Each impinger was analyzed gravimetrically before and after each test run on the same balance to determine the amount of moisture condensed.

### **3.5 U.S. EPA Reference Test Method 7E – Nitrogen Oxides**

The nitrogen oxides (NO<sub>x</sub>) testing was conducted in accordance with U.S. EPA Reference Test Method 7E. Data was collected online and reported in one-minute averages. The sampling system consisted of a stainless-steel probe, Teflon sample line(s), gas conditioning system and the identified gas analyzer. The gas conditioning system was a non-contact condenser used to remove moisture from the stack gas. If an unheated Teflon sample line was used, then a portable non-contact condenser was placed in the system directly after the probe. Otherwise, a heated Teflon sample line was used. The quality control measures are described in Section 3.8.

The relative accuracy of the NO<sub>x</sub> CEMS will be determined based on procedures found in 40 CFR 60, Performance Specification 2 and 40 CFR 75, Appendices A & B.

### **3.6 U.S. EPA Reference Test Method 10 – Carbon Monoxide**

The carbon monoxide (CO) testing was conducted in accordance with U.S. EPA Reference Test Method 10. Data was collected online and reported in one-minute averages. The sampling system consisted of a stainless-steel probe, Teflon sample line(s), gas conditioning system, and the identified gas analyzer. The gas conditioning system was a non-contact condenser used to remove moisture from the gas. If an unheated Teflon sample line was used, then a portable non-contact condenser was placed in the system directly after the probe. Otherwise, a heated Teflon sample line was used. The quality control measures are described in Section 3.8.

The relative accuracy of the CO CEMS will be determined based on procedures found in CFR 60, Performance Specification 4.

### **3.7 U.S. EPA Reference Test Method 19 – Mass Emission Factors**

The mass emission factor (lb/MMBtu) were calculated using the pollutant concentration, O<sub>2</sub> concentration and the standard F-factors from USEPA Method 19, Table 19-2.

### 3.8 Quality Assurance/Quality Control – U.S. EPA Reference Test Methods 3A, 7E and 10

#### *EPA Protocol 1 Calibration Gases*

Cylinder calibration gases used met EPA Protocol 1 (+/- 2%) standards. Copies of all calibration gas certificates can be found in the Quality Assurance/Quality Control Appendix.

#### *Direct Calibration & Calibration Error Test*

Low Level gas was introduced directly to the analyzer. After adjusting the analyzer to the Low-Level gas concentration and once the analyzer reading was stable, the analyzer value was recorded. This process was repeated for the High-Level gas. For the Calibration Error Test, Low, Mid, and High Level calibration gases were sequentially introduced directly to the analyzer. All values were within 2.0 percent of the Calibration Span or 0.5 ppmv/% absolute difference.

#### *System Bias and Response Time*

High or Mid Level gas (whichever was closer to the stack gas concentration) was introduced at the probe and the time required for the analyzer reading to reach 95 percent or 0.5 ppmv/% (whichever was less restrictive) of the gas concentration was recorded. The analyzer reading was observed until it reached a stable value, and this value was recorded. Next, Low Level gas was introduced at the probe and the time required for the analyzer reading to decrease to a value within 5.0 percent or 0.5 ppmv/% (whichever was less restrictive) was recorded. If the Low-Level gas was zero gas, the response was 0.5 ppmv/% or 5.0 percent of the upscale gas concentration (whichever was less restrictive). The analyzer reading was observed until it reached a stable value and this value was recorded. The measurement system response time and initial system bias were determined from these data. The System Bias was within 5.0 percent of the Calibration Span or 0.5 ppmv/% absolute difference.

#### *Post Test System Bias Checks*

High or Mid Level gas (whichever was closer to the stack gas concentration) was introduced at the probe. After the analyzer response was stable, the value was recorded. Next, Low Level gas was introduced at the probe, and the analyzer value recorded once it reached a stable response. The System Bias was within 5.0 percent of the Calibration Span or 0.5 ppmv/% absolute difference or the data was invalidated and the Calibration Error Test and System Bias were repeated.

#### *Post Test Drift Checks*

Drift between pre- and post-run System Bias was within 3 percent of the Calibration Span or 0.5 ppmv/% absolute difference. If the drift exceeded 3 percent or 0.5 ppmv/%, the Calibration Error Test and System Bias were repeated.

#### *Stratification Check*

To determine the number of sampling points, a gas stratification check was conducted prior to initiating testing. The pollutant concentrations were measured at three points (16.7, 50.0 and 83.3 percent of the measurement line). Each traverse point was sampled for a minimum of twice the system response time.

If the pollutant concentration at each traverse point did not differ more than 5 percent or 0.5 ppmv/0.3% (whichever was less restrictive) of the average pollutant concentration, then single point sampling was conducted during the test runs. If the pollutant concentration did not meet these specifications but differed less than 10 percent or 1.0 ppmv/0.5% from the average concentration, then three (3) point sampling was conducted (stacks less than 7.8 feet in diameter - 16.7, 50.0 and 83.3 percent of the measurement line; stacks greater than 7.8 feet in diameter – 0.4, 1.0,



and 2.0 meters from the stack wall). If the pollutant concentration differed by more than 10 percent or 1.0 ppmv/0.5% from the average concentration, then sampling was conducted at a minimum of twelve (12) traverse points. Copies of stratification check data can be found in the Quality Assurance/Quality Control Appendix.

*NO<sub>x</sub> Converter Check*

An NO<sub>2</sub> – NO converter check was performed on the analyzer prior to initiating testing and at the completion of testing. An approximately 50 ppm nitrogen dioxide cylinder gas was introduced directly to the NO<sub>x</sub> analyzer and the instrument response was recorded in an electronic data sheet. The instrument response was within +/- 10 percent of the cylinder concentration.

*Data Collection*

A Data Acquisition System with battery backup was used to record the instrument response in one (1) minute averages. The data was continuously stored as a \*.CSV file in Excel format on the hard drive of a computer. At the completion of testing, the data was also saved to the Alliance server. All data was reviewed by the Field Team Leader before leaving the facility. Once arriving at Alliance's office, all written and electronic data was relinquished to the report coordinator and then a final review was performed by the Project Manager.