

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : ADA COGENERATION LIMITED PARTNERSHIP		SRN : N1784
Location : 7575 FULTON STREET EAST BLDG 74-1A		District : Grand Rapids
		County : KENT
City : ADA	State: MI	Zip Code : 49355
Compliance Status :		Compliance
Source Class : MAJOR		Staff : Steve Lachance
FCE Begin Date : 6/18/2013		FCE Completion Date : 6/18/2014
Comments : FY '014 Full Compliance Evaluation		

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
06/18/2014	ROP Annual Cert	Compliance	Required Annual and Semi-Annual ROP Reports; compilation of previously submitted quarterly reports. Review of Semi-Annual Certified Report of Deviations is consistent with previously submitted Quarterly Reports. Deviations are attributed to startup/shutdown and transitory load ramping conditions where water injection rates have not been verified. (SLachance, 6/17/14)
06/18/2014	Self Initiated Inspection	Compliance	Unannounced Inspection/ FCE for '014; self-initiated based on ROP renewal
06/17/2014	Excess Emissions (CEM)	Compliance	1st Quarter 2014 Excess Emissions Report; 99.95% compliance with <1 hour with low water injection rate due to startup. (SLachance, 6/17/14)
06/17/2014	Excess Emissions (CEM)	Compliance	4th Quarter Excess Emissions Report; 2 short, defined periods of apparent low water injection during unit startup totaling 0.19% of operating time; but per established startup procedure. (SLachance, 6/17/14)