

Report of...

Compliance Emission Testing

performed for the...

Grayling Generating Station Grayling, Michigan

on the...

Wood Fired Boiler

October 21-22, 2015

Project #: 106.33

By...

Network Environmental, Inc.
Grand Rapids, MI

RECEIVED
DEC 04 2015
AIR QUALITY DIV.



**RENEWABLE OPERATING PERMIT
REPORT CERTIFICATION**

AIR QUALITY DIV.

Authorized by 1994 P.A. 451, as amended. Failure to provide this information may result in civil and/or criminal penalties.

Reports submitted pursuant to R 336.1213 (Rule 213), subrules (3)(c) and/or (4)(c), of Michigan's Renewable Operating (RO) Permit program must be certified by a responsible official. Additional information regarding the reports and documentation listed below must be kept on file for at least 5 years, as described in General Condition No. 22 in the RO Permit and be made available to the Department of Environmental Quality, Air Quality Division upon request.

Source Name Grayling Generating Station County Crawford
Source Address 4400 W. 4 Mile Rd. City Grayling
AQD Source ID (SRN) N2388 RO Permit No. MI-ROP-N2388-2014 RO Permit Section No. EUBoILER, VII, 7

Please check the appropriate box(es):

Annual Compliance Certification (General Condition No. 28 and No. 29 of the RO Permit)

Reporting period (provide inclusive dates): From _____ To _____

1. During the entire reporting period, this source was in compliance with ALL terms and conditions contained in the RO Permit, each term and condition of which is identified and included by this reference. The method(s) used to determine compliance is/are the method(s) specified in the RO Permit.

2. During the entire reporting period this source was in compliance with all terms and conditions contained in the RO Permit, each term and condition of which is identified and included by this reference, EXCEPT for the deviations identified on the enclosed deviation report(s). The method used to determine compliance for each term and condition is the method specified in the RO Permit, unless otherwise indicated and described on the enclosed deviation report(s).

Semi-Annual (or More Frequent) Report Certification (General Condition No. 23 of the RO Permit)

Reporting period (provide inclusive dates): From _____ To _____

1. During the entire reporting period, ALL monitoring and associated recordkeeping requirements in the RO Permit were met and no deviations from these requirements or any other terms or conditions occurred.

2. During the entire reporting period, all monitoring and associated recordkeeping requirements in the RO Permit were met and no deviations from these requirements or any other terms or conditions occurred, EXCEPT for the deviations identified on the enclosed deviation report(s).


Other Report Certification

Reporting period (provide inclusive dates): From Oct 21, 2015 To Oct 22, 2015

Additional monitoring reports or other applicable documents required by the RO Permit are attached as described:

EUBoILER, VII, 7 + U, 1 → 5 yr test to ensure compliance

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this report and the supporting enclosures are true, accurate and complete, and that any observed, documented or known instances of noncompliance have been reported as deviations, including situations where a different or no monitoring method is specified by the RO Permit.

Philip E. Lewis Plant Manager 989-348-4575x111
Name of Responsible Official (print or type) Title Phone Number
 Date 12/2/15
Signature of Responsible Official

I. INTRODUCTION

Network Environmental, Inc. was retained by the Grayling Generating Station of Grayling, Michigan to conduct a compliance emission study at their facility. The purpose of the study was to meet the emission testing requirements of Renewable Operating Permit (ROP) No. MI-ROP-N2388-2014.

The following is a list of the applicable emission limits for the boiler exhaust:

Emission Limit(s)
Particulate (PM): 0.03 Lbs/MMBTU of Heat Input, 12.0 Lbs/Hr & 25.2 Tons/Year
VOC's: 0.017 Lbs/MMBTU of Heat Input, 8.9 Lbs/Hr & 39.0 Tons/Year
Arsenic (As): 0.02 Lbs/Hr
Cadmium (Cd): 0.012 Lbs/Hr
Total Chromium (Cr): 0.012 Lbs/Hr
Lead (Pb): 0.02 Lbs/Hr & 0.10 Tons/Year
Manganese (Mn): 0.061 Lbs/Hr
Zinc (Zn): 9.5 Lbs/Hr
Benzo-A-Pyrene: 0.005 Lbs/Hr
H₂SO₄: 0.003 Lbs/MMBTU of Heat Input, 1.5 Lbs/Hr & 6.6 Tons/Year

RECEIVED
DEC 04 2015
AIR QUALITY DIV.

The following reference test methods were employed to conduct the emission sampling:

- Particulate Matter – U.S. EPA Method 5 (combined with Method 29)
- VOC's – U.S. EPA Method 25A
- Metals – U.S. EPA Method 29 (combined with Method 5)
- Benzo-A-Pyrene – U.S. EPA Method 23
- H₂SO₄ – U.S. EPA Method 8
- Exhaust Gas Parameters (air flow rate, temperature, moisture & density) – U.S. EPA Methods 1- 4

During the sampling the boiler was firing a combination of wood waste and tire derived fuel (TDF).

The sampling was performed over the period of October 21-22, 2015 by Stephan K. Byrd, R. Scott Cargill, Richard D. Eerdmans, and David D. Engelhardt of Network Environmental, Inc.. Assisting with the study

were Mr. Phil Lewis and the operating staff of the facility. Mr. Jeremy Howe and Ms. Gloria Torello of the Michigan Department of Environmental Quality (MDEQ) - Air Quality Division were present to observe the sampling and source operation.

II. PRESENTATION OF RESULTS

**II.1 TABLE 1
PARTICULATE EMISSION RESULTS
WOOD FIRED BOILER EXHAUST
GRAYLING GENERATING STATION
GRAYLING, MI**

Sample	Date	Time	Air Flow Rate DSCFM ⁽¹⁾	Filterable Particulate Emissions	
				Lbs/Hr ⁽²⁾	Lbs/MMBTU ⁽³⁾
1	10/21/15	16:03-17:22	106,746	10.00	0.019
2	10/21/15	17:58-19:08	109,600	10.48	0.020
3	10/22/15	08:25-09:37	110,240	10.90	0.020
Average			108,862	10.46	0.020

(1) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F and 29.92 in. Hg)
 (2) Lbs/Hr = Pounds Per Hour
 (3) Lbs/MMBTU = Pounds Per Million BTU Of Heat Input (Calculated Using Equation 19-6 From U.S. EPA Method 19 With An F-Factor of 1,830 DSCF/MMBTU)

**II.2 TABLE 2
TOTAL HYDROCARBON (VOC) EMISSION RESULTS
WOOD FIRED BOILER EXHAUST
GRAYLING GENERATING STATION
GRAYLING, MI**

Sample	Date	Time	Air Flow Rate DSCFM ⁽¹⁾	VOC Emissions		
				PPM ⁽²⁾	Lbs/Hr ⁽³⁾	Lbs/MMBTU ⁽⁴⁾
1	10/21/15	12:32-13:32	102,243	0.76	0.53	0.0011
2	10/21/15	13:47-14:47	105,605	0.88	0.64	0.0012
3	10/21/15	15:06-16:06	106,746	0.76	0.55	0.0011
Average			104,865	0.80	0.57	0.0011

(1) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F and 29.92 in. Hg)
 (2) PPM = Parts Per Million (v/v) On A Dry Basis As Propane
 (3) Lbs/Hr = Pounds Per Hour As Propane
 (4) Lbs/MMBTU = Pounds Per Million BTU Of Heat Input (Calculated Using Equation 19-6 From U.S. EPA Method 19 With An F-Factor of 1,830 DSCF/MMBTU)

**II.3 TABLE 3
ARSENIC (As) EMISSION RESULTS
WOOD FIRED BOILER EXHAUST
GRAYLING GENERATING STATION
GRAYLING, MI**

Sample	Date	Time	Air Flow Rate DSCFM ⁽¹⁾	Arsenic (As) Emissions	
				Mg/M ³ ⁽²⁾	Lbs/Hr ⁽³⁾
1	10/21/15	16:03-17:22	106,746	0.0219	0.0088
2	10/21/15	17:58-19:08	109,600	0.0188	0.0077
3	10/22/15	08:25-09:37	110,240	0.0289	0.0119
Average			108,862	0.0232	0.0095

- (1) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F and 29.92 in. Hg)
(2) Mg/M³ = Milligrams Per Dry Standard Cubic Meter
(3) Lbs/Hr = Pounds Per Hour

**II.4 TABLE 4
CADMIUM (Cr) EMISSION RESULTS
WOOD FIRED BOILER EXHAUST
GRAYLING GENERATING STATION
GRAYLING, MI**

Sample	Date	Time	Air Flow Rate DSCFM ⁽¹⁾	Cadmium (Cd) Emissions	
				Mg/M ³ ⁽²⁾	Lbs/Hr ⁽³⁾
1	10/21/15	16:03-17:22	106,746	0.0014	0.00056
2	10/21/15	17:58-19:08	109,600	0.0014	0.00055
3	10/22/15	08:25-09:37	110,240	0.0018	0.00075
Average			108,862	0.0015	0.00062

- (1) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F and 29.92 in. Hg)
(2) Mg/M³ = Milligrams Per Dry Standard Cubic Meter
(3) Lbs/Hr = Pounds Per Hour

**II.5 TABLE 5
TOTAL CHROMIUM (Cr) EMISSION RESULTS
WOOD FIRED BOILER EXHAUST
GRAYLING GENERATING STATION
GRAYLING, MI**

Sample	Date	Time	Air Flow Rate DSCFM ⁽¹⁾	Total Chromium (Cr) Emissions	
				Mg/M ³ ⁽²⁾	Lbs/Hr ⁽³⁾
1	10/21/15	16:03-17:22	106,746	0.0142	0.0057
2	10/21/15	17:58-19:08	109,600	0.0148	0.0061
3	10/22/15	08:25-09:37	110,240	0.0205	0.0085
Average			108,862	0.0165	0.0067

- (1) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F and 29.92 in. Hg)
(2) Mg/M³ = Milligrams Per Dry Standard Cubic Meter
(3) Lbs/Hr = Pounds Per Hour

**II.6 TABLE 6
MANGANESE (Mn) EMISSION RESULTS
WOOD FIRED BOILER EXHAUST
GRAYLING GENERATING STATION
GRAYLING, MI**

Sample	Date	Time	Air Flow Rate DSCFM ⁽¹⁾	Manganese (Mn) Emissions	
				Mg/M ³ ⁽²⁾	Lbs/Hr ⁽³⁾
1	10/21/15	16:03-17:22	106,746	0.0765	0.0306
2	10/21/15	17:58-19:08	109,600	0.1195	0.0490
3	10/22/15	08:25-09:37	110,240	0.0939	0.0388
Average			108,862	0.0966	0.0395

- (1) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F and 29.92 in. Hg)
(2) Mg/M³ = Milligrams Per Dry Standard Cubic Meter
(3) Lbs/Hr = Pounds Per Hour

**II.7 TABLE 7
LEAD (Pb) EMISSION RESULTS
WOOD FIRED BOILER EXHAUST
GRAYLING GENERATING STATION
GRAYLING, MI**

Sample	Date	Time	Air Flow Rate DSCFM ⁽¹⁾	Lead (Pb) Emissions	
				Mg/M ³ ⁽²⁾	Lbs/Hr ⁽³⁾
1	10/21/15	16:03-17:22	106,746	0.0260	0.0104
2	10/21/15	17:58-19:08	109,600	0.0230	0.0094
3	10/22/15	08:25-09:37	110,240	0.0292	0.0120
Average			108,862	0.0260	0.0106

- (1) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F and 29.92 in. Hg)
 (2) Mg/M³ = Milligrams Per Dry Standard Cubic Meter
 (3) Lbs/Hr = Pounds Per Hour

**II.8 TABLE 8
ZINC (Zn) EMISSION RESULTS
WOOD FIRED BOILER EXHAUST
GRAYLING GENERATING STATION
GRAYLING, MI**

Sample	Date	Time	Air Flow Rate DSCFM ⁽¹⁾	Zinc (Zn) Emissions	
				Mg/M ³ ⁽²⁾	Lbs/Hr ⁽³⁾
1	10/21/15	16:03-17:22	106,746	2.87	1.15
2	10/21/15	17:58-19:08	109,600	3.30	1.36
3	10/22/15	08:25-09:37	110,240	2.98	1.23
Average			108,862	3.05	1.25

- (1) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F and 29.92 in. Hg)
 (2) Mg/M³ = Milligrams Per Dry Standard Cubic Meter
 (3) Lbs/Hr = Pounds Per Hour

**II.9 TABLE 9
 BENZO-A-PYRENE EMISSION RESULTS
 WOOD FIRED BOILER EXHAUST
 GRAYLING GENERATING STATION
 GRAYLING, MI**

Sample	Date	Time	Air Flow Rate DSCFM ⁽¹⁾	Benzo-A-Pyrene Emissions	
				ug/M ³ ⁽²⁾	Lbs/Hr ⁽³⁾
1	10/22/15	10:53-12:09	106,336	4.50E-03	1.79E-06
2	10/22/15	13:04-14:17	111,446	4.45E-03	1.86E-06
3	10/22/15	15:05-16:16	110,469	4.26E-03	1.76E-06
Average			109,417	4.40E-03	1.80E-06

- (1) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F and 29.92 in. Hg)
 (2) ug/M³ = Micrograms Per Dry Standard Cubic Meter (STP = 68 °F and 29.92 in. Hg)
 (3) Lbs/Hr = Pounds Per Hour

**II.10 TABLE 10
 SULFURIC ACID (H₂SO₄) EMISSION RESULTS
 WOOD FIRED BOILER EXHAUST
 GRAYLING GENERATING STATION
 GRAYLING, MI**

Sample	Date	Time	Air Flow Rate DSCFM ⁽¹⁾	Sulfuric Acid (H ₂ SO ₄) Emissions		
				Mg/M ³ ⁽²⁾	Lbs/Hr ⁽³⁾	Lbs/MMBTU ⁽⁴⁾
1	10/21/15	10:05-11:20	104,320	0.33	0.13	0.00026
2	10/21/15	11:52-13:04	102,243	0.31	0.12	0.00025
3	10/21/15	13:38-14:52	105,605	0.42	0.17	0.00032
Average			104,056	0.36	0.14	0.00027

- (1) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F and 29.92 in. Hg)
 (2) Mg/M³ = Milligrams Per Dry Standard Cubic Meter (STP = 68 °F and 29.92 in. Hg)
 (3) Lbs/Hr = Pounds Per Hour
 (4) Lbs/MMBTU = Pounds Per Million BTU Of Heat Input (Calculated Using Equation 19-6 From U.S. EPA Method 19 With An F-Factor of 1,830 DSCF/MMBTU).

III. DISCUSSION OF RESULTS

The results of the emission sampling are summarized in Tables 1 through 10 (Sections II.1 through II.10).

The results are presented as follows:

III.1 Particulate Emission Results (Table 1)

Table 1 summarizes the particulate emission results as follows:

- Sample
- Date
- Time
- Air Flow Rate (DSCFM) - Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- Particulate Mass Emission Rates:
 - ✧ Lbs/Hr - Pounds of Particulate Per Hour
 - ✧ Lbs/MMBTU - Pounds of Particulate Per Million BTU of Heat Input (Calculated Using Equation 19-6 From U.S. EPA Method 19 With An F-Factor of 1,830 DSCF/MMBTU)

III.2 VOC Emission Results (Table 2)

Table 2 summarizes the total hydrocarbon (VOC) emission results as follows:

- Sample
- Date
- Time
- Air Flow Rate (SCFM) - Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- VOC Concentrations (PPM) - Parts Per Million (v/v) On A Dry Basis As Propane
- VOC Mass Emission Rates:
 - ✧ Lbs/Hr - Pounds of VOC Per Hour As Propane
 - ✧ Lbs/MMBTU - Pounds of VOC Per Million BTU of Heat Input (Calculated Using Equation 19-6 From U.S. EPA Method 19 With An F-Factor of 1,830 DSCF/MMBTU)

III.3 Arsenic (As) Emission Results (Table 3)

Table 3 summarizes the arsenic (As) emission results as follows:

- Sample
- Date
- Time
- Air Flow Rate (DSCFM) - Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- Arsenic (As) Concentrations (Mg/M³) - Milligrams Per Dry Standard Cubic Meter

- Arsenic (As) Mass Emission Rates (Lbs/Hr) - Pounds of Arsenic Per Hour

III.4 Cadmium (Cd) Emission Results (Table 4)

Table 4 summarizes the cadmium (Cd) emission results as follows:

- Sample
- Date
- Time
- Air Flow Rate (DSCFM) - Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- Cadmium (Cd) Concentrations (Mg/M³) - Milligrams Per Dry Standard Cubic Meter
- Cadmium (Cd) Mass Emission Rates (Lbs/Hr) - Pounds of Cadmium Per Hour

III.5 Total Chromium (Cr) Emission Results (Table 5)

Table 5 summarizes the total chromium (Cr) emission results as follows:

- Sample
- Date
- Time
- Air Flow Rate (DSCFM) - Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- Total Chromium (Cr) Concentrations (Mg/M³) - Milligrams Per Dry Standard Cubic Meter
- Total Chromium (Cr) Mass Emission Rates (Lbs/Hr) - Pounds of Total Chromium Per Hour

III.6 Manganese (Mn) Emission Results (Table 6)

Table 6 summarizes the manganese (Mn) emission results as follows:

- Sample
- Date
- Time
- Air Flow Rate (DSCFM) - Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- Manganese (Mn) Concentrations (Mg/M³) - Milligrams Per Dry Standard Cubic Meter
- Manganese (Mn) Mass Emission Rates (Lbs/Hr) - Pounds of Manganese Per Hour

III.7 Lead (Pb) Emission Results (Table 7)

Table 7 summarizes the lead (Pb) emission results as follows:

- Sample
- Date
- Time
- Air Flow Rate (DSCFM) - Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)

- Lead (Pb) Concentrations (Mg/M³) - Milligrams Per Dry Standard Cubic Meter
- Lead (Pb) Mass Emission Rates (Lbs/Hr) - Pounds of Lead Per Hour

III.8 Zinc (Zn) Emission Results (Table 8)

Table 8 summarizes the Zinc (Zn) emission results as follows:

- Sample
- Date
- Time
- Air Flow Rate (DSCFM) - Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- Zinc (Zn) Concentrations (Mg/M³) - Milligrams Per Dry Standard Cubic Meter
- Zinc (Zn) Mass Emission Rates (Lbs/Hr) - Pounds of Zinc Per Hour

III.9 Benzo-A-Pyrene Emission Results (Table 9)

Table 9 summarizes the benzo-a-pyrene emission results as follows:

- Sample
- Date
- Time
- Air Flow Rate (DSCFM) - Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- Benzo-A-Pyrene Concentration (ug/M³) - Micrograms Per Dry Standard Cubic Meter
- Benzo-A-Pyrene Mass Emission Rate (Lbs/Hr) - Pounds of Benzo-A-Pyrene Per Hour

III.10 Sulfuric Acid (H₂SO₄) Emission Results (Table 10)

Table 10 summarizes the sulfuric acid (H₂SO₄) emission results as follows:

- Sample
- Date
- Time
- Air Flow Rate (DSCFM) - Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- Sulfuric Acid (H₂SO₄) Concentrations (Mg/M³) - Milligrams Per Dry Standard Cubic Meter
- Sulfuric Acid (H₂SO₄) Mass Emission Rates:
 - ✧ Lbs/Hr - Pounds of Sulfuric Acid Per Hour
 - ✧ Lbs/MMBTU - Pounds of Sulfuric Acid Per Million BTU of Heat Input (Calculated Using Equation 19-6 From U.S. EPA Method 19 With An F-Factor of 1,830 DSCF/MMBTU)

IV. SAMPLING AND ANALYTICAL PROTOCOL

The sampling location for the boiler exhaust was on the 92 inch diameter exhaust at a location that meets the 8 duct diameter downstream and 2 duct diameter upstream requirement of U.S. EPA Method 1. There are 4 sample ports. Twelve (12) sampling points (3 per port) were used for the isokinetic sampling. The sampling point dimensions were as follows:

<u>Sample Point</u>	<u>Dimension (Inches)</u>
1	4.04
2	13.43
3	27.23

IV.1 Particulate & Metals – The particulate and metals sampling was conducted by employing U.S. EPA Method 29 (combined with Method 5). This is an out of stack filtration method, where the sampling probe and filter are heated at 250 °F (plus or minus 25 °F).

Three (3) samples were collected from the boiler exhaust stack. Each sample was sixty (60) minutes in duration. Each sample had a minimum sample volume of thirty (30) dry standard cubic feet. The samples were collected isokinetically on quartz filters and in a nitric acid/hydrogen peroxide solution.

The filters and nozzle/probe rinses (front half) were analyzed gravimetrically for particulates in accordance with U.S. EPA Method 5. The nozzle/probe rinses, filters and nitric acid/hydrogen peroxide solutions were analyzed for all the above listed metals by inductively coupled argon plasma/mass spectrophotometry (ICAP/MS) analysis in accordance with Method 29. All the quality assurance and quality control procedures listed in the method were incorporated in the sampling and analysis. Figure 1 is a diagram of the sampling train.

IV.2 VOC – The total hydrocarbon (VOC) emission sampling was conducted in accordance with U.S. EPA Reference Method 25A. A J.U.M. Model 3-500 flame ionization detector (FID) analyzer was used to monitor the boiler exhaust. Sample gas was extracted through a heated probe. A heated teflon sample line was used to transport the exhaust gases to the analyzer. The analyzer produces instantaneous readouts of the VOC concentrations (PPM).

The analyzer was calibrated by system injection (from the back of the stack probe to the analyzer) prior to the testing. A span gas of 96.49 PPM was used to establish the initial instrument calibration. Calibration gases of 29.17 PPM and 50.19 PPM were used to determine the calibration error of the analyzer. After each sample, a system zero and system injection of 29.17 PPM were performed to establish system drift and system bias during the test period. All calibration gases used were EPA Protocol Propane Calibration Gases. Three (3) samples were collected from the boiler exhaust. Each sample was sixty (60) minutes in duration.

The analyzer was calibrated to the output of the data acquisition system (DAS) used to collect the data from the boiler exhaust. All reference method data was corrected using Equation 7E-5 from U.S. EPA Method 7E. Figure 2 is a diagram of the Method 25A VOC sampling train.

IV.3 Benzo-A-Pyrene – The benzo-a-pyrene emission sampling was performed in accordance with U.S. EPA Method 23. A Modified Method 5 (MM5) sampling train, as described in Method 23, was used to collect the samples. The sampling train consisted of a heated glass lined probe followed by a heated pre-cleaned quartz filter. A condenser coil followed by an XAD sorbent trap followed the heated filter. An impinger train containing HPLC water followed the XAD trap. All sampling train components were pre-cleaned in accordance with the method.


Three (3) samples were collected. Each sample was sixty (60) minutes in duration, and had a minimum sample volume of thirty (30) dry standard cubic feet. The sampling system operation was consistent with U.S. EPA Method 5. The three samples and the blank train were recovered in pre-cleaned sample bottles with Teflon lined caps. The probe rinse and filter rinse were combined with the XAD extract for analysis. The back-half impinger condensate was also analyzed. The analytes were extracted from the sample, separated by high resolution gas chromatography, and measured by high resolution mass spectrometry. The analysis followed the procedures of SW-846 Method 8290. All the quality assurance and quality control procedures listed in the methods were incorporated in the sampling and analysis. Figure 3 is a diagram of the Method 23 sampling train.

IV.4 Sulfuric Acid – The sulfuric acid determinations were conducted in accordance with U.S. EPA Method 8. The exhaust gas was extracted through a heated probe which lead to an impinger train. The first impinger contained 80% isopropyl alcohol (IPA), which is where the sulfuric acid was collected. The samples were collected isokinetically as described in the method. Immediately following each sample, a twenty (20) minute purge (at approximately the average sampling rate) using ambient air was performed

on the impinger train. The purge is designed to remove any SO₂ that might remain in the first impinger. The sulfuric acid content in the samples was determined by the barium thorin titration technique described in the method. Three (3) samples, were collected. Each sample was sixty (60) minutes in duration and had a minimum sample volume of thirty (30) dry standard cubic feet. All the quality assurance and quality control requirements of the method will be incorporated in the sampling and analysis. The sulfuric acid sampling train is shown in Figure 4.


IV.5 Exhaust Gas Parameters – The exhaust gas parameters (air flow rate, temperature, moisture and density) were determined in conjunction with the other sampling by employing U.S. EPA Methods 1 through 4. Air flow rates, temperatures, moistures and densities were determined using the Isokinetic sampling trains. All the quality assurance and quality control procedures listed in the methods were incorporated in the sampling and analysis.

This report was prepared by:



David D. Engelhardt
Vice President

This report was reviewed by:



Stephan K. Byrd
President




Figure 1
Particulate & Metals
Sampling Train




Figure 2

VOC
Sampling Train




Figure 3
Benzo-A-Pyrene
Sampling Train




Figure 4
 H_2SO_4
Sampling Train