

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION
ACTIVITY REPORT: Scheduled Inspection

N295539094

FACILITY: KINROSS CORRECTIONAL FACILITY		SRN / ID: N2955
LOCATION: 16770 South Watertower Drive, KINCHELOE		DISTRICT: Upper Peninsula
CITY: KINCHELOE		COUNTY: CHIPPEWA
CONTACT: JOHN REICHHARDT , BOILER OPERATOR		ACTIVITY DATE: 03/28/2017
STAFF: Joel Asher	COMPLIANCE STATUS: Compliance	SOURCE CLASS: SM OPT OUT
SUBJECT: PTI#215-15		
RESOLVED COMPLAINTS:		

PTI #215-15 was issued on 1/12/16 to the Michigan Department of Corrections for the Kinross Correctional Facility. The permit includes conditions applicable to three natural gas/fuel oil boilers and six diesel-fueled reciprocating internal combustion emergency generators. This facility is scheduled for an annual inspection based on the FY 2017 Compliance Monitoring Strategy (CMS).

On 3/28/17 I conducted an unannounced inspection of this facility. My contact was Mr. John Reichhardt, boiler operator. Mr. Reichhardt has been relocated to this facility in the last few months. The primary operator, Mr. Rick Burd was out of the area for the week.

Mr. Reichhardt stated the three boilers (EU-BOILER1, EU-BOILER2, and EU-BOILER3) have been taken out of service. On 2/22/17 the units were shut down and have been drained. At the time of this inspection, Mr. Reichhardt was capping the natural gas line to the units. There is no plan to restart the boilers in the future.

It was not clear if the six diesel-fueled reciprocating internal combustion emergency generators are still in operation. Mr. Reichhardt was not knowledgeable of the units. I left a copy of my business card with Mr. Reichhardt and asked him to have Mr. Burd call me when he returns next week.

Staff will stop by the facility at a later date to determine the RICE generators compliance with PTI #215-15.

NAME  DATE 3/29/17 SUPERVISOR 