

**AIR EMISSION TEST REPORT**

Title AIR EMISSION TEST REPORT FOR THE LANDFILL
 GAS FUELED INTERNAL COMBUSTION ENGINES
 OPERATED AT THE ORCHARD HILL SANITARY
 LANDFILL

Report Date March 16, 2016

Test Dates February 17, 2016

RECEIVED

MAR 28 2016

AIR QUALITY DIV.

Facility Information	
Name	Granger Electric of Watervliet
Street Address	3290 Hennesey Road
City, County	Watervliet, Berrien

Facility Permit Information	
ROP No.:	MI-ROP-N5917-2011a
Facility SRN :	N5917

Testing Contractor	
Company	Derenzo Environmental Services
Mailing Address	39395 Schoolcraft Road Livonia, MI 48150
Phone	(734) 464-3880
Project No.	1508006



MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

RECEIVED

MAR 28 2016

AIR QUALITY DIVISION

**RENEWABLE OPERATING PERMIT
REPORT CERTIFICATION**

Authorized by 1994 P.A. 451, as amended. Failure to provide this information may result in civil and/or criminal penalties.

Reports submitted pursuant to R 336.1213 (Rule 213), subrules (3)(c) and/or (4)(c), of Michigan's Renewable Operating Permit (ROP) program must be certified by a responsible official. Additional information regarding the reports and documentation listed below must be kept on file for at least 5 years, as specified in Rule 213(3)(b)(ii), and be made available to the Department of Environmental Quality, Air Quality Division upon request.

Source Name Granger Electric Company-Orchard Hill Gen. Station County Berrien
Source Address 3290 Hennesy Road City Watervliet
AQD Source ID (SRN) N5719 ROP No. MI-ROP-N5719 ROP Section No. 2
2011a

Please check the appropriate box(es):

☐ **Annual Compliance Certification (Pursuant to Rule 213(4)(c))**

Reporting period (provide inclusive dates): From _____ To _____

- ☐ 1. During the entire reporting period, this source was in compliance with **ALL** terms and conditions contained in the ROP, each term and condition of which is identified and included by this reference. The method(s) used to determine compliance is/are the method(s) specified in the ROP.
- ☐ 2. During the entire reporting period this source was in compliance with all terms and conditions contained in the ROP, each term and condition of which is identified and included by this reference, **EXCEPT** for the deviations identified on the enclosed deviation report(s). The method used to determine compliance for each term and condition is the method specified in the ROP, unless otherwise indicated and described on the enclosed deviation report(s).

☐ **Semi-Annual (or More Frequent) Report Certification (Pursuant to Rule 213(3)(c))**

Reporting period (provide inclusive dates): From _____ To _____

- ☐ 1. During the entire reporting period, **ALL** monitoring and associated recordkeeping requirements in the ROP were met and no deviations from these requirements or any other terms or conditions occurred.
- ☐ 2. During the entire reporting period, all monitoring and associated recordkeeping requirements in the ROP were met and no deviations from these requirements or any other terms or conditions occurred, **EXCEPT** for the deviations identified on the enclosed deviation report(s).

☒ **Other Report Certification**

Reporting period (provide inclusive dates): From _____ To _____

Additional monitoring reports or other applicable documents required by the ROP are attached as described:

Test report prepared by Derenzo Environmental Seivices, dated March 16, 2016 for the
measurement of emissions from two (2) CAT 3520 IC Engines identified as EUCENGINE1
and EUCENGINE2 in PTI No. 98-12. Test dates: February 17, 2016.

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this report and the supporting enclosures are true, accurate and complete

Marc Pauley Director of Operations (517) 372-8330
Name of Responsible Official (print or type) Title Phone Number

Signature of Responsible Official

Date

3.18.16

* Photocopy this form as needed.

EQP 5736 (Rev 11-04)

AIR EMISSION TEST REPORT
FOR THE
VERIFICATION OF AIR POLLUTANT EMISSIONS
FROM
LANDFILL GAS FUELED INTERNAL COMBUSTION ENGINES

GRANGER ELECTRIC OF WATERVLIET
AT THE ORCHARD HILL SANITARY LANDFILL

1.0 INTRODUCTION

Granger Electric (Granger) operates two (2) Caterpillar (CAT®) Model No. G3520C gas fueled internal combustion (IC) engines and electricity generator sets at the Orchard Hill Sanitary Landfill in Watervliet, Berrien County, Michigan. The two (2) landfill gas (LFG) fueled IC engine-generator sets are identified as emission units EUICEENGINE1-S2 and EUICEENGINE2-S2 (collectively flexible emission group FGICEENGINES-S2) in Section 2 of Michigan Renewable Operating Permit (ROP) No. MI-ROP-N5917-2011a issued by the Michigan Department of Environmental Quality (MDEQ).

The conditions of MI-ROP-N5917-2011a:

1. Allow for the installation and operation of two (2) spark ignition, lean burn reciprocating internal combustion engine (RICE) and electricity generation sets (CAT® Model G3520C) that have a rated horsepower (hp) output of 2,233 at full load.
2. Specify that ... *The permittee shall conduct an initial performance test for each engine in FGICEENGINES-S2, to verify NOx, CO, and VOC emission rates...and subsequent performance testing every 8760 hours of operation or three years, whichever occurs first, to demonstrate compliance.*

The compliance testing was performed by Derenzo Environmental Services (DES), a Michigan-based environmental consulting and testing company. DES representatives Jason Logan and Jeffrey Schlaf performed the field sampling and measurements February 17, 2016.

The exhaust gas sampling and analysis was performed using procedures specified in the Test Plan dated October 30, 2015 that was reviewed and approved by the MDEQ-AQD. Mr. Tom Gasloli of the MDEQ-AQD was on-site to observe the testing project.

Derenzo Environmental Services

Granger Electric of Watervliet
Air Emission Test Report

March 16, 2016
Page 2

Questions regarding this emission test report should be directed to:

Jason Logan
Environmental Consultant
Derenzo Environmental Services
39395 Schoolcraft Road
Livonia, MI 48150
Ph: (734) 464-3880

Mr. Dan Zimmerman
Director of Operations and Compliance
Granger Electric Company
16980 Wood Road
Lansing, MI 48906
Ph: (517) 371-9711

Report Certification

This test report was prepared by Derenzo Environmental Services based on field sampling data collected by Derenzo Environmental Services. Facility process data were collected and provided by Granger employees or representatives. This test report has been reviewed by Granger representatives and approved for submittal to the MDEQ-AQD. A test report certification form (EQP 5736) is submitted with this report.

I certify that the testing was conducted in accordance with the specified test methods and submitted test plan unless otherwise specified in this report. I believe the information provided in this report and its attachments are true, accurate, and complete.

Report Prepared By:



Blake Beddow
Environmental Consultant
Derenzo Environmental Services

Reviewed By:



Robert L. Harvey, P.E.
General Manager
Derenzo Environmental Services

2.0 SOURCE AND SAMPLING LOCATION DESCRIPTION

2.1 General Process Description

Landfill gas (LFG) containing methane is generated in the Orchard Hill Sanitary Landfill from the anaerobic decomposition of disposed waste materials. The LFG is collected from both active and capped landfill cells using a system of wells (gas collection system). The collected LFG is transferred to the Granger LFG power station facility where it is treated and used as fuel for the two (2) RICE. Each RICE is connected to an electricity generator that produces electricity that is transferred to the local utility.

2.2 Rated Capacities and Air Emission Controls

The CAT® Model No. G3520C RICE has a rated output of 2,233 brake-horsepower (bhp) and the connected generator has a rated electricity output of 1,600 kilowatts (kW). The engine is designed to fire low-pressure, lean fuel mixtures (e.g., LFG) and is equipped with an air-to-fuel ratio controller that monitors engine performance parameters and automatically adjusts the air-to-fuel ratio and ignition timing to maintain efficient fuel combustion.

The RICE generator sets are not equipped with add-on emission control devices. Air pollutant emissions are minimized through the proper operation of the gas treatment system and efficient fuel combustion in the engines.

The fuel consumption rate is regulated automatically to maintain the heat input rate required to support engine operations and is dependent on the fuel heat value (methane content) of the treated LFG.

2.3 Sampling Locations

The RICE exhaust gas is directed through mufflers and is released to the atmosphere through dedicated vertical exhaust stacks. The two (2) CAT® Model G3520C RICE exhaust stacks are identical.

The exhaust stack sampling ports for the CAT® Model G3520C engines (EUICEENGINE1-S2 – EUICEENGINE2-S2) are located in individual exhaust stacks with an inner diameter of 13.25 inches. Each stack is equipped with two (2) sample ports, opposed 90°, that provide a sampling location greater than 6.6 inches (0.5 duct diameters) upstream and greater than 26.5 inches (2 duct diameters) downstream from any flow disturbance and satisfies the USEPA Method 1 criteria for a representative sample location.

Individual traverse points were determined in accordance with USEPA Method 1.

Appendix 1 provides diagrams of the emission test sampling location.

3.0 SUMMARY OF TEST RESULTS AND OPERATING CONDITIONS**3.1 Purpose and Objective of the Tests**

The conditions of ROP No. MI-ROP-N5917-2011a and 40 CFR Part 60 Subpart JJJJ require Granger to test each engine contained in FGICEENGINES-S2 for carbon monoxide (CO), nitrogen oxides (NO_x) and volatile organic compounds (VOCs) every 8,760 hours of operation.

3.2 Operating Conditions During the Compliance Tests

The testing was performed while the Granger RICE generator sets were operated at maximum operating conditions (1,600 kW electricity output +/- 10%). Granger representatives provided the generator electricity output (kW) in 15-minute intervals for each test period. The generator kW output ranged between 1,564 and 1,612 kW during the test periods.

Fuel flowrate (scfm) and fuel methane content (%), were also recorded by Granger representatives at 15-minute intervals for each test period. The FGENGINES fuel consumption rate ranged between 585 and 618 scfm and fuel methane content ranged between 47.3 and 48.7%

In addition, the engine serial number and operating hours at the beginning of test No. 1 were recorded by the facility operators.

Appendix 2 provides operating records provided by Granger representatives for the test periods.

Engine output (bhp) cannot be measured directly and was calculated based on the recorded electricity output, the calculated CAT® Model G3520C generator efficiency (96.1%), and the unit conversion factor for kW to horsepower (0.7457 kW/hp).

$$\text{Engine output (bhp)} = \text{Electricity output (kW)} / (0.961) / (0.7457 \text{ kW/hp})$$

Table 3.1 presents a summary of the average engine operating conditions during the test periods.

3.3 Summary of Air Pollutant Sampling Results

The gases exhausted from the LFG fueled RICE (EUICEENGINE1-S2 and EUICEENGINE2-S2) were each sampled for three (3) one-hour test periods during the compliance testing performed February 17, 2016.

Table 3.2 presents the average measured CO, NO_x and VOC emission rates for the engines (average of the three test periods for each engine).

Test results for each one hour sampling period are presented in Section 6.0 of this report.

Derenzo Environmental Services

Granger Electric of Watervliet
Air Emission Test Report

March 16, 2016
Page 5

Table 3.1 Average engine operating conditions during the test periods

Engine Parameter	EUICEEENGINE1-S2	EUICEEENGINE2-S2
Generator output (kW)	1,595	1,587
Engine output (bhp)	2,226	2,215
Engine LFG fuel use (scfm)	594	608
LFG methane content (%)	48.2	48.4
Exhaust temperature (°F)	799	799

Table 3.2 Average measured emission rates for each engine (three-test average)

Emission Unit	CO Emission Rates		NOx Emission Rates		VOC Emission Rates
	(lb/hr)	(g/bhp-hr)	(lb/hr)	(g/bhp-hr)	(g/bhp-hr)
Engine No. 1	13.1	2.66	1.87	0.38	0.13
Engine No. 2	13.3	2.73	1.72	0.35	0.13
Permit Limit	17.3	3.5	4.94	1.0	1.0

4.0 SAMPLING AND ANALYTICAL PROCEDURES

A test protocol for the air emission testing was reviewed and approved by the MDEQ-AQD. This section provides a summary of the sampling and analytical procedures that were used during the testing periods.

4.1 Summary of Sampling Methods

USEPA Method 1	Exhaust gas velocity measurement locations were determined based on the physical stack arrangement and requirements in USEPA Method 1
USEPA Method 2	Exhaust gas velocity pressure was determined using a Type-S Pitot tube connected to a red oil incline manometer; temperature was measured using a K-type thermocouple connected to the Pitot tube.
USEPA Method 3A	Exhaust gas O ₂ and CO ₂ content was determined using zirconia ion/paramagnetic and infrared instrumental analyzers, respectively.
USEPA Method 4	Exhaust gas moisture was determined based on the water weight gain in chilled impingers.
USEPA Method 7E	Exhaust gas NO _x concentration was determined using chemiluminescence instrumental analyzers.
USEPA Method 10	Exhaust gas CO concentration was measured using an NDIR instrumental analyzer
USEPA Method 25A / ALT-096	Exhaust gas VOC (as NMHC) concentration was determined using a flame ionization analyzer equipped with methane separation column

4.2 Exhaust Gas Velocity Determination (USEPA Method 2)

The RICE exhaust stack gas velocities and volumetric flow rates were determined using USEPA Method 2 prior to and after each test. An S-type Pitot tube connected to a red-oil manometer was used to determine velocity pressure at each traverse point across the stack cross section. Gas temperature was measured using a K-type thermocouple mounted to the Pitot tube. The Pitot tube and connective tubing were leak-checked periodically to verify the integrity of the measurement system.

The absence of significant cyclonic flow for the exhaust configuration was verified using an S-type Pitot tube and oil manometer. The Pitot tube was positioned at each velocity traverse point with the planes of the face openings of the Pitot tube perpendicular to the stack cross-sectional

plane. The Pitot tube was then rotated to determine the null angle (rotational angle as measured from the perpendicular, or reference, position at which the differential pressure is equal to zero). Appendix 3 provides exhaust gas flowrate calculations and field data sheets.

4.3 Exhaust Gas Molecular Weight Determination (USEPA Method 3A)

CO₂ and O₂ content in the RICE exhaust gas stream was measured continuously throughout each test period in accordance with USEPA Method 3A. The CO₂ content of the exhaust was monitored using a single beam single wavelength (SBSW) infrared gas analyzer. The O₂ content of the exhaust was monitored using a gas analyzer that uses a paramagnetic sensor.

During each sampling period, a continuous sample of the RICE exhaust gas stream was extracted from the stack using a stainless steel probe connected to a Teflon® heated sample line. The sampled gas was conditioned by removing moisture prior to being introduced to the analyzers; therefore, measurement of O₂ and CO₂ concentrations correspond to standard dry gas conditions. Instrument response data were recorded using an ESC Model 8816 data acquisition system that monitored the analog output of the instrumental analyzers continuously and logged data as one-minute averages.

Prior to, and at the conclusion of each test, the instruments were calibrated using upscale calibration and zero gas to determine analyzer calibration error and system bias (described in Section 5.0 of this document). Sampling times were recorded on field data sheets.

Appendix 4 provides O₂ and CO₂ calculation sheets. Raw instrument response data are provided in Appendix 5.

4.4 Exhaust Gas Moisture Content (USEPA Method 4)

Moisture content of the RICE exhaust gas was determined in accordance with USEPA Method 4 using a chilled impinger sampling train. The moisture sampling was performed concurrently with the instrumental analyzer sampling. During each sampling period a gas sample was extracted at a nonisokinetic rate from the source where moisture was removed from the sampled gas stream using impingers that were submersed in an ice bath. At the conclusion of each sampling period, the moisture gain in the impingers was determined gravimetrically by weighing each impinger to determine net weight gain.

4.5 NO_x and CO Concentration Measurements (USEPA Methods 7E and 10)

NO_x and CO pollutant concentrations in the RICE exhaust gas stream was determined using a chemiluminescence NO_x analyzer and an infrared CO analyzer.

Throughout each test period, a continuous sample of the engine exhaust gas was extracted from the stack using the Teflon® heated sample line and gas conditioning system and delivered to the instrumental analyzers. Instrument response for each analyzer was recorded on an ESC Model 8816

data acquisition system that logged data as one-minute averages. Prior to, and at the conclusion of each test, the instruments were calibrated using upscale calibration and zero gas to determine analyzer calibration error and system bias.

Appendix 4 provides CO and NO_x calculation sheets. Raw instrument response data are provided in Appendix 5.

4.6 Measurement of Volatile Organic Compounds (USEPA Method 25A/ALT-096)

VOC emission rate was determined by measuring the nonmethane hydrocarbon (NMHC) concentration in the RICE exhaust gas. NMHC pollutant concentration was determined using a Thermo Environmental Instruments (TEI) Model 55i Methane / Nonmethane hydrocarbon analyzer. The TEI 55i analyzer contains an internal gas chromatograph column that separates methane from non-methane components and has been approved by the USEPA for measuring VOC relative to 40 CFR Part 60 Subpart JJJJ compliance test demonstrations (Alternative Test Method 096). The concentration of NMHC in the sampled gas stream, after separation from methane, is determined relative to a propane standard using a flame ionization detector in accordance with USEPA Method 25A.

Three (3) one-hour sampling periods were performed on each RICE exhaust. Throughout each one-hour test period, a continuous sample of the RICE exhaust gas was extracted from the stack using the Teflon® heated sample line described in Section 4.3 of this document, and delivered to the instrumental analyzer. The sampled gas was not conditioned prior to being introduced to the analyzer; therefore, the measurement of NMHC concentration corresponds to standard wet gas conditions. Instrument NMHC (VOC) response for the analyzer was recorded on an ESC Model 8816 data logging system that monitored the analog output of the instrumental analyzers continuously and logged data as one-minute averages. Prior to, and at the conclusion of each test, the instrument was calibrated using low-range calibration and zero gas to determine analyzer calibration error and system bias (described in Section 5.0 of this document).

Appendix 4 provides VOC calculation sheets. Raw instrument response data for the NMHC analyzer is provided in Appendix 5.

5.0 QA/QC ACTIVITIES

5.1 NO_x Converter Efficiency Test

The NO₂ – NO conversion efficiency of the chemiluminescence NO_x analyzer was verified prior to the testing program. A USEPA Protocol 1 certified concentration of NO₂ was injected directly into the analyzer, following the initial three-point calibration, to verify the analyzer's conversion efficiency. The analyzer's NO₂ – NO converter uses a catalyst at high temperatures to convert the NO₂ to NO for measurement. The conversion efficiency of the analyzer is deemed acceptable if the measured NO₂ concentration is at least 90% of the expected value.

The NO₂ – NO conversion efficiency test satisfied the USEPA Method 7E criteria (measured NO₂ concentration was 91.7% of the expected value, i.e., greater than 90% of the expected value as required by Method 7E).

5.2 Gas Divider Certification (USEPA Method 205)

A STEC Model SGD-710C 10-step gas divider was used to obtain appropriate calibration span gases. The ten-step STEC gas divider was NIST certified (within the last 12 months) with a primary flow standard in accordance with Method 205. When cut with an appropriate zero gas, the ten-step STEC gas divider delivered calibration gas values ranging from 0% to 100% (in 10% step increments) of the USEPA Protocol 1 calibration gas that was introduced into the system. The field evaluation procedures presented in Section 3.2 of Method 205 were followed prior to use of gas divider. The field evaluation yielded no errors greater than 2% of the triplicate measured average and no errors greater than 2% from the expected values.

5.3 Instrumental Analyzer Interference Check

The instrumental analyzers used to measure NO_x, CO, O₂ and CO₂ have had an interference response test preformed prior to their use in the field, pursuant to the interference response test procedures specified in USEPA Method 7E. The appropriate interference test gases (i.e., gases that would be encountered in the exhaust gas stream) were introduced into each analyzer, separately and as a mixture with the analyte that each analyzer is designed to measure. All of analyzers exhibited a composite deviation of less than 3.0% of the span for all measured interferent gases. No major analytical components of the analyzers have been replaced since performing the original interference tests.

5.4 Instrument Calibration and System Bias Checks

At the beginning of each day of the testing program, initial three-point instrument calibrations were performed for the NO_x, CO, CO₂ and O₂ analyzers by injecting calibration gas directly into the inlet sample port for each instrument. System bias checks were performed prior to and at the conclusion of each sampling period by introducing the upscale calibration gas and zero gas into the sampling system (at the base of the stainless steel sampling probe prior to the particulate

filter and Teflon® heated sample line) and determining the instrument response against the initial instrument calibration readings.

At the beginning of each test day, appropriate high-range, mid-range, and low-range span gases followed by a zero gas were introduced to the NMHC analyzer, in series at a tee connection, which is installed between the sample probe and the particulate filter, through a poppet check valve. After each one hour test period, mid-range and zero gases were re-introduced in series at the tee connection in the sampling system to check against the method's performance specifications for calibration drift and zero drift error.

The instruments were calibrated with USEPA Protocol 1 certified concentrations of CO₂, O₂, NO_x, and CO in nitrogen and zeroed using hydrocarbon free nitrogen. The NMHC (VOC) instrument was calibrated with USEPA Protocol 1 certified concentrations of propane in air and zeroed using hydrocarbon-free air. A STEC Model SGD-710C ten-step gas divider was used to obtain intermediate calibration gas concentrations as needed.

5.5 Determination of Exhaust Gas Stratification

A stratification test was performed for the RICE exhaust stack. The stainless steel sample probe was positioned at sample points correlating to 16.7, 50.0 (centroid) and 83.3% of the stack diameter. Pollutant concentration data were recorded at each sample point for a minimum of twice the maximum system response time.

The recorded concentration data for the RICE exhaust stack indicated that the measured NO_x concentrations did not vary by more than 5% of the mean across the stack diameter. Therefore, the RICE exhaust gas was considered to be unstratified and the compliance test sampling was performed at a single sampling location within the RICE exhaust stack.

5.6 Meter Box Calibrations

The metering console, which was used for exhaust gas moisture content sampling, was calibrated prior to and after the testing program. This calibration uses the critical orifice calibration technique presented in USEPA Method 5. The metering console calibration exhibited no data outside the acceptable ranges presented in USEPA Method 5.

The digital pyrometer in the metering console was calibrated using a NIST traceable Omega® Model CL 23A temperature calibrator.

Appendix 6 presents test equipment quality assurance data (NO₂ – NO conversion efficiency test data, instrument calibration and system bias check records, calibration gas and gas divider certifications, interference test results, meter box calibration records, Pitot tube calibration records).

6.0 RESULTS

6.1 Test Results and Allowable Emission Limits

Engine operating data and air pollutant emission measurement results for each one hour test period are presented in Tables 6.1 and 6.2.

The measured air pollutant concentrations and emission rates for Engine Nos. 1 and 2 are less than the allowable limits specified in MI-ROP-N5917-2011a for Emission Unit Nos. EUICEENGINE1-S2 and EUICEENGINE2-S2:

- 1.0 g/bhp-hr and 4.94 lb/hr for NO_x;
- 3.5 g/bhp-hr and 17.3 lb/hr for CO; and
- 1.0 g/bhp-hr for VOC.

6.2 Variations from Normal Sampling Procedures or Operating Conditions

The testing for all pollutants was performed in accordance with USEPA methods and the approved test protocol.

Derenzo Environmental ServicesGranger Electric of Watervliet
Air Emission Test ReportMarch 16, 2016
Page 12Table 6.1 Measured exhaust gas conditions and NO_x, CO and VOC air pollutant emission rates for Engine No. 1 (EUICEEENGINE1-S2)

Test No.	1	2	3	
Test date	2/17/16	2/17/16	2/17/16	Three Test
Test period (24-hr clock)	1302-1402	1425-1525	1550-1650	Average
Fuel flowrate (scfm)	586	594	600	594
Generator output (kW)	1,595	1,595	1,594	1,595
Engine output (bhp)	2,226	2,226	2,225	2,226
LFG methane content (%)	48.6	48.5	47.7	48.2
<u>Exhaust Gas Composition</u>				
CO ₂ content (% vol)	11.0	10.5	10.5	10.7
O ₂ content (% vol)	8.26	8.65	8.68	8.53
Moisture (% vol)	10.7	10.6	10.5	10.6
Exhaust gas temperature (°F)	797	799	801	799
Exhaust gas flowrate (dscfm)	4,237	4,195	4,160	4,197
Exhaust gas flowrate (scfm)	4,744	4,691	4,648	4,694
<u>Nitrogen Oxides</u>				
NO _x conc. (ppmvd)	63.4	61.0	61.9	62.1
NO _x emissions (lb/hr)	1.92	1.84	1.85	1.87
Permitted emissions (lb/hr)	-	-	-	4.94
NO _x emissions (g/bhp*hr)	0.39	0.37	0.38	0.38
Permitted emissions (g/bhp*hr)	-	-	-	1.0
<u>Carbon Monoxide</u>				
CO conc. (ppmvd)	717	711	710	713
CO emissions (lb/hr)	13.3	13.0	12.9	13.1
Permitted emissions (lb/hr)	-	-	-	17.3
CO emissions (g/bhp*hr)	2.70	2.65	2.63	2.66
Permitted emissions (g/bhp*hr)	-	-	-	3.5
<u>Volatile Organic Compounds</u>				
VOC conc. (ppmv)	19.9	21.3	18.9	2.0
VOC emissions (lb/hr)	0.65	0.69	0.60	0.65
VOC emissions (g/bhp*hr)	0.13	0.14	0.12	0.13
Permitted emissions (g/bhp*hr)	-	-	-	1.0

Derenzo Environmental ServicesGranger Electric of Watervliet
Air Emission Test ReportMarch 16, 2016
Page 13Table 6.2 Measured exhaust gas conditions and NO_x, CO and VOC air pollutant emission rates for Engine No. 2 (EUICEEENGINE2-S2)

Test No.	1	2	3	
Test date	2/17/16	2/17/16	2/17/16	Three Test
Test period (24-hr clock)	0815-0915	0937-1037	1108-1208	Average
Fuel flowrate (scfm)	607	612	606	608
Generator output (kW)	1,585	1,584	1,592	1,587
Engine output (bhp)	2,211	2,211	2,222	2,215
LFG methane content (%)	48.5	48.2	48.4	48.4
<u>Exhaust Gas Composition</u>				
CO ₂ content (% vol)	10.5	10.2	10.2	10.3
O ₂ content (% vol)	8.97	8.97	9.01	8.98
Moisture (% vol)	11.4	11.3	10.0	10.9
Exhaust gas temperature (°F)	801	800	798	799
Exhaust gas flowrate (dscfm)	4,284	4,351	4,440	4,358
Exhaust gas flowrate (scfm)	4,831	4,868	4,933	4,877
<u>Nitrogen Oxides</u>				
NO _x conc. (ppmvd)	55.4	54.3	55.1	55.0
NO _x emissions (lb/hr)	1.70	1.69	1.75	1.72
Permitted emissions (lb/hr)	-	-	-	4.94
NO _x emissions (g/bhp*hr)	0.35	0.35	0.36	0.35
Permitted emissions (g/bhp*hr)	-	-	-	1.0
<u>Carbon Monoxide</u>				
CO conc. (ppmvd)	700	701	703	701
CO emissions (lb/hr)	13.1	13.3	13.6	13.3
Permitted emissions (lb/hr)	-	-	-	17.3
CO emissions (g/bhp*hr)	2.68	2.73	2.78	2.73
Permitted emissions (g/bhp*hr)	-	-	-	3.5
<u>Volatile Organic Compounds</u>				
VOC conc. (ppmv)	18.7	19.0	19.2	19.0
VOC emissions (lb/hr)	0.62	0.63	0.65	0.64
VOC emissions (g/bhp*hr)	0.13	0.13	0.13	0.13
Permitted emissions (g/bhp*hr)	-	-	-	1.0