

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report

Facility : DTE Gas Company - Alpena Compressor Station	SRN : N5935
Location : 8512 E. ARNOLD LAKE ROAD	District : Bay City
	County : CLARE
City : HARRISON State: MI Zip Code : 48625	Compliance Status : Compliance
Source Class : MAJOR	Staff : Nathanael Gentle
FCE Begin Date : 9/29/2019	FCE Completion Date : 9/29/2020
Comments : 2020 FCE	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
09/29/2020	ROP Semi 1 Cert	Compliance	No deviations reported.
09/17/2020	Scheduled Inspection	Compliance	Inspection of MI-ROP-N5935-2019. Facility was in compliance.
04/17/2020	MAERS	Compliance	No issues identified. The source only operates for readiness/emergency testing, so the negligible emissions reported make sense. Audit passed.
03/11/2020	ROP Annual Cert	Compliance	No deviations reported.
03/11/2020	ROP SEMI 2 CERT	Compliance	No deviations reported.
03/11/2020	MACT (Part 63)	Compliance	Subpart ZZZZ Semiannual Compliance Report. No deviations reported.
11/06/2019	Stack Test	Compliance	CO Emissions Compliance Test Report (Subpart ZZZZ). The CO reduction results were 16.8 ppm CO @ 15% O2. The limit pursuant to Subpart ZZZZ is 47 ppmvd @ 15% O2.

Nathanael Gentle

Name: _____

Date: 9/29/2020

Supervisor: _____

Chris Hare