

**Relative Accuracy Test Audit Report** 

Consumers Energy Covert Generating Station Unit 001 Covert, Michigan September 13, 2023

Report Submittal Date November 3, 2023

> © Copyright 2023 All rights reserved in Mostardi Platt

# Project No. M233711A

Corporate Headquarters 888 Industrial Drive Elmhurst, Illinois 60126 630-993-2100

Crown Point, IN | Mendota Heights, MN | Denver, CO | Henderson, NV

# TABLE OF CONTENTS

1.0 EXECUTIVE SUMMARY	1
2.0 TEST METHODOLOGY Method 3A Oxygen (O <sub>2</sub> ) Determination Method 7E Nitrogen Oxides (NO <sub>x</sub> ) Determination Method 10 Carbon Monoxide (CO) Determination	3 3 3 4
3.0 TEST RESULT SUMMARIES	5
4.0 CERTIFICATION	9
APPENDICES	11
Appendix B - QI Certification(s) for Field Personnel.	
Appendix C - Test Section Diagram Appendix D - Sample Train Diagram	
Appendix E - Calculation Nomenclature and Formulas	20
Appendix F - Reference Method Test Data Appendix G - Continuous Emissions Monitoring System Data and Plant Operating Data	
Appendix H - Calibration and Response Time Data	
Appendix I - Calibration Gas Cylinder Data Appendix J - NO2 to NO Converter Test	

# 1.0 EXECUTIVE SUMMARY

Mostardi Platt conducted a Continuous Emissions Monitoring System (CEMS) Relative Accuracy Test Audit (RATA) test program for Consumers Energy at the Covert Generating Station in Covert, Michigan, on Unit 001 on September 13, 2023. This report summarizes the results of the test program and test methods used in accordance with the Mostardi Platt Protocol P233711 submitted to MDEQ on July 21, 2023. Mostardi Platt is a self-certified air emissions testing body (AETB). A copy of Mostardi Platt's self-certification can be found in Appendix A.

The test location, test date, and test parameters are summarized below.

	TEST INFORMATION	
Test Location	Test Date	Test Parameters
Unit 001 Stack	September 13, 2023	Carbon Monoxide (CO), Oxygen (O <sub>2</sub> ), and Nitrogen Oxides (NO <sub>x</sub> )

The purpose of the test program was to demonstrate the relative accuracies of the Unit 001 CO,  $O_2$ , and  $NO_X$  analyzers during the specified operating condition. The test results from this test program indicate that each CEMS component meets the United States Environmental Protection Agency (USEPA) annual performance specification for relative accuracy as published in 40 Code of Federal Regulations Part 75 (40CFR75) and 40 Code of Federal Regulations Part 60 (40CFR 60).

				RATA RESULTS		
Test Location	Date	Parameter	Units	Relative Accuracy Acceptance Criteria	Relative Accuracy (RA)	Bias Adjustment Factor (BAF)
	0/12/22	со	ppmvd	≤ 10 % of the mean reference method value	0.00%	N/A
Unit 001		0/12/22	NOx	lb/mmBtu	≤ 7.5 % of the mean reference method value	0.00%
Stack	9/13/23	NOx	ppmvd @ 15 % O2	≤ 20 % of the mean reference value	6.06%	N/A
		O2	% dry	≤ 7.5 % of the mean reference value	0.46%	N/A

	GAS CYLINDER INFORMATION									
Parameter	Gas Vendor	Cylinder Serial Number	Cylinder Value	Expiration Date						
NOx	Airgas	CC101641	0.00 ppm	12/20/2030						
NOx	Airgas	EB0058865	12.66 ppm	4/22/2025						
NOx	Airgas	CC403273	25.21 ppm	8/15/2026						
O2	Airgas	EB0058865	0.00 %	4/22/2025						
O2	Airgas	SG9125104BAL	9.976%	8/9/2031						
O2	Airgas	CC432067	19.01%	12/20/2030						
CO	Airgas	EB0058865	0.00 ppm	4/22/2025						
CO	Airgas	CC101641	10.31 ppm	12/20/2030						
СО	Airgas	XC017604B	19.82 ppm	1/24/2030						

The gas cylinders used to perform the RATA are summarized below.

No deviations, additions, or exclusions from the test protocol, test methods, the Mostardi Platt Quality Manual, or the ASTM D7036-12 occurred. The specific test conditions encountered did not interfere with the collection of the data.

The identification of the individuals associated with the test program are summarized below.

TEST PERSONNEL INFORMATION								
Location	Address	Contact						
Test Facility	Consumers Energy Covert Generating Station 26000 77 <sup>th</sup> Street Covert, Michigan 49043	Chris Head Operations Manager (269) 764-3805 (phone) chris.head@cmsenergy.com						
Testing Company Supervisor	Mostardi Platt 888 Industrial Drive Elmhurst, Illinois 60126	Damian Panek 630-993-2100 (phone) dpanek@mp-mail.com QI Group V (certified on 1/19/2021)						
Testing Company Personnel		Ryan Gartner Test Engineer						

A copy of the QI certification for test personnel is included in Appendix B.

# 2.0 TEST METHODOLOGY

Emission testing was conducted following the United States Environmental Protection Agency (USEPA) methods specified in 40CFR75 and 40CFR60, Appendix A, in addition to the Mostardi Platt Quality Manual and the Mostardi Platt test protocol. Schematics of the test section diagram and sampling train used are included in Appendix C and D respectively. Calculation and nomenclature are included in Appendix E. Copies of analyzer print-outs for each test run are included in Appendix F. CEM data and process data as provided by Consumer's Energy are included in Appendix G.

The following methodologies were used during the test program:

### Method 3A Oxygen (O<sub>2</sub>) Determination

Stack gas O<sub>2</sub> concentrations were determined in accordance with USEPA Method 3A, 40CFR60, Appendix A. A Servomex analyzer was used to determine the O<sub>2</sub> concentrations in the manner specified in the Method. The instrument has a paramagnetic detector and the O<sub>2</sub> operates in the nominal range of 0% to 25% with the specific range determined by the high-level calibration gas. High-range calibrations were performed using USEPA Protocol gas. Zero nitrogen (a low ppm pollutant in balance nitrogen calibration gases) was introduced during other instrument calibrations to check instrument zero. High- and a mid-range % O2 levels in balance nitrogen were also introduced. Zero and mid-range calibrations were performed using USEPA Protocol gas after each test run. Copies of the gas cylinder certifications are found in Appendix J. This testing met the performance specifications as outlined in the Method.

### Method 7E Nitrogen Oxides (NO<sub>x</sub>) Determination

Stack gas NOx concentrations and emission rates were determined in accordance with USEPA Method 7E, 40CFR60, Appendix A. A Thermo Scientific Model 42i-HL Chemiluminescence Nitrogen Oxides Analyzer was used to determine NOx concentrations, in the manner specified in the Method. The instrument operated in the nominal range of 0 ppm to 100 ppm with the specific range determined by the high-level span calibration gas of 25.21 ppm.

The Model 42i-HL is based on the principle that nitric oxide (NO) and ozone ( $O_3$ ) react to produce a characteristic luminescence with an intensity linearly proportional to the NO concentration. Infrared light emission results when electronically excited nitrogen dioxide (NO<sub>2</sub>) molecules decay to lower energy states. Specifically,

#### NO+O<sub>3</sub>→NO<sub>2</sub>+O<sub>2</sub>+hu

NO<sub>2</sub> must first be transformed into NO before it can be measured using the chemiluminescent reaction. NO<sub>2</sub> is converted to NO by a molybdenum NO<sub>2</sub>-to-NO converter heated to about 620°C. The flue gas air sample is drawn into the Model 42i-HL through the sample bulkhead. The sample flows through a particulate filter, a capillary, and then to the mode solenoid valve. The solenoid valve routes the sample either straight to the reaction chamber (NO mode) or through the NO<sub>2</sub>to-NO converter and then to the reaction chamber (NOx mode).

Dry air enters the Model 42i-HL through the dry air bulkhead, through a flow sensor, and then through a silent discharge ozonator. The ozonator generates the necessary ozone concentration needed for the chemiluminescent reaction. The ozone reacts with the NO in the ambient air sample to produce electronically excited NO<sub>2</sub> molecules. A photomultiplier tube (PMT) housed in a thermoelectric cooler detects the NO<sub>2</sub> luminescence.

AIR QUART Prett DIVISION

The NO and NO<sub>x</sub> concentrations calculated in the NO and NO<sub>x</sub> modes are stored in memory. The difference between the concentrations is used to calculate the NO<sub>2</sub> concentration. The Model 42i outputs NO, NO<sub>2</sub>, and NO<sub>x</sub> concentrations to both the front panel display and the analog outputs.

Stack gas was delivered to the analyzer via a Teflon® sampling line, heated to a minimum temperature of 250°F. Excess moisture in the stack gas was removed using a refrigerated condenser. The entire system was calibrated in accordance with the Method, using USEPA Protocol gases introduced at the probe, before and after each test run. This testing met the performance specifications as outlined in the Method.

A list of calibration gases used and the results of all calibration and other required quality assurance checks are found in Appendix H. Copies of the gas cylinder certifications are found in Appendix I. The NO<sub>2</sub> to NO converter test can be found in Appendix J. This testing met the performance specifications as outlined in the Method.

### Method 10 Carbon Monoxide (CO) Determination

Stack gas CO concentrations and emission rates were determined in accordance with USEPA Method 10, 40CFR60, Appendix A. A Thermo Scientific Model 48i Gas Filter Correlation Carbon Monoxide was used to determine carbon monoxide concentrations, in the manner specified in the Method. The instrument operated in the nominal range of 0 ppm to 100 ppm with the specific range determined by the high-level span calibration gas of 19.82 ppm.

The Model 48i operates on the principle that CO absorbs infrared radiation at a wavelength of 4.6 microns. Because infrared absorption is a non-linear measurement technique, it is necessary to transform the basic analyzer signal into a linear output. The Model 48i uses an internally stored calibration curve to accurately linearize the instrument output over any range up to a concentration of 10,000 ppm. The sample is drawn into the Model 48i through the sample bulkhead. The sample flows through the optical bench. Radiation from an infrared source is chopped and then passed through a gas filter alternating between CO and N<sub>2</sub>. The radiation then passes through a narrow bandpass interference filter and enters the optical bench where absorption by the sample gas occurs. The infrared radiation then exits the optical bench and falls on an infrared detector. The CO gas filter acts to produce a reference beam which cannot be further attenuated by CO in the sample cell. The N<sub>2</sub> side of the filter wheel is transparent to the infrared radiation and therefore produces a measurement beam which can be absorbed by CO in the cell. The chopped detector signal is modulated by the alternation between the two gas filters with an amplitude related to the concentration of CO in the sample cell. Other gases do not cause modulation of the detector signal since they absorb the reference and measure beams equally. Thus, the GFC system responds specifically to CO. The Model 48i outputs the CO concentration to the front panel display, the analog outputs, and also makes the data available over the serial or Ethernet connection.

Stack gas was delivered to the analyzer via a Teflon® sampling line, heated to a minimum temperature of 250°F. Excess moisture in the stack gas was removed using a refrigerated condenser. The entire system was calibrated in accordance with the Method, using USEPA protocol gases introduced at the probe, before and after each test run. A list of calibration gases used and the results of all calibration and other required quality assurance checks are found in Appendix H. Copies of the gas cylinder certifications are found in Appendix I. This testing met the performance specifications as outlined in the Method.

# **3.0 TEST RESULT SUMMARIES**

Client: Consumers Energy Facility: Covert Generating Station Project #: M233711

#### Location: Unit 001 Date: 9/13/23

Test Method: 10

				CEM	O ppmvd I Analyzer Int	RATA formation									
CO Monitor/Model: Teledyne T300M							CO Serial # :	413							
1=accept 0=reject	Test Run	Mw	Test Run Mw	Test Run <sup>Mw</sup>	st In Mw	Run Mw	est Run Mw	Mw	Test Date	Start Time	End Time	RM CO ppmvd	CEM CO ppmvd	(RM-CEM) Difference (di)	(RM-CEM) Difference <sup>2</sup> (di <sup>2</sup> )
1	1	243	09/13/23	08:45	09:05	0.0	0.0	0.0	0.00						
1	2	241	09/13/23	09:25	09:45	0.0	0.0	0.0	0.00						
1	3	241	09/13/23	10:01	10:21	0.0	0.0	0.0	0.00						
1	4	240	09/13/23	10:47	11:07	0.0	0.0	0.0	0.00						
1	5	238	09/13/23	11:22	11:42	0.0	0.0	0.0	0.00						
1	6	238	09/13/23	11:59	12:19	0.0	0.0	0.0	0.00						
1	7	237	09/13/23	12:42	13:02	0.0	0.0	0.0	0.00						
1	8	235	09/13/23	13:19	13:39	0.0	0.0	0.0	.0 0.00						
1	9	234	09/13/23	13:55 14:15	14:15 0.0	0.0	0.0	0.0	0.0	0.0	0.0	5 0.0	0.0	0.0	0.00
0	10	234	09/13/23	14:38	14:58	0.0	0.0	0.0	0.00						
					n		9								
					t(0.975)	2.3	306								
	_		Mean Re	ference Me	thod Value	0.	000	RM avg							
				Mean	CEM Value	0.	000	CEM avg							
				Sum of	Differences	0.	000	di							
Mean Difference						0.	000	d							
	Sum of Differences Squared					0.	000	di <sup>2</sup>							
				Standar	d Deviation	0.	000	sd							
	(	Confid	ence Coeff	icient 2.5%	Error (1-tail)	0.	0.000								
				Relativ	e Accuracy	0	.00	RA							

Client: Consumers Energy Facility: Covert Generating Station Project #: M233711 Fuel Type: Natural Gas

				O2 base CEM	d NOx Ib/n Analyzer In	nmBtu RAT	A		
	NC	x Mon	itor/Model:	Teledyne T200M			NO <sub>x</sub> Serial # :	7	781
	0	2 Mon	itor/Model:	Teledyn	e T300M		O2 Serial # :	4	113
1=accept 0=reject	Test Run	Mw	Test Date	Start Time	End Time	RM NO <sub>x</sub> Ib/MMBtu	CEM NO <sub>x</sub> Ib/MMBtu	(RM-CEM) Difference (di)	(RM-CEM) Difference <sup>2</sup> (di <sup>2</sup> )
1	1	243	09/13/23	08:45	09:05	0.007	0.007	0.000	0.000000
1	2	241	09/13/23	09:25	09:45	0.007	0.007	0.000	0.000000
1	3	241	09/13/23	10:01	10:21	0.007	0.007	0.000	0.000000
1	4	240	09/13/23	10:47	11:07	0.007	0.007	0.000	0.000000
1	5	238	09/13/23	11:22	11:42	0.007	0.007	0.000	0.000000
1	6	238	09/13/23	11:59	12:19	0.007	0.007	0.000	0.000000
1	7	237	09/13/23	12:42	13:02	0.007	0.007	0.000	0.000000
1	8	235	09/13/23	13:19	13:39	0.007	0.007	0.000	
1	9	234	09/13/23	13:55	14:15	0.007	0.007	0.000	0.000000
0	10	234	09/13/23	14:38	14:58	0.007	0.007	0.000	0.000000
					n t(0.025)	9 2.306			
			Mean Re	eference Me	thod Value	0.	007	RM avg	
				Mean	CEM Value	0.007		CEM avg	
				Sum of	Differences	0.000		di	
	Mean Difference						000	d	
Sum of Differences Squared						0.	000	di <sup>2</sup>	
Standard Deviation						0.	000	sd	
		Confid	ence Coeff	icient 2.5%	Error (1-tail)	0.000		cc	
				Relativ	e Accuracy	0.	.00	RA	
				Bias Adjustr	1.000 BAF				

Client: Facility:	Consur Covert	ners Er Genera	nergy ting Station	1		Location: Date:	Unit 001 9/13/23			
Project #:	M2337	11				Test Method:	7E, 3A			
				NOx pp	mvd @ 15	5% O2 RATA	4			
				CEM	Analyzer In	nformation				
	NC	D <sub>x</sub> Moni	tor/Model:	Teledyne	e T200M		NO <sub>x</sub> Serial # :	7	81	
	C	D <sub>2</sub> Mon	tor/Model:	Teledyne	e T300M		O2 Serial # :	4	13	
1=accept 0=reject	Test Run	Mw	Test Date	Start Time	End Time	RM NOx ppmvd @ 15 %O2	RM NOx CEM NOx (RM-CEM) ppmvd @ 15 ppmvd @ 15 Difference %Q2 %Q2 (di)			
1	1	243	09/13/23	08:45	09:05	1.8	1.8	0.0	0.00	
1	2	241	09/13/23	09:25	09:45	1.9	1.8	0.1	0.01	
1	3	241	09/13/23	10:01	10:21	1.9	1.8	0.1	0.01	
0	4	240	09/13/23	10:47	11:07	2.0	1.8	0.2	0.04	
1	5	238	09/13/23	11:22	11:42	1.9	1.8	0.1	0.01	
1	6	238	09/13/23	11:59	12:19	1.9	1.8	0.1	0.01	
1	7	237	09/13/23	12:42	13:02	1.9	1.8	0.1	0.01	
1	8	235	09/13/23	13:19	13:39	1.9	1.8	0.1	0.01	
1	9	234	09/13/23	13:55	14:15	1.9	1.8	0.1	0.01	
1	10	234	09/13/23	14:38	14:58	1.9	1.8	0.1	0.01	
					n		9			
		_			t(0.975)	2.3	306			
		_	Mean Re	ference Me	thod Value	1.8	889	RM avg		
				Mean	1.8	800	CEM avg			
Sum of Differences						0.8	800	di		
	Mean Difference						089	d		
	Sum of Differences Squared						080	di <sup>2</sup>		
				Standar	d Deviation	0.0	0.033		sd	
		Confide	ence Coeff	icient 2.5% E	Error (1-tail)	0.0	0.026		CC	
				Relativ	6.	06	RA			

I

Ī

©Mostardi Platt

Client:	Consur	ners Er	nerav			Location:	Unit 001			
Facility:	Covert	Genera	ting Station	1	Date: 9/13/23					
Project #:	M2337	11	ing olution		Test Method:	34				
					0 0/ (dm/)	DATA	or c			
				0.51	0 <sub>2</sub> % (ary)	RAIA				
	-			CEN	Analyzer In	formation				
	0	2 Monit	or/Model:	Teledyne	e T300M		O <sub>2</sub> Serial # :	4	13	
1=accept 0=reject	Test Run	Mw	Test Date	Start Time	End Time	RM O <sub>2</sub> % (dry)	CEM O <sub>2</sub> % (dry)	(RM-CEM) Difference (di)	(RM-CEM) Difference <sup>2</sup> (di <sup>2</sup> )	
0	1	243	09/13/23	08:45	09:05	12.2	12.5	-0.3	0.09	
1	2	241	09/13/23	09:25	09:45	12.4	12.5	-0.1	0.01	
1	3	241	09/13/23	10:01	10:21	12.6	12.5	0.1	0.01	
1	4	240	09/13/23	10:47	11:07	12.6	12.5	0.1	0.01	
1	5	238	09/13/23	11:22	11:42	12.5	12.5	0.0	0.00	
1	6	238	09/13/23	11:59	12:19	12.5	12.5	0.0	0.00	
1	7	237	09/13/23	12:42	13:02	12.5	12.5	0.0	0.00	
1	8	235	09/13/23	13:19	13:39	12.5	12.5	0.0	0.00	
1	9	234	09/13/23	13:55	14:15	12.5	12.5	0.0	0.00	
1	10	234	09/13/23	14:38	14:58	12.5	12.5	0.0	0.00	
					n	3	9			
					t(0.025)	2.3	306			
			Mean Re	ference Me	thod Value	12.	.511	RM avg		
				Mean	12.	.500	CEM avg			
Sum of Differences						0.	100	di		
Mean Difference						0.	011	d		
			Sum	of Difference	es Squared	0.030		di <sup>2</sup>		
				Standar	d Deviation	0.	060	sd		
	C	onfide	nce Coeff	icient 2.5% E	Error (1-tail)	0.	046	cc		
				Relativ	0.	.46	RA			

# **4.0 CERTIFICATION**

Mostardi Platt is pleased to have been of service to Consumers Energy. If you have any questions regarding this test report, please do not hesitate to contact us at 630-993-2100.

As the program manager, I hereby certify that this test report represents a true and accurate summary of emissions test results and the methodologies employed to obtain those results. The test program was performed in accordance with the test protocol, test methods, the Mostardi Platt Quality Manual, and the ASTM D7036-12, as applicable.

MOSTARDI PLATT

and NG

Program Manager

Damian P. Panek

Benjamin W. Hendricks

Fel W

Quality Assurance

### APPENDICES

### Appendix A - Company AETB Certification

Ī



March 23, 2012

Effective immediately, Mostardi Platt self-certifies that all Part 75 test projects conform to the ASTM D 7036-04 Standard Practice. The following contact information is provided as required by the Standard:

Mostardi Platt 888 Industrial Drive Elmhurst, Illinois 60126

630-993-2100

tplatt@mp-mail.com

Also, attached is a list of each Qualified Individual (QI) with the type of exam (e.g., Group I, II, III IV and/or V), the date the exam was taken and the name and email address of the exam provider.

Should you have any questions or need additional information, please contact Thomas Platt, P.E. at 630-993-2683.

Approved:

By:

Rober J. Platt Chief Executive Officer

> 888 Industrial Drive Elmhurst, Illinois 60126 630-993-2100

Project No. M233711A Unit 001 ©Mostardi Platt

#### QSTI AETB Import Data

QI Last Name [REQUIRED]	QI First Name [REQUIRED]	QI Middle Initial	AETB Name [REQUIRED]	AETB Phone Number [REQUIRED]	AETB Email [REQUIRED]	Exam Date mm/dd/yyyy [REQUIRED]	Exam Provider Name [REQUIRED]	Exam Provider Email [REQUIRED]	Comment
leckham	Kenneth	1	Mostard Platt	630-993-2100	tplatt@mp-mail.com	5/18/2023	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
enninghoff	Aaron	W	Mostard Platt	630-993-2100	tplatt@mp-mail.com	9/8/2023	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
lurton	Stuart	L	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/4/2023	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
Carlisle	Robert	W	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/8/2021	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
colangelo	Nicholas	C	Mostard Platt	630-993-2100	tplatt@mp-mail.com	2/1/2019	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
oleman	Paul	F	Mostard Platt	630-993-2100	tplatt@mp-mail.com	3/22/2023	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
rivlare	Jeffrey	м	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/4/2023	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
ldridge	Christopher	5	Mostard Platt	630-993-2100	tplatt@mp-mail.com	2/18/2021	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
iross	Jeffrey	M	Mostard Platt	630-993-2100	tplatt@mp-mail.com	11/20/2018	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
lendricks	Benjamin	W	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/30/2020	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
lowe	Jacob	W	Mostard Platt	630-993-2100	tplatt@mp-mail.com	2/17/2021	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)
ensen	Christopher	E	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/4/2023	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
ones	Kyle	L	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/11/2021	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
aschinske	Jordan	R	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/8/2021	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
ossack	Daniel	1	Mostard Platt	630-993-2100	tplatt@mp-mail.com	11/11/2021	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
ukla	Joshua	R	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/4/2019	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
ipinski	Michal		Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/31/2020	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
anek	Damian	P	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/19/2021	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
eterson	Mark	E	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/17/2023	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
etrovich	William	A	Mostard Platt	630-993-2100	tplatt@mp-mail.com	2/4/2022	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
luss	Timothy	E	Mostard Platt	630-993-2100	tplatt@mp-mail.com	4/8/2020	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
ands	Stuart	T	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/5/2023	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
ather	Michael	Ρ	Mostard Platt	630-993-2100	tplatt@mp-mail.com	2/7/2020	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
imon	Ryan	к	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/19/2023	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
ollars	Richard	1	Mostard Platt	630-993-2100	tplatt@mp-mail.com	7/28/2023	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
orce	Angelo	M	Mostard Platt	630-993-2100	tplatt@mp-mail.com	2/18/2022	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
rezak	Christopher	S	Mostard Platt	630-993-2100	tplatt@mp-mail.com	4/14/2020	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)

9/8/2023

### Appendix B - QI Certification(s) for Field Personnel





mostardi platt
Qualified Individual
Damian P. Panek
Has satisfactorily completed the requirements of
ASTM D 7036 – 04, Section 8.3
Standard Practice for Competence of Air Emission Testing Bodies
Examinations provided by Source Evaluation Society: www.sesnews.org, (919) 544-6338
All Part 75 test methods, under my supervision, shall conform to the company's Quality Manual and to this practice, in all respects.
Passed Group V on 1/19/2021
Expiration Date: 1/19/2026
Signature: Damia Panete Date: January 19, 2021
Quality Manager: Thomas B. Nott Technical Director:

# GASEOUS TRAVERSE FOR ROUND DUCTS





- Job: Consumers Energygy Covert Generating Station Covert, Michigan
- Date: September 13, 2023
- Test Location: Unit 001 Stack
- Stack Diameter: 22.083 Feet

Stack Area: 383.02 Square Feet

- Upstream Disturbance: 240 Inches (0.91 diameters)
- Downstream Disturbance: 1,020 Inches (3.85 diameters)
  - No. Sample Points: 3

Port Length: 12 Inches

#### Distance from Inside Wall To Traverse Point:

- 1. 2.0 Meters
- 2. 1.2 Meters
- 3. 0.4 Meters





# USEPA Methods 3A, 7E, and 10 Extractive Gaseous Sampling Diagram

©Mostardi Platt