

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : Michigan Public Power Agency	SRN : N7113
Location : 1750 Prough Road SW	District : Gaylord
	County : KALKASKA
City : KALKASKA State: MI Zip Code : 49646	Compliance Status :
Source Class : MAJOR	Staff : Gloria Torello
FCE Begin Date : 6/23/2013	FCE Completion Date : 6/23/2014
Comments : 2014 FCE	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
06/23/2014	Scheduled Inspection	Compliance	2014 FCE.
05/30/2014	MAERS	Compliance	2013 MAERS. Reported sourcewide NOx emissions were 9.8 tons. The ROP allows 34 tons NOx from the turbines.
03/24/2014	ROP Annual Cert	Compliance	MI-ROP-N7113-2011. 2013 Annual Cert. During the reporting period the permittee reported the source was in compliance with all ROP conditions. No objection.
03/24/2014	ROP SEMI 2 CERT	Compliance	MI-ROP-N7113-2011. July-December 2013 semiannual. During the reporting period the permittee reported all monitoring and associated recordkeeping requirements of the ROP were met and there were no deviations. No objection.
12/12/2013	ROP Semi 1 Cert	Compliance	2013 Jan-June. Zero deviations reported.

Name: Gloria Torello Date: 6-25-14

Supervisor: 