

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report

Facility : DTE Gas Company - Willow Run Compressor Station	SRN : N7421
Location : 3020 East Michigan Avenue	District : Jackson
	County : WASHTENAW
City : YPSILANTI State: MI Zip Code : 48198	Compliance Status : Compliance
Source Class : MAJOR	Staff : Mike Kovalchick
FCE Begin Date : 9/11/2019	FCE Completion Date : 9/11/2020
Comments : Facility is in compliance.	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
09/11/2020	ROP Other	Compliance	Initial notification of startup for EUBOILER5
09/11/2020	Stack Test	Compliance	Emissions test report for carbon monoxide destruction efficiency testing conducted on EUENGINE1 (unit 1100) and EURICE1-3 (Units 2100-2300) and NOx emissions testing on EUTURBINE1.
09/10/2020	Scheduled Inspection	Compliance	Scheduled Inspection. A methane survey of the facility yard was also conducted using a SEM5000 methane device.
03/18/2020	MACT (Part 63)	Compliance	Part 63 Subpart ZZZZ Semi-Annual Compliance. No deviations.
03/13/2020	MACT (Part 63)		Submitted test plan that 4 compressor engines to be tested for CO June 2 to 9, 2020
03/13/2020	MACT (Part 63)	Compliance	Notification that one 3 MMBTU/hr natural gas fired boiler installed but exempt from PTI requirements. It is subject to NESHAP Subpart DDDDD.
02/05/2020	Stack Test	Compliance	Emissions Test Report for Carbon Monoxide (CO) Destruction Efficiency, EURICE1-3. 98.2% destruction eff. which meets greater than 93% requirement.
11/25/2019	ROP Semi 1 Cert	Compliance	No deviations.
11/25/2019	MACT (Part 63)	Compliance	Subpart ZZZZ. No deviations.

Name:

McKen
/per Scott

Date:

9/10/20

Supervisor:

[Signature]