

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : LOWELL LIGHT & POWER (LL&P)	SRN : P0375
Location : 625 CHATHAM STREET	District : Grand Rapids
	County : KENT
City : LOWELL State: MI Zip Code : 49331	Compliance Status : Compliance
Source Class : SM OPT OUT	Staff : Steve Lachance
FCE Begin Date : 7/31/2013	FCE Completion Date : 7/31/2014
Comments : FCE for FY '014	


List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
07/31/2014	Scheduled Inspection	Compliance	Scheduled Inspection for FY '014
06/24/2014	Stack Test	Compliance	Compliance Emission Sampling Report for the SOLAR Turbine; reported results indicate compliance with NOx and CO limits (ppm and pph for each pollutant, corrected to 15% O2) from PTI. Subject to any further review by AQD-TPU. (SLachance, 6/24/14)
03/18/2014	MAERS	Compliance	No changes to database as submitted; see comments in electronic MAERS Audit Console. (SLachance, 3/18/14)
09/12/2013	Scheduled Inspection	Compliance	Inspection of 2 Turbine Installation (s) (SLachance, 9/12/13)

Name:



Date:



Supervisor:

