



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

LANSING

EGLE
LIESL EICHLER CLARK
DIRECTOR

October 9, 2020

UPS NEXT DAY DELIVERY

Mr. Brian Taylor
City of Jackson
161 West Michigan Avenue
Jackson, Michigan 49201

Mr. Scott Hiller
Asbestos and Lead Abatement of Michigan Inc.
2505 Precision Street
Jackson, Michigan 49202

SRN/ID: U382001700, Jackson County

Dear Mr. Taylor and Hiller:

VIOLATION NOTICE

On October 5, 2020, the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD) conducted an inspection at 1206 Deyo Street, Jackson, Jackson County, Michigan. The purpose of this inspection was to determine compliance with the requirements of Title 40 of the Code of Federal Regulations, Part 61, Subpart M (National Emission Standard for Asbestos), and Rule 942 of Part 55, Air Pollution Control of the Natural Resources and Environmental Protection Act, 1994 PA 451.

According to our investigation, The City of Jackson owns the subject facility and Asbestos and Lead Abatement of Michigan Inc., was the contractor who performed the abatement activities. The National Emission Standard for Asbestos (NESHAP) holds the *owner and operator* liable for all violations.

The EGLE staff conducted an inspection of the site and found RACM (Regulated Asbestos Containing Material) on a removed duct boot in the basement and as debris on the basement floor.

Process Description	Section Violated	Comments
RACM was observed loose as debris on the basement floor during a post planned renovation inspection.	40 CFR §61.145(c)(4)	Failure to contain in leak tight container.
	40 CFR §61.145(c)(6)(i)	Failure to wet RACM that has been stripped.

VIOLATION NOTICE

Mr. Brian Taylor and Mr. Scott Hiller

Page 2


October 9, 2020

Please initiate actions necessary to correct the cited violations and submit a written response to this violation notice by October 30, 2020, (which coincides with 21 calendar days from the date of this letter). The written response should include: the date(s) the violations occurred; an explanation of the causes and duration of the violations; whether the violations are ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violations, and the date(s) by which these actions will take place; and what steps are being taken to prevent a reoccurrence. The *signed* written response from the *owner and operator* to this violation notice, may be submitted by mail and directed to my attention at: EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760. You must also include a copy to Mr. Jason Wolf, Enforcement Unit at: EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760. The response may be scanned and emailed to DechyC@Michigan.gov and WolfJ2@Michigan.gov.

If you believe the above observations or statements are inaccurate or do not constitute a violation of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violations cited above and for your cooperation regarding your immediate response to the clean-up. If you have any questions regarding the violation notice or the actions necessary to bring this facility into compliance, please contact me at 517-749-2891; DechyC@Michigan.gov; or the post office box address provided in the paragraph above.

Sincerely,



Craig W. Dechy
Environmental Quality Analyst
Air Quality Division

cc: Ms. Mary Ann Dolehanty, EGLE
Dr. Eduardo Olaguer, EGLE
Mr. Christopher Ethridge, EGLE
Ms. Karen Kajiya-Mills, EGLE
Mr. Scott Miller, EGLE
Mr. Jason Wolf, EGLE