



GRETCHEN WHITMER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF  
ENVIRONMENT, GREAT LAKES, AND ENERGY  
LANSING



LIESL EICHLER CLARK  
DIRECTOR

June 24, 2019

Mr. Luk Dedvukaj  
Metro General Contracting  
48155 West Road  
Wixom, Michigan 48393

SRN / ID: U471906196; Livingston County

Dear Mr. Dedvukaj:

**VIOLATION NOTICE**

On June 11, 2019, the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD), performed an asbestos NESHAP (National Emission Standard for Hazardous Air Pollutants) drive-by inspection at 2425 West Grand River Avenue, Howell, Livingston County. The purpose of this inspection was to determine compliance with the requirements of Title 40 of the Code of Federal Regulations, Part 61, Subpart M (National Emission Standard for Asbestos), and Rule 942 of Part 55, Air Pollution Control of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451).

According to my investigation, Metro General Contracting is the general contractor/owner's representative and the contractor who performed the demolition activities. The National Emission Standard for Asbestos may hold both the owner and operator equally liable for any violations.

During the inspection, staff observed the following:

Demolition of a residential facility had been performed and the property was being prepared for a new private commercial development. The contractor failed to perform a thorough asbestos inspection and had also failed to provide the Administrator with written notice of intent to demolish or renovate prior to the demolition activities.

Process Description	Section Violated	Comments
On 6/11/19, staff observed a demolition at 2425 West Grand River Avenue, Howell. No notice of intent to demolish or renovate had been submitted to the Administrator for the demolition.	40 CFR 61.145 (a)	Failure to thoroughly inspect.
	40 CFR 61.145 (b)(1)	Failure to provide the Administrator with written notice of intent to demolish or renovate.

Mr. Luk Dedvukaj  
Page 2  
June 24, 2019

Please initiate actions necessary to correct the cited violations and submit a written response to this violation notice by July 16, 2019, (which coincides with 21 calendar days from the date of this letter). The written response should include: the dates the violations occurred; an explanation of the causes and duration of the violations; whether the violations are ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violations, and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

Please submit the signed written response to Mr. Craig Dechy at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760 or scan and email as an attachment to me at [Dechyc@michigan.gov](mailto:Dechyc@michigan.gov) and submit a copy to Mr. Jason Wolf, Enforcement Unit at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760 or [Wolfj2@michigan.gov](mailto:Wolfj2@michigan.gov).

If you believe the above observations or statements are inaccurate or do not constitute a violation of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violations cited above and for the cooperation that was extended to me during our phone conversation. If you have any questions regarding the violation notification or the actions necessary to bring this facility into compliance, please feel free to contact me at 517-749-2891; [dechyc@michigan.gov](mailto:dechyc@michigan.gov); or EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760.

Sincerely,



Craig Dechy  
Environmental Quality Analyst  
Air Quality Division  
517-749-2891

cc: Ms. Mary Ann Dolehanty, EGLE  
Dr. Eduardo Olaguer, EGLE  
Mr. Christopher Ethridge, EGLE  
Mr. Brad Myott, EGLE  
Mr. Jason Wolf, EGLE  
Ms. Karen Kajiya-Mills, EGLE