



GRETCHEN WHITMER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF  
ENVIRONMENT, GREAT LAKES, AND ENERGY

LANSING

LIESL EICHLER CLARK  
DIRECTOR



March 20, 2020

UPS NEXT DAY DELIVERY

Mr. Byron Clouse  
Rogers Family Foods  
P.O. Box 188  
Glennie, Michigan 48737

SRN/ID: U572001150; Missaukee County

**VIOLATION NOTICE**

Dear Mr. Clouse:

On March 4, 2020, the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD) performed an asbestos NESHAP (National Emission Standard for Hazardous Air Pollutants) inspection at 5760 West Houghton Lake Road, Lake City, Missaukee County, Michigan. The purpose of this inspection was to determine compliance with the requirements of Title 40 of the Code of Federal Regulations (40 CFR), Part 61, Subpart M (National Emission Standard for Asbestos), and Rule 942 of Part 55, Air Pollution Control of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended.

According to my investigation, Rogers Family Foods owns the subject property and performed the renovation activities. The National Emission Standard for Asbestos holds both the *owner and operator* equally liable for any violations.

During the inspection, staff observed the following:

The subject commercial property had ongoing renovation work, including flooring, interior demolition, and plumbing work. In discussion with Mr. Clouse, he stated that he did not have an asbestos building survey completed prior to renovation. Mr. Clouse also stated he was unaware of the NESHAP program and its requirements and that only local permits were obtained from the Missaukee County Building Department.

## VIOLATION NOTICE

Mr. Clouse

Page 2

March 20, 2020

Process Description	Section Violated	Comments
On 3/4/20, staff performed an inspection at subject commercial building with renovation work being completed.	40 CFR 61.145 (a)	Failure to thoroughly inspect. No asbestos building survey.

Please initiate actions necessary to correct the cited violation and submit a written response to this violation notice by April 9, 2020, (which coincides with 21 calendar days from the date of this letter). The written response should include: the dates the violation occurred; an explanation of the causes and duration of the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation, and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

Please submit the signed written response to Mr. Steven Kidder at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760 or scan and email as an attachment to me at KidderS@Michigan.gov and submit a copy to Mr. Jason Wolf, Enforcement Unit at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760 or WolfJ2@Michigan.gov.

If you believe the above observations or statements are inaccurate or do not constitute a violation of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violation cited above and for the cooperation that was extended to me during our conversation about the site. If you have any questions regarding the violation notification or the actions necessary to bring this facility into compliance, please feel free to contact me at 517-243-4492; or KidderS@Michigan.gov; or EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760.

Sincerely,



Steven Kidder  
Environmental Quality Analyst  
Air Quality Division

cc: Ms. Mary Ann Dolehanty, EGLE  
Dr. Eduardo Olaguer, EGLE  
Mr. Christopher Ethridge, EGLE  
Mr. Shane Nixon, EGLE  
Ms. Karen Kajiya-Mills, EGLE  
Mr. Jason Wolf, EGLE