



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
DETROIT



C. HEIDI GREETHER
DIRECTOR

July 18, 2017

Mr. Aurther Carpenter
Carpenter Enterprise, Inc.
14242 Curtis Street
Detroit, MI 48235

SRN: U821702956, Wayne County

Dear Mr. Carpenter:

VIOLATION NOTICE

On July 17, 2017, the Department of Environmental Quality (DEQ), Air Quality Division (AQD), conducted an inspection of commercial/industrial property located at 15550-15630 Woodrow Wilson, Highland Park. The purpose of this inspection was to determine Carpenter Enterprise, Inc.'s compliance with the requirements of Title 40 of the Code of Federal Regulations, Part 61, Subpart M (National Emission Standard for Asbestos), and Rule 942 of Part 55, Air Pollution Control of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended.

According to our investigation, Carpenter Enterprise, Inc. owns the facility and is also the operator who notified to conduct renovation/demolition activities at the facility. The National Emission Standard for Asbestos holds both the owner and operator equally liable for violations.

During a previous site inspection, DEQ staff Tammy S. Bell and Joseph Goeddeke observed that regulated asbestos-containing materials were found mixed with demolition debris at the site. A notification for removal was provided to the DEQ, but the debris has not been removed as of July 17, 2017.

Process Description	Section Violated	Comments
Removal of demolition debris containing known/presumed regulated asbestos containing materials.	§61.145(b)(2)	Failure to update notice
	§61.150(b)(1)	Failure to deposit asbestos containing waste material as soon as practical

Please initiate actions necessary to correct the cited violations and submit a written response to this Violation Notice by August 8, 2017 (which coincides with 21 calendar days from the date of this letter). The written response should include: the dates the violations occurred; an explanation of the causes and duration of the violations; whether the violations are ongoing; a summary of the actions that have been taken and are


Mr. Aurther Carpenter
Page 2
July 18, 2017

proposed to be taken to correct the violations and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

If Carpenter Enterprise Inc. believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violations cited. If you have any questions regarding the violations or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Tammy S. Bell
Senior Environmental Quality Analyst
Air Quality Division
313-330-0105

Enclosure: Sample results

cc: Ms. Lynn Fiedler, DEQ
Ms. Mary Ann Dolehanty, DEQ
Mr. Christopher Ethridge DEQ
Mr. Thomas Hess, DEQ
Ms. Karen Kajiya-Mills, DEQ
Ms. Wilhemina McLemore, DEQ
Ms. Ann Vogen, DEQ