



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
DETROIT



C. HEIDI GREETHER
DIRECTOR

May 29, 2018

Mr. Steve Hamade
Hamco Enterprises, Inc.
32889 West Warren
Garden City, MI 48135

Mr. John Alsivo
J B A General Construction, LLC
1939 Devere Drive
Sterling Heights, MI 48127

SRN: U821802926, Wayne County

Dear Mr. Hamade and Mr. Alsivo:

VIOLATION NOTICE

On May 8, 2018, the Department of Environmental Quality (DEQ), Air Quality Division (AQD), conducted a complaint investigation of the commercial building located at 32932 Warren, Westland. The purpose of this inspection was to determine Hamco Enterprises, Inc.'s and J B A General Construction, LLC's compliance with the requirements of Title 40 of the Code of Federal Regulations, Part 61, National Emission Standards for Hazardous Air Pollutants, Subpart M, and Rule 942 of Part 55, Air Pollution Control of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended.

According to our investigation, Hamco Enterprises, Inc. owns the facility and J B A General Construction, LLC performed renovation activities at the facility. The National Emission Standard for Asbestos holds both the owner and operator liable for violations.

During the inspection, AQD staff Tammy Bell observed that building materials were removed from the exterior of the building prior to the required thorough inspection for asbestos. Disturbed cementitious asbestos containing materials were disturbed during renovation activities.

Process Description	Section Violated	Comments
Renovation of an asbestos NESHAP subject facility.	40 CFR 61.145(a)	Failure to thoroughly inspect for asbestos prior to renovation

Please initiate actions necessary to correct the cited violation and submit a written response to this Violation Notice by June 19, 2018 (which coincides with 21 calendar

Mr. Steve Hamade
Mr. John Alsivo
Page 2
May 29, 2018

days from the date of this letter). The written response should include: the dates the violation occurred; an explanation of the causes and duration of the violation, whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

If Hamco Enterprises, Inc. and J B A General Construction, LLC believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violation cited above and for the cooperation that was extended to me during my inspection of 32932 Warren, Westland. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Tammy Bell
Senior Environmental Quality Analyst
Air Quality Division
313-330-0105

Enclosure: Fact Sheet

cc: Ms. Mary Ann Dolehanty, DEQ
Mr. Craig Fitzner, DEQ
Mr. Christopher Ethridge, DEQ
Ms. Jenine Camilleri, DEQ
Ms. Karen Kajiya-Mills, DEQ
Ms. Wilhemina McLemore, DEQ