



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DETROIT DISTRICT OFFICE



LIESL EICHLER CLARK
DIRECTOR

June 10, 2019

Mr. Richard Meixner
Superior Wrecking, Inc.
260 Marlon Avenue
River Rouge, MI 48218

SRN: U821904691, Wayne County

Dear Mr. Meixner,

VIOLATION NOTICE

On May 1, 2019, the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD), conducted a referral inspection of the building located at 4468 W. Jefferson, Ecorse. The purpose of this inspection was to determine the owner's and contractor's compliance with the requirements of Title 40 of the Code of Federal Regulations (CFR), Part 61, National Emission Standards for Hazardous Air Pollutants (NESHAP), Subpart M and Rule 942 of the administrative rules promulgated under Part 55, Air Pollution Control of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended.

According to our investigation, Ms. Donna Pleso owns the building. Superior Wrecking, Inc. is the operator that demolished the building. The NESHAP for Asbestos holds both the owner and operator equally liable for violations.

During the inspection, it was noted that the building had been demolished without the submittal of a 10-day notice of intent to demolish to the Air Quality Division. An asbestos survey was requested but was not provided to the Air Quality Division.

Process Description	Section Violated	Comments
Demolition of the building located at 4468 W. Jefferson, Ecorse.	40 CFR 61.145(a)	Failure to thoroughly inspect for asbestos.
	40 CFR 61.145(b)(1)	Failure to provide 10 working day notification prior to demolition.

Please initiate actions necessary to correct the cited violation(s) and submit a signed written response to this Violation Notice by July 1, 2019 (which coincides with 21 calendar days from the date of this letter). The response should include: the dates the violation(s) occurred; an explanation of the causes and duration of the violation(s) whether the violation(s) are ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation(s) and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

Mr. Richard Meixner

Page 2


June 10, 2019

Please submit the written response to Ms. Tammy Bell at EGLE, AQD 3058 West Grand Boulevard, Suite 2-300, Detroit, Michigan 48202 or bellt4@michigan.gov and submit a copy to Mr. Jason Wolf, Enforcement Unit at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760 or wolfj2@michigan.gov.

If Superior Wrecking, Inc. believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide factual information to explain your position.

Thank you for your attention to resolving the violation(s) cited. If you have any questions regarding the violation(s) or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Tammy Bell
Senior Environmental Quality Analyst
Air Quality Division
313-330-0105

Enclosure: Fact Sheet

cc: Ms. Mary Ann Dolehanty, EGLE
Dr. Eduardo Olaguer, EGLE
Ms. Jenine Camilleri, EGLE
Mr. Christopher Ethridge, EGLE
Ms. Karen Kajiya-Mills, EGLE
Mr. Jason Wolf, EGLE
Ms. Wilhemina McLemore, EGLE