

NOTE: On July 11, 2006, EPA promulgated 40 CFR Part 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition (CI) Internal Combustion Engines (ICE). Sources should examine the applicability criteria in §60.4200 to determine if an engine using diesel fuel is regulated by this New Source Performance Standard (NSPS).

- **40 CFR 60.4200(a)(2)** Owners and operators of stationary CI ICE that commence construction (order the engine) after July 11, 2005 where the stationary CI ICE are:
 - (i) Manufactured after April 1, 2006 and are not fire pump engines, or
 - (ii) Manufactured as a certified National Fire Protection Association fire pump engine after July 1, 2006.
- **40 CFR 60.4200(a)(3)** Owners and operators of stationary CI ICE that modify or reconstruct the CI ICE after July 11, 2005.

The AQD is reviewing this NSPS to determine how it may affect the General Permit for Diesel Fuel-Fired Engine Generators. An amendment to the general permit is pending. Until then, the general permit will continue to be used in its current format. If a source is subject to 40 CFR Part 60, Subpart IIII, and feels the conditions in the general permit are not applicable, a regular Permit to Install application may be submitted.

A copy of the complete regulation is available electronically through www.regulations.gov or www.epa.gov/ttn/oarpg. For questions please contact Melissa Byrnes at 517-373-7065 or ByrnesM@michigan.gov.