## MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY AIR QUALITY DIVISION

October 22, 2021

PERMIT TO INSTALL 195-15B

#### ISSUED TO

Oakland County Water Resources Commissioner's Office

#### **LOCATED AT**

155 North Opdyke Road Pontiac, Michigan 48342

IN THE COUNTY OF Oakland

#### STATE REGISTRATION NUMBER B1950

The Air Quality Division has approved this Permit to Install, pursuant to the delegation of authority from the Michigan Department of Environment, Great Lakes, and Energy. This permit is hereby issued in accordance with and subject to Section 5505(1) of Article II, Chapter I, Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended. Pursuant to Air Pollution Control Rule 336.1201(1), this permit constitutes the permittee's authority to install the identified emission unit(s) in accordance with all administrative rules of the Department and the attached conditions. Operation of the emission unit(s) identified in this Permit to Install is allowed pursuant to Rule 336.1201(6).

DATE OF RECEIPT OF ALL INFORMATION REQUIRED BY RULE 203:  September 23, 2021		
DATE PERMIT TO INSTALL APPROVED:	SIGNATURE:	
October 22, 2021		
DATE PERMIT VOIDED:	SIGNATURE:	
DATE PERMIT REVOKED:	SIGNATURE:	

## **PERMIT TO INSTALL**

## **Table of Contents**

COMMON ACRONYMS	2
POLLUTANT / MEASUREMENT ABBREVIATIONS	
GENERAL CONDITIONS	4
EMISSION UNIT SPECIAL CONDITIONS	6
EMISSION UNIT SUMMARY TABLE	6
FLEXIBLE GROUP SPECIAL CONDITIONS	8
FLEXIBLE GROUP SUMMARY TABLE	8
FGENGINES	9
FGBOILER6	11
FGFACILITY CONDITIONS	
APPENDIX A	15

(B1950) October 22, 2021 Permit No. 195-15B Page 2 of 15

#### **COMMON ACRONYMS**

AQD Air Quality Division

BACT Best Available Control Technology

CAA Clean Air Act

CAM Compliance Assurance Monitoring
CEMS Continuous Emission Monitoring System

CFR Code of Federal Regulations

COMS Continuous Opacity Monitoring System

Department/department/EGLE Michigan Department of Environment, Great Lakes, and Energy

EU Emission Unit FG Flexible Group

GACS Gallons of Applied Coating Solids

GC General Condition
GHGs Greenhouse Gases

HVLP High Volume Low Pressure\*

ID Identification

IRSLInitial Risk Screening LevelITSLInitial Threshold Screening LevelLAERLowest Achievable Emission RateMACTMaximum Achievable Control TechnologyMAERSMichigan Air Emissions Reporting System

MAP Malfunction Abatement Plan MSDS Material Safety Data Sheet

NA Not Applicable

NAAQS National Ambient Air Quality Standards

NESHAP National Emission Standard for Hazardous Air Pollutants

NSPS New Source Performance Standards

NSR New Source Review
PS Performance Specification

PSD Prevention of Significant Deterioration

PTE Permanent Total Enclosure

PTI Permit to Install

RACT Reasonable Available Control Technology

ROP Renewable Operating Permit

SC Special Condition

SCR Selective Catalytic Reduction SNCR Selective Non-Catalytic Reduction

SRN State Registration Number

TBD To Be Determined

TEQ Toxicity Equivalence Quotient

USEPA/EPA United States Environmental Protection Agency

VE Visible Emissions

<sup>\*</sup>For HVLP applicators, the pressure measured at the gun air cap shall not exceed 10 psig.

(B1950) October 22, 2021 Permit No. 195-15B Page 3 of 15

#### **POLLUTANT / MEASUREMENT ABBREVIATIONS**

acfm Actual cubic feet per minute

BTU British Thermal Unit °C Degrees Celsius CO Carbon Monoxide

CO₂e Carbon Dioxide Equivalent dscf Dry standard cubic foot dscm Dry standard cubic meter pegrees Fahrenheit

gr Grains

HAP Hazardous Air Pollutant

Hg Mercury hr Hour

HP Horsepower
H<sub>2</sub>S Hydrogen Sulfide

kW Kilowatt
lb Pound
m Meter
mg Milligram
mm Millimeter
MM Million
MW Megawatts

NMOC Non-Methane Organic Compounds

NO<sub>x</sub> Oxides of Nitrogen

ng Nanogram

PM Particulate Matter

PM10 Particulate Matter equal to or less than 10 microns in diameter PM2.5 Particulate Matter equal to or less than 2.5 microns in diameter

pph Pounds per hour ppm Parts per million

ppmv Parts per million by volume ppmw Parts per million by weight

psia Pounds per square inch absolute psig Pounds per square inch gauge

scf Standard cubic feet

 $\begin{array}{ccc} \text{sec} & \text{Seconds} \\ \text{SO}_2 & \text{Sulfur Dioxide} \end{array}$ 

TAC Toxic Air Contaminant

Temp Temperature
THC Total Hydrocarbons
tpy Tons per year
µg Microgram

μm Micrometer or Micron

VOC Volatile Organic Compounds

yr Year

#### October 22, 2021 Page 4 of 15

#### **GENERAL CONDITIONS**

- 1. The process or process equipment covered by this permit shall not be reconstructed, relocated, or modified, unless a Permit to Install authorizing such action is issued by the Department, except to the extent such action is exempt from the Permit to Install requirements by any applicable rule. (R 336.1201(1))
- 2. If the installation, construction, reconstruction, relocation, or modification of the equipment for which this permit has been approved has not commenced within 18 months, or has been interrupted for 18 months, this permit shall become void unless otherwise authorized by the Department. Furthermore, the permittee or the designated authorized agent shall notify the Department via the Supervisor, Permit Section, Air Quality Division, Michigan Department of Environment, Great Lakes, and Energy, P.O. Box 30260, Lansing, Michigan 48909-7760, if it is decided not to pursue the installation, construction, reconstruction, relocation, or modification of the equipment allowed by this Permit to Install. (R 336.1201(4))
- 3. If this Permit to Install is issued for a process or process equipment located at a stationary source that is not subject to the Renewable Operating Permit program requirements pursuant to Rule 210 (R 336.1210), operation of the process or process equipment is allowed by this permit if the equipment performs in accordance with the terms and conditions of this Permit to Install. (R 336.1201(6)(b))
- 4. The Department may, after notice and opportunity for a hearing, revoke this Permit to Install if evidence indicates the process or process equipment is not performing in accordance with the terms and conditions of this permit or is violating the Department's rules or the Clean Air Act. (R 336.1201(8), Section 5510 of Act 451, PA 1994)
- 5. The terms and conditions of this Permit to Install shall apply to any person or legal entity that now or hereafter owns or operates the process or process equipment at the location authorized by this Permit to Install. If the new owner or operator submits a written request to the Department pursuant to Rule 219 and the Department approves the request, this permit will be amended to reflect the change of ownership or operational control. The request must include all of the information required by subrules (1)(a), (b), and (c) of Rule 219 and shall be sent to the District Supervisor, Air Quality Division, Michigan Department of Environment, Great Lakes, and Energy. (R 336.1219)
- 6. Operation of this equipment shall not result in the emission of an air contaminant which causes injurious effects to human health or safety, animal life, plant life of significant economic value, or property, or which causes unreasonable interference with the comfortable enjoyment of life and property. (R 336.1901)
- 7. The permittee shall provide notice of an abnormal condition, start-up, shutdown, or malfunction that results in emissions of a hazardous or toxic air pollutant which continue for more than one hour in excess of any applicable standard or limitation, or emissions of any air contaminant continuing for more than two hours in excess of an applicable standard or limitation, as required in Rule 912, to the Department. The notice shall be provided not later than two business days after start-up, shutdown, or discovery of the abnormal condition or malfunction. Written reports, if required, must be filed with the Department within 10 days after the start-up or shutdown occurred, within 10 days after the abnormal condition or malfunction has been corrected, or within 30 days of discovery of the abnormal condition or malfunction, whichever is first. The written reports shall include all of the information required in Rule 912(5). (R 336.1912)
- 8. Approval of this permit does not exempt the permittee from complying with any future applicable requirements which may be promulgated under Part 55 of 1994 PA 451, as amended or the Federal Clean Air Act.
- 9. Approval of this permit does not obviate the necessity of obtaining such permits or approvals from other units of government as required by law.
- 10. Operation of this equipment may be subject to other requirements of Part 55 of 1994 PA 451, as amended and the rules promulgated thereunder.

- 11. Except as provided in subrules (2) and (3) or unless the special conditions of the Permit to Install include an alternate opacity limit established pursuant to subrule (4) of Rule 301, the permittee shall not cause or permit to be discharged into the outer air from a process or process equipment a visible emission of density greater than the most stringent of the following. The grading of visible emissions shall be determined in accordance with Rule 303 (R 336.1303). (R 336.1301)
  - a) A six-minute average of 20 percent opacity, except for one six-minute average per hour of not more than 27 percent opacity.
  - b) A visible emission limit specified by an applicable federal new source performance standard.
  - c) A visible emission limit specified as a condition of this Permit to Install.
- 12. Collected air contaminants shall be removed as necessary to maintain the equipment at the required operating efficiency. The collection and disposal of air contaminants shall be performed in a manner so as to minimize the introduction of contaminants to the outer air. Transport of collected air contaminants in Priority I and II areas requires the use of material handling methods specified in Rule 370(2). (R 336.1370)
- 13. The Department may require the permittee to conduct acceptable performance tests, at the permittee's expense, in accordance with Rule 1001 and Rule 1003, under any of the conditions listed in Rule 1001. (R 336.2001)

## **EMISSION UNIT SPECIAL CONDITIONS**

#### **EMISSION UNIT SUMMARY TABLE**

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

	Emission Unit Description		
	(Including Process Equipment & Control		
Emission Unit ID	Device(s))	Flexible Group ID	
EUBOILER4	A 1.526 MMBtu/Hr natural gas fired boiler	NA	
EUBOILER5	A 2200 Btu/Hr natural gas fired boiler	NA	
EUBOILER6	A 2.67 MMBtu/hr dual fuel natural gas and	FGBOILER6	
	process gas boilers used for building heat		
	and the thermal hydrolysis process.		
EUBOILER7	A 2.67 MMBtu/hr dual fuel natural gas and	FGBOILER6	
	process gas boilers used for building heat		
	and the thermal hydrolysis process.		
EUBOILER8	A 2.67 MMBtu/hr dual fuel natural gas and	FGBOILER6	
	process gas boilers used for building heat		
	and the thermal hydrolysis process.		
EUENGINEGEN1	Natural gas fired reciprocating internal	FGENGINES	
	combustion engine driving an emergency		
	generator. Fuel usage: 805 dscf/hr		
EUENGINEGEN2	Natural gas fired reciprocating internal	FGENGINES	
	combustion engine driving an emergency		
	generator. Fuel usage: 2340 dscf/hr		
EUENGINEGEN3	Natural gas fired reciprocating internal	FGENGINES	
	combustion engine driving an emergency		
	generator. Fuel usage: 2340 dscf/hr		
EUENGINEGEN4	Natural gas fired reciprocating internal	FGENGINES	
	combustion engine driving an emergency		
	generator. Fuel usage: 2340 dscf/hr		
EUENGINEGEN5	Natural gas fired reciprocating internal	FGENGINES	
	combustion engine driving an emergency		
FUENCINECENIC	generator. Fuel usage: 10747 dscf/hr	FOENOMEO	
EUENGINEGEN6	Natural gas fired reciprocating internal	FGENGINES	
	combustion engine driving an emergency		
FUENCINECENZ	generator. Fuel usage: 10747 dscf/hr	FOENOINEO	
EUENGINEGEN7	Natural gas fired reciprocating internal combustion engine driving an emergency	FGENGINES	
	generator. Fuel usage: 1116 dscf/hr		
EUENGINEGEN8	Natural gas fired reciprocating internal	FGENGINES	
LOLINGINEGENO	combustion engine driving an emergency	TOLINOINES	
	generator. Fuel usage: 2340 dscf/hr		
EUENGINEGEN9	Natural gas fired reciprocating internal	FGENGINES	
	combustion engine driving an emergency	. 52.15.112.5	
	generator. Fuel usage: 2340 dscf/hr		
EUWAUKENG1	Reciprocating internal combustion	FGENGINES	
	Waukesha engine providing power to the		
	aeration blowers. Fueled by either natural		
	gas or digester methane. Heat input:		
	1.824MMBTU/hr		

Emission Unit ID	Emission Unit Description (Including Process Equipment & Control Device(s))	Flexible Group ID
EUWAUKENG2	Reciprocating internal combustion Waukesha engine providing emergency backup power to the aeration blowers. Fueled by natural gas. Heat input: 1.824MMBTU/hr	FGENGINES
EUFLARE	Flare that burns excess gas from the digesters.	NA

Changes to the equipment described in this table are subject to the requirements of R 336.1201, except as allowed by R 336.1278 to R 336.1291.

## **FLEXIBLE GROUP SPECIAL CONDITIONS**

## **FLEXIBLE GROUP SUMMARY TABLE**

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Flexible Group ID	Flexible Group Description	Associated Emission Unit IDs
FGENGINES	All reciprocating internal combustion engines at the	EUENGINEGEN1
	facility.	EUENGINEGEN2
		EUENGINEGEN3
		EUENGINEGEN4
		EUENGINEGEN5
		EUENGINEGEN6
		EUENGINEGEN7
		EUENGINEGEN8
		EUENGINEGEN9
		EUWAUKENG1
		EUWAUKENG2
FGBOILER6	Three (3) 2.67 MMBtu/hr dual fuel natural gas and	EUBOILER6
	process gas boilers	EUBOILER7
		EUBOILER8

October 22, 2021 Page 9 of 15

# FGENGINES FLEXIBLE GROUP CONDITIONS

#### **DESCRIPTION**

All reciprocating internal combustion engines at the facility.

**Emission Unit:** EUENGINEGEN1, EUENGINEGEN2, EUENGINEGEN3, EUENGINEGEN4, EUENGINEGEN5, EUENGINEGEN6, EUENGINEGEN7, EUENGINEGEN8, EUENGINEGEN9, EUWAUKENG1, EUWAUKENG2

#### POLLUTION CONTROL EQUIPMENT

NA

I. EMISSION LIMIT(S)

NA

II. MATERIAL LIMIT(S)

NA

III. PROCESS/OPERATIONAL RESTRICTION(S)

NA

IV. DESIGN/EQUIPMENT PARAMETER(S)

NΑ

V. TESTING/SAMPLING

NA

VI. MONITORING/RECORDKEEPING

NA

VII. REPORTING

NA

VIII. STACK/VENT RESTRICTION(S)

NA

#### IX. OTHER REQUIREMENT(S)

 The permittee shall comply with all applicable provisions of the National Emission Standards for Hazardous Air Pollutants, as specified in 40 CFR Part 63, Subpart A and Subpart ZZZZ, for Stationary Reciprocating Internal Combustion Engines by the initial compliance date. (40 CFR 63.6595, 40 CFR Part 63, Subparts A and ZZZZ) Oakland County Water Resources Commissioner's Office (B1950)

October 22, 2021 Permit No. 195-15B Page 10 of 15

2. The permittee shall comply with all applicable provisions of the federal Standards of Performance for New Stationary Sources, as specified in 40 CFR Part 60 Subpart A and Subpart JJJJ for Stationary Reciprocating Internal Combustion Engines, as they apply to each engine in FGENGINES. (40 CFR Part 60 Subparts A & JJJJ)

October 22, 2021 Page 11 of 15

# FGBOILER6 FLEXIBLE GROUP CONDITIONS

#### **DESCRIPTION**

Three (3) 2.67 MMBtu/hr dual fuel natural gas and process gas boilers.

Emission Unit: EUBOILER6, EUBOILER7, EUBOILER8

#### POLLUTION CONTROL EQUIPMENT

NA

#### I. EMISSION LIMIT(S)

NA

#### II. MATERIAL LIMIT(S)

1. The permittee shall burn only natural gas or process gas in FGBOILER6. (R 336.1224, R 336.1225)

#### III. PROCESS/OPERATIONAL RESTRICTION(S)

NA

#### IV. DESIGN/EQUIPMENT PARAMETER(S)

1. The maximum heat input capacity of each boiler in FGBOILER6 shall not exceed a 2.67 million BTU per hour on a fuel heat input basis. (R 336.1225, R 336.1702(a), 40 CFR 52.21(c) & (d))

#### V. TESTING/SAMPLING

NA

#### VI. MONITORING/RECORDKEEPING

- 1. The permittee shall complete all required calculations in a format acceptable to the AQD District Supervisor by the last day of the calendar month, for the previous calendar month, unless otherwise specified in any monitoring/recordkeeping special condition. (40 CFR 52.21 (c) & (d))
- 2. The permittee shall keep natural gas usage records, in a format acceptable to the AQD District Supervisor, indicating the amount of natural gas combusted on a monthly and 12-month rolling time period, in million cubic feet per year for FGBOILER6. The permittee shall keep all records on file at the facility and make them available to the Department upon request. (R 336.1205(1)(a), R 336.1702(a))
- 3. The permittee shall keep process gas usage records, in a format acceptable to the AQD District Supervisor, indicating the amount of process gas combusted on a monthly and 12-month rolling time period, in million cubic feet per year for FGBOILER6. The permittee shall keep all records on file at the facility and make them available to the Department upon request. (R 336.1205(1)(a), R 336.1702(a))

#### VII. REPORTING

NA

Oakland County Water Resources Commissioner's Office (B1950) Permit No. 195-15B

October 22, 2021 Page 12 of 15

## VIII. STACK/VENT RESTRICTION(S)

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Diameter / Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SVBOILER6*	11.5	42	40 CFR 52.21 (c) & (d)
2. SVBOILER7*	11.5	42	40 CFR 52.21 (c) & (d)
3. SVBOILER8*	11.5	42	40 CFR 52.21 (c) & (d)

<sup>\*</sup>Stack is obstructed by cowl rain cap

## IX. OTHER REQUIREMENT(S)

NA

#### October 22, 2021 Page 13 of 15

#### **FGFACILITY CONDITIONS**

#### **DESCRIPTION**

The following conditions apply source-wide to all process equipment including equipment covered by other permits, grand-fathered equipment, and exempt equipment.

#### POLLUTION CONTROL EQUIPMENT

NA

#### I. EMISSION LIMIT(S)

Pollutant	Limit	Time Period / Operating Scenario	Equipment	Monitoring / Testing Method	Underlying Applicable Requirements
1. NOx	89 tpy	12-month rolling time period as determined at the end of each calendar month.	FGFACILITY	SC VI.3 and Appendix A	R 336.1205(3)

#### II. MATERIAL LIMIT(S)

NA

#### III. PROCESS/OPERATIONAL RESTRICTION(S)

NA

#### IV. <u>DESIGN/EQUIPMENT PARAMETER(S)</u>

NA

#### V. TESTING/SAMPLING

NA

#### VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. (R 336.1201(3))

- 1. The permittee shall complete all required calculations in a format acceptable to the AQD District Supervisor and make them available by the last day of the calendar month, for the previous calendar month, unless otherwise specified in any monitoring/recordkeeping special condition. (R 336.1205(3))
- 2. The permittee shall keep, in a satisfactory manner, monthly and 12-month rolling time period records of operating time for all fuel burning emission units, except the flare. The permittee shall keep all records on file at the facility and make them available to the Department upon request. (R 336.1205(3))
- 3. The permittee shall keep, in a satisfactory manner, monthly and 12-month rolling time period NOx emission calculation records for FGFACILITY, as required by SC I.1 and Appendix A. The permittee shall keep all records on file at the facility and make them available to the Department upon request. (R 336.1205(3))
- 4. The permittee shall keep, in a satisfactory manner, monthly and 12-month rolling time period records of the volumetric flow rate of gas burned in the flare. The permittee shall keep all records on file at the facility and make them available to the Department upon request. (R 336.1205(3))

Oakland County Water Resources Commissioner's Office (B1950) Permit No. 195-15B

October 22, 2021 Page 14 of 15

## VII. REPORTING

NA

## VIII. STACK/VENT RESTRICTION(S)

NA

## IX. OTHER REQUIREMENT(S)

NA

#### **APPENDIX A**

Emission Unit	Max Heat input capacity or max fuel use capacity	NOx Emission Factor
EUBOILER4	1.526 MMBTU/hr	100 lb/MM standard cubic foot of natural gas
EUBOILER5	2200 BTU/hr	100 lb/MM standard cubic foot of natural gas
EUBOILER6	3348 cubic foot of natural gas and process gas per hour	100 lb/MM standard cubic foot of natural gas and process gas
EUBOILER7	3348 cubic foot of natural gas and process gas per hour	100 lb/MM standard cubic foot of natural gas and process gas
EUBOILER8	3348 cubic foot of natural gas and process gas per hour	100 lb/MM standard cubic foot of natural gas and process gas
EUENGINEGEN1	805 cubic foot of natural gas per hour	4.08 lb/MMBTU
EUENGINEGEN2	2340 cubic foot of natural gas per hour	4.08 lb/MMBTU
EUENGINEGEN3	2340 cubic foot of natural gas per hour	4.08 lb/MMBTU
EUENGINEGEN4	2340 cubic foot of natural gas per hour	4.08 lb/MMBTU
EUENGINEGEN5	10747 cubic foot of natural gas per hour	4.08 lb/MMBTU
EUENGINEGEN6	10747 cubic foot of natural gas per hour	4.08 lb/MMBTU
EUENGINEGEN7	1116 cubic foot of natural gas per hour	4.08 lb/MMBTU
EUENGINEGEN8	2340 cubic foot of natural gas per hour	4.08 lb/MMBTU
EUENGINEGEN9	2340 cubic foot of natural gas per hour	4.08 lb/MMBTU
EUWAUKENG1	1.824 MMBTU/hr	4.08 lb/MMBTU
EUWAUKENG2	1.824 MMBTU/hr	4.08 lb/MMBTU
EUFLARE	NA	40 lb/MM standard cubic foot of digester gas

#### For boilers:

(operating hours/month)(max heat input/heat content of fuel)(NOx emission factor)(Ton/2,000lb) = Ton/month

#### For engines driving generators:

(operating hours/month)(max fuel input)(heat content of fuel)(NOx emission factor)(Ton/2,000lb) = Ton/month

#### For the two Waukesha engines:

(operating hours/month)(max heat input)(NOx emission factor)(Ton/2,000lb) = Ton/month

#### For the flare:

(cubic feet of digester gas/month)(NOx emission factor)(Ton/2,000lb) = Ton/month