# MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY AIR QUALITY DIVISION

June 7, 2019

PERMIT TO INSTALL 35-19

**ISSUED TO** Walter P. Reuther Psychiatric Hospital

> LOCATED AT 30901 West Palmer Road Westland, Michigan

IN THE COUNTY OF Wayne

# STATE REGISTRATION NUMBER M4132

The Air Quality Division has approved this Permit to Install, pursuant to the delegation of authority from the Michigan Department of Environment, Great Lakes, and Energy. This permit is hereby issued in accordance with and subject to Section 5505(1) of Article II, Chapter I, Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended. Pursuant to Air Pollution Control Rule 336.1201(1), this permit constitutes the permittee's authority to install the identified emission unit(s) in accordance with all administrative rules of the Department and the attached conditions. Operation of the emission unit(s) identified in this Permit to Install is allowed pursuant to Rule 336.1201(6).

DATE OF RECEIPT OF ALL INFORMATION REQUIRED BY RULE 203:

# March 29, 2019

DATE PERMIT TO INSTALL APPROVED: June 7, 2019	SIGNATURE:
DATE PERMIT VOIDED:	SIGNATURE:
DATE PERMIT REVOKED:	SIGNATURE:

# PERMIT TO INSTALL

# **Table of Contents**

COMMON ACRONYMS	. 2
POLLUTANT / MEASUREMENT ABBREVIATIONS	. 3
GENERAL CONDITIONS	. 4
EMISSION UNIT SPECIAL CONDITIONS	. 6
EMISSION UNIT SUMMARY TABLE	. 6
EUMAINGEN-2220HP	. 7

# **COMMON ACRONYMS**

AQD BACT CAA CAM CEMS CFR COMS Department/department EU FG GACS GC GHGS HVLP ID IRSL ITSL LAER MACT MAERS MAP MDEQ MSDS NA NAAQS NESHAP NSPS NSR PS PSD PTE PTI RACT ROP SC SCR SCR SCR SCR SRN TBD TEQ USEPA/EPA VE	Air Quality Division Best Available Control Technology Clean Air Act Compliance Assurance Monitoring Continuous Emission Monitoring System Code of Federal Regulations Continuous Opacity Monitoring System Michigan Department of Environmental Quality Emission Unit Flexible Group Gallons of Applied Coating Solids General Condition Greenhouse Gases High Volume Low Pressure* Identification Initial Risk Screening Level Initial Threshold Screening Level Lowest Achievable Emission Rate Maximum Achievable Control Technology Michigan Air Emissions Reporting System Malfunction Abatement Plan Michigan Department of Environmental Quality Material Safety Data Sheet Not Applicable National Ambient Air Quality Standards National Emission Standard for Hazardous Air Pollutants New Source Performance Standards New Source Review Performance Specification Prevention of Significant Deterioration Permanent Total Enclosure Permit to Install Reasonable Available Control Technology Renewable Operating Permit Special Condition Selective Catalytic Reduction State Registration Number To Be Determined Toxicity Equivalence Quotient United States Environmental Protection Agency Visible Emissions
V E	

# POLLUTANT / MEASUREMENT ABBREVIATIONS

acfm BTU $^{\circ}C$ CO CO <sub>2</sub> e dscf dscm $^{\circ}F$ gr HAP Hg hr HP H2S kW Ib m mg mm MM	Actual cubic feet per minute British Thermal Unit Degrees Celsius Carbon Monoxide Carbon Dioxide Equivalent Dry standard cubic foot Dry standard cubic meter Degrees Fahrenheit Grains Hazardous Air Pollutant Mercury Hour Horsepower Hydrogen Sulfide Kilowatt Pound Meter Milligram Millimeter Million
MW NMOC	Megawatts Non-Methane Organic Compounds
NO <sub>x</sub>	Oxides of Nitrogen
ng	Nanogram
PM	Particulate Matter
PM10	Particulate Matter equal to or less than 10 microns in diameter
PM2.5	Particulate Matter equal to or less than 2.5 microns in diameter
pph	Pounds per hour Parts per million
ppm ppmv	Parts per million by volume
ppmw	Parts per million by weight
psia	Pounds per square inch absolute
psig	Pounds per square inch gauge
scf	Standard cubic feet
sec	Seconds
SO <sub>2</sub>	Sulfur Dioxide
TAC	Toxic Air Contaminant
Temp	Temperature
THC	Total Hydrocarbons
tpy	Tons per year Microgram
μg μm	Micrometer or Micron
VOC	Volatile Organic Compounds
yr	Year
<i>.</i>	

## **GENERAL CONDITIONS**

- The process or process equipment covered by this permit shall not be reconstructed, relocated, or modified, unless a Permit to Install authorizing such action is issued by the Department, except to the extent such action is exempt from the Permit to Install requirements by any applicable rule. (R 336.1201(1))
- 2. If the installation, construction, reconstruction, relocation, or modification of the equipment for which this permit has been approved has not commenced within 18 months, or has been interrupted for 18 months, this permit shall become void unless otherwise authorized by the Department. Furthermore, the permittee or the designated authorized agent shall notify the Department via the Supervisor, Permit Section, Air Quality Division, Michigan Department of Environmental Quality, P.O. Box 30260, Lansing, Michigan 48909-7760, if it is decided not to pursue the installation, construction, reconstruction, relocation, or modification of the equipment allowed by this Permit to Install. (R 336.1201(4))
- 3. If this Permit to Install is issued for a process or process equipment located at a stationary source that is not subject to the Renewable Operating Permit program requirements pursuant to Rule 210 (R 336.1210), operation of the process or process equipment is allowed by this permit if the equipment performs in accordance with the terms and conditions of this Permit to Install. (R 336.1201(6)(b))
- 4. The Department may, after notice and opportunity for a hearing, revoke this Permit to Install if evidence indicates the process or process equipment is not performing in accordance with the terms and conditions of this permit or is violating the Department's rules or the Clean Air Act. (R 336.1201(8), Section 5510 of Act 451, PA 1994)
- 5. The terms and conditions of this Permit to Install shall apply to any person or legal entity that now or hereafter owns or operates the process or process equipment at the location authorized by this Permit to Install. If the new owner or operator submits a written request to the Department pursuant to Rule 219 and the Department approves the request, this permit will be amended to reflect the change of ownership or operational control. The request must include all of the information required by subrules (1)(a), (b), and (c) of Rule 219 and shall be sent to the District Supervisor, Air Quality Division, Michigan Department of Environmental Quality. (R 336.1219)
- 6. Operation of this equipment shall not result in the emission of an air contaminant which causes injurious effects to human health or safety, animal life, plant life of significant economic value, or property, or which causes unreasonable interference with the comfortable enjoyment of life and property. (R 336.1901)
- 7. The permittee shall provide notice of an abnormal condition, start-up, shutdown, or malfunction that results in emissions of a hazardous or toxic air pollutant which continue for more than one hour in excess of any applicable standard or limitation, or emissions of any air contaminant continuing for more than two hours in excess of an applicable standard or limitation, as required in Rule 912, to the Department. The notice shall be provided not later than two business days after start-up, shutdown, or discovery of the abnormal condition or malfunction. Written reports, if required, must be filed with the Department within 10 days after the start-up or shutdown occurred, within 10 days after the abnormal condition or malfunction, whichever is first. The written reports shall include all of the information required in Rule 912(5). (R 336.1912)
- 8. Approval of this permit does not exempt the permittee from complying with any future applicable requirements which may be promulgated under Part 55 of 1994 PA 451, as amended or the Federal Clean Air Act.
- 9. Approval of this permit does not obviate the necessity of obtaining such permits or approvals from other units of government as required by law.

Walter P. Reuther Psychiatric Hospital (M4132) Permit No. 35-19

- 10. Operation of this equipment may be subject to other requirements of Part 55 of 1994 PA 451, as amended and the rules promulgated thereunder.
- 11. Except as provided in subrules (2) and (3) or unless the special conditions of the Permit to Install include an alternate opacity limit established pursuant to subrule (4) of Rule 301, the permittee shall not cause or permit to be discharged into the outer air from a process or process equipment a visible emission of density greater than the most stringent of the following. The grading of visible emissions shall be determined in accordance with Rule 303 (R 336.1303). **(R 336.1301)** 
  - a) A six-minute average of 20 percent opacity, except for one six-minute average per hour of not more than 27 percent opacity.
  - b) A visible emission limit specified by an applicable federal new source performance standard.
  - c) A visible emission limit specified as a condition of this Permit to Install.
- 12. Collected air contaminants shall be removed as necessary to maintain the equipment at the required operating efficiency. The collection and disposal of air contaminants shall be performed in a manner so as to minimize the introduction of contaminants to the outer air. Transport of collected air contaminants in Priority I and II areas requires the use of material handling methods specified in Rule 370(2). (R 336.1370)
- The Department may require the permittee to conduct acceptable performance tests, at the permittee's expense, in accordance with Rule 1001 and Rule 1003, under any of the conditions listed in Rule 1001. (R 336.2001)

#### **EMISSION UNIT SPECIAL CONDITIONS**

## EMISSION UNIT SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Emission Unit ID	Emission Unit Description (Including Process Equipment & Control Device(s))	Flexible Group ID
EUMAINGEN-2220HP	Cummins QSK50-G5-NR2 1650 kW diesel fired generator (2220 hp)	NA

Changes to the equipment described in this table are subject to the requirements of R 336.1201, except as allowed by R 336.1278 to R 336.1291.

# EUMAINGEN-2220HP EMISSION UNIT CONDITIONS

#### DESCRIPTION

Cummins QSK50-G5-NR2 1650 kW diesel fired generator (2220 hp)

#### Flexible Group ID: NA

#### POLLUTION CONTROL EQUIPMENT

NA

#### I. EMISSION LIMIT(S)

Pollutant	Limit	Time Period / Operating Scenario	Equipment	Monitoring / Testing Method	Underlying Applicable Requirements
1. NMHC + NOx	6.4 g/kW-hr	Hourly	EUMAINGEN- 2220HP	SC VI.2	40 CFR 60.4205(b), 40 CFR 60.4202(a), Table 1 of 40 CFR 89.112
2. CO	3.5 g/kW-hr	Hourly	EUMAINGEN- 2220HP	SC VI.2	40 CFR 60.4205(b), 40 CFR 60.4202(a), Table 1 of 40 CFR 89.112
3. PM	0.20 g/kW-hr	Hourly	EUMAINGEN- 2220HP	SC VI.2	40 CFR 60.4205(b), 40 CFR 60.4202(a), Table 1 of 40 CFR 89.112

#### II. MATERIAL LIMIT(S)

1. The permittee shall burn only diesel fuel, in EUMAINGEN-2220HP with the maximum sulfur content of 15 ppm (0.0015 percent) by weight and a minimum Cetane index of 40 or a maximum aromatic content of 35 volume percent. (R 336.1205(1)(a) & (3), 40 CFR 60.4207, 40 CFR 80.510(b))

### III. PROCESS/OPERATIONAL RESTRICTION(S)

- The permittee shall not operate EUMAINGEN-2220HP for more than 500 hours per year on a 12-month rolling time period basis as determined at the end of each calendar month. The 500 hours includes the hours for the purpose of necessary maintenance checks and readiness testing as described in SC III.2. (R 336.1205(1)(a) & (3), R 336.1225, R 336.1702(a), 40 CFR 52.21(c) & (d))
- 2. The permittee may operate EUMAINGEN-2220HP for no more than 100 hours per calendar year for the purpose of necessary maintenance checks and readiness testing, provided that the tests are recommended by Federal, State, or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The permittee may petition the Department for approval of additional hours to be used for maintenance checks and readiness testing. A petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency internal combustion engines beyond 100 hours per calendar year. (40 CFR 60.4211(f)(2))
- 3. EUMAINGEN-2220HP may operate up to 50 hours per calendar year in non-emergency situations, but those 50 hours are counted towards the 100 hours per calendar year provided for maintenance and testing as provided in §60.4211(f)(2). Except as provided in §60.4211(f)(3)(i), the 50 hours per calendar year for non-

emergency situations cannot be used for peak shaving or demand response, or to generate income for the permittee to supply non-emergency power as part of a financial arrangement with another entity. (40 CFR 60.4211(f)(3))

- 4. If the permittee purchased a certified engine, according to procedures specified in 40 CFR Part 60 Subpart IIII, for the same model year, the permittee shall meet the following requirements for each engine of EUMAINGEN-2220HP:
  - a) Operate and maintain the certified engine and control device according to the manufacturer's emission-related written instructions,
  - b) Change only those emission related settings that are permitted by the manufacturer, and
  - c) Meet the requirements as specified in 40 CFR 89, 94, and/or 1068, as they apply to you.

If you do not operate and maintain the certified engine and control device according to the manufacturer's emission-related written instructions, the engine will be considered a non-certified engine. (40 CFR 60.4211(a))

5. If the permittee purchased a non-certified engine or a certified engine operating in a non-certified manner, the permittee shall keep a maintenance plan for EUMAINGEN-2220HP and shall, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. (40 CFR 60.4211(g)(3))

## IV. DESIGN/EQUIPMENT PARAMETER(S)

- 1. The permittee shall equip and maintain EUMAINGEN-2220HP with non-resettable hours meters to track the operating hours. (R 336.1205(1)(a) & (3), R 336.1225, 40 CFR 60.4209)
- The maximum rated power output of EUMAINGEN-2220HP shall not exceed 1650 kW (2220 HP), as certified by the equipment manufacturer. (R 336.1205(1)(a) & (3), R 336.1225, R 336.1702(a), 40 CFR 60.4202, 40 CFR 60.4205, 40 CFR 89.112(a))

## V. TESTING/SAMPLING

Records shall be maintained on file for a period of five years. (R 336.1201(3))

- 1. If the engine is not installed, configured, operated, and maintained according to the manufacturer's emissionrelated written instructions, or the permittee changes emission-related settings in a way that is not permitted by the manufacturer, the permittee must demonstrate compliance as follows:
  - a) Conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of startup, or within 1 year after an engine and control device is no longer installed, configured, operated, and maintained in accordance with the manufacturer's emission-related written instructions, or within 1 year after you change emission-related settings in a way that is not permitted by the manufacturer.
  - b) If a performance test is required, the performance tests shall be conducted according to 40 CFR 60.4212 (less than 30 liters).
  - c) Conduct subsequent performance testing every 8,760 hours of engine operation or every 3 years, whichever comes first, thereafter to demonstrate compliance with the applicable emission standards.

No less than 30 days prior to testing, a complete test plan shall be submitted to the AQD. The permittee must submit a complete report of the test results to the AQD Technical Programs Unit and District Office within 60 days following the last date of the test. (40 CFR 60.4211(g)(3), 40 CFR 60.4212)

#### VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. (R 336.1201(3))

 The permittee shall keep all required records and calculations in a format acceptable to the AQD District Supervisor by the 30th day of the calendar month, for the previous calendar month, unless otherwise specified in any monitoring/recordkeeping special condition. (R 336.1205(1)(a) & (3), R 336.1225, 40 CFR 52.21(c) & (d), 40 CFR 60 Subpart IIII)

- 2. The permittee shall keep, in a satisfactory manner, the following records for EUMAINGEN-2220HP:
  - a) For a certified engine: The permittee shall keep records of the manufacturer certification documentation.
  - b) For an uncertified engine: The permittee shall keep records of testing required in SC V.1.

The permittee shall keep all records on file and make them available to the Department upon request. (40 CFR 60.4211)

- 3. The permittee shall keep, in a satisfactory manner, the following records of maintenance activity for EUMAINGEN-2220HP:
  - a) For a certified engine: The permittee shall keep records of the manufacturer's emission-related written instructions, and records demonstrating that the engine has been maintained according to those instructions, as specified in SC III.4.
  - b) For an uncertified engine: The permittee shall keep records of a maintenance plan, as required by SC III.5, and maintenance activities.

The permittee shall keep all records on file and make them available to the Department upon request. (40 CFR 60.4211)

- The permittee shall monitor and record, in a satisfactory manner, the total hours of operation for EUMAINGEN-2220HP, on a monthly and 12-month rolling time period basis, and the hours of operation during non-emergency operation for EUMAINGEN-2220HP, on a calendar year time basis, in a manner acceptable to the AQD District Supervisor. The permittee shall document how many hours are spent for emergency operation of EUMAINGEN-2220HP, including what classified the operation as emergency and how many hours are spent for non-emergency operation. (R 336.1205(1)(a) & (3), 40 CFR 60.4211, 40 CFR 60.4214)
- The permittee shall keep, in a satisfactory manner, fuel supplier certification records or fuel sample test data, for each delivery of diesel fuel oil used in EUMAINGEN-2220HP, demonstrating that the fuel meets the requirement of 40 CFR 80.510(b). The certification or test data shall include the name of the oil supplier or laboratory, the sulfur content, and cetane index or aromatic content of the fuel oil. (R 336.1205(1)(a) & (3), 40 CFR 80.510(b))

## VII. <u>REPORTING</u>

- Within 30 days after completion of the installation, construction, reconstruction, relocation, or modification authorized by this Permit to Install, the permittee or the authorized agent pursuant to Rule 204, shall notify the AQD District Supervisor, in writing, of the completion of the activity. Completion of the installation, construction, reconstruction, relocation, or modification is considered to occur not later than commencement of trial operation of EUMAINGEN-2220HP. (R 336.1201(7)(a))
- 2. The permittee shall submit a notification specifying whether EUMAINGEN-2220HP will be operated in a certified or a non-certified manner to the AQD District Supervisor, in writing, within 30 days following the issuance of this permit and within 30 days of switching the manner of operation. **(40 CFR 60 Subpart IIII)**

## VIII. STACK/VENT RESTRICTION(S)

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Diameter / Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SVMAINGEN	6	9.5	R 336.1225, 40 CFR 52.21(c) & (d)

# IX. OTHER REQUIREMENT(S)

- 1. The permittee shall comply with all applicable provisions of the federal Standards of Performance for New Stationary Sources as specified in 40 CFR Part 60 Subpart A and Subpart IIII for Stationary Compression Ignition Internal Combustion Engines. **(40 CFR 60 Subparts A & IIII)**
- The permittee shall comply with all applicable provisions of the National Emission Standards for Hazardous Air Pollutants, as specified in 40 CFR Part 63, Subpart A and Subpart ZZZZ for Stationary Reciprocating Internal Combustion Engines. (40 CFR 63 Subparts A & ZZZZ)

#### Footnotes:

<sup>1</sup> This condition is state only enforceable and was established pursuant to Rule 201(1)(b).