MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY AIR QUALITY DIVISION

September 10, 2020

PERMIT TO INSTALL 34-20

ISSUED TO

The Regents of the University of Michigan

LOCATED AT

1303-1269 East Ann Street (Ann Street & Zina Pitcher Place) Ann Arbor, Michigan 48109

IN THE COUNTY OF

Washtenaw

STATE REGISTRATION NUMBER M0675

The Air Quality Division has approved this Permit to Install, pursuant to the delegation of authority from the Michigan Department of Environment, Great Lakes, and Energy. This permit is hereby issued in accordance with and subject to Section 5505(1) of Article II, Chapter I, Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended. Pursuant to Air Pollution Control Rule 336.1201(1), this permit constitutes the permittee's authority to install the identified emission unit(s) in accordance with all administrative rules of the Department and the attached conditions. Operation of the emission unit(s) identified in this Permit to Install is allowed pursuant to Rule 336.1201(6).

DATE OF RECEIPT OF ALL INFORMATION REQUIRED BY RULE 203: August 12, 2020			
September 10, 2020	SIGNATURE:		
DATE PERMIT VOIDED:	SIGNATURE:		
DATE PERMIT REVOKED:	SIGNATURE:		

PERMIT TO INSTALL

Table of Contents

COMMON ACRONYMS	2
POLLUTANT / MEASUREMENT ABBREVIATIONS	3
GENERAL CONDITIONS	4
EMISSION UNIT SPECIAL CONDITIONS	6
EMISSION UNIT SUMMARY TABLE	6
FLEXIBLE GROUP SPECIAL CONDITIONS	6
FLEXIBLE GROUP SUMMARY TABLE	6
FGCITENGINES	7

COMMON ACRONYMS

AQD Air Quality Division

BACT Best Available Control Technology

CAA Clean Air Act

CAM Compliance Assurance Monitoring
CEMS Continuous Emission Monitoring System

CFR Code of Federal Regulations

COMS Continuous Opacity Monitoring System

Department/department/EGLE Michigan Department of Environment, Great Lakes, and Energy

EU Emission Unit FG Flexible Group

GACS Gallons of Applied Coating Solids

GC General Condition
GHGs Greenhouse Gases

HVLP High Volume Low Pressure*

ID Identification

IRSLInitial Risk Screening LevelITSLInitial Threshold Screening LevelLAERLowest Achievable Emission RateMACTMaximum Achievable Control TechnologyMAERSMichigan Air Emissions Reporting System

MAP Malfunction Abatement Plan MSDS Material Safety Data Sheet

NA Not Applicable

NAAQS National Ambient Air Quality Standards

NESHAP National Emission Standard for Hazardous Air Pollutants

NSPS New Source Performance Standards

NSR New Source Review
PS Performance Specification

PSD Prevention of Significant Deterioration

PTE Permanent Total Enclosure

PTI Permit to Install

RACT Reasonable Available Control Technology

ROP Renewable Operating Permit

SC Special Condition

SCR Selective Catalytic Reduction
SNCR Selective Non-Catalytic Reduction
SRN State Registration Number

TBD To Be Determined

TEQ Toxicity Equivalence Quotient

USEPA/EPA United States Environmental Protection Agency

VE Visible Emissions

^{*}For HVLP applicators, the pressure measured at the gun air cap shall not exceed 10 psig

POLLUTANT / MEASUREMENT ABBREVIATIONS

acfm Actual cubic feet per minute

BTU British Thermal Unit °C Degrees Celsius CO Carbon Monoxide

CO2e Carbon Dioxide Equivalent dscf Dry standard cubic foot dscm Dry standard cubic meter Pegrees Fahrenheit

gr Grains

HAP Hazardous Air Pollutant

Hg Mercury hr Hour

 $\begin{array}{ccc} \text{HP} & \text{Horsepower} \\ \text{H}_2 \text{S} & \text{Hydrogen Sulfide} \end{array}$

kW Kilowatt

lb Pound

m Meter

mg Milligram

mm Millimeter

MM Million

MW Megawatts

NMOC Non-Methane Organic Compounds

NO_x Oxides of Nitrogen

ng Nanogram

PM Particulate Matter

PM10 Particulate Matter equal to or less than 10 microns in diameter PM2.5 Particulate Matter equal to or less than 2.5 microns in diameter

pph Pounds per hour ppm Parts per million

ppmv Parts per million by volume
ppmw Parts per million by weight
psia Pounds per square inch absolute

psig Pounds per square inch absolut

scf Standard cubic feet

sec Seconds SO₂ Sulfur Dioxide

TAC Toxic Air Contaminant

Temp Temperature

THC Total Hydrocarbons tpy Tons per year Microgram

µm Micrometer or Micron
VOC Volatile Organic Compounds

Volatilo Organio Oo

yr Year

GENERAL CONDITIONS

- 1. The process or process equipment covered by this permit shall not be reconstructed, relocated, or modified, unless a Permit to Install authorizing such action is issued by the Department, except to the extent such action is exempt from the Permit to Install requirements by any applicable rule. (R 336.1201(1))
- 2. If the installation, construction, reconstruction, relocation, or modification of the equipment for which this permit has been approved has not commenced within 18 months, or has been interrupted for 18 months, this permit shall become void unless otherwise authorized by the Department. Furthermore, the permittee or the designated authorized agent shall notify the Department via the Supervisor, Permit Section, Air Quality Division, Michigan Department of Environment, Great Lakes, and Energy, P.O. Box 30260, Lansing, Michigan 48909-7760, if it is decided not to pursue the installation, construction, reconstruction, relocation, or modification of the equipment allowed by this Permit to Install. (R 336.1201(4))
- 3. If this Permit to Install is issued for a process or process equipment located at a stationary source that is not subject to the Renewable Operating Permit program requirements pursuant to Rule 210 (R 336.1210), operation of the process or process equipment is allowed by this permit if the equipment performs in accordance with the terms and conditions of this Permit to Install. (R 336.1201(6)(b))
- 4. The Department may, after notice and opportunity for a hearing, revoke this Permit to Install if evidence indicates the process or process equipment is not performing in accordance with the terms and conditions of this permit or is violating the Department's rules or the Clean Air Act. (R 336.1201(8), Section 5510 of Act 451, PA 1994)
- 5. The terms and conditions of this Permit to Install shall apply to any person or legal entity that now or hereafter owns or operates the process or process equipment at the location authorized by this Permit to Install. If the new owner or operator submits a written request to the Department pursuant to Rule 219 and the Department approves the request, this permit will be amended to reflect the change of ownership or operational control. The request must include all of the information required by subrules (1)(a), (b), and (c) of Rule 219 and shall be sent to the District Supervisor, Air Quality Division, Michigan Department of Environment, Great Lakes, and Energy. (R 336.1219)
- 6. Operation of this equipment shall not result in the emission of an air contaminant which causes injurious effects to human health or safety, animal life, plant life of significant economic value, or property, or which causes unreasonable interference with the comfortable enjoyment of life and property. (R 336.1901)
- 7. The permittee shall provide notice of an abnormal condition, start-up, shutdown, or malfunction that results in emissions of a hazardous or toxic air pollutant which continue for more than one hour in excess of any applicable standard or limitation, or emissions of any air contaminant continuing for more than two hours in excess of an applicable standard or limitation, as required in Rule 912, to the Department. The notice shall be provided not later than two business days after start-up, shutdown, or discovery of the abnormal condition or malfunction. Written reports, if required, must be filed with the Department within 10 days after the start-up or shutdown occurred, within 10 days after the abnormal conditions or malfunction has been corrected, or within 30 days of discovery of the abnormal condition or malfunction, whichever is first. The written reports shall include all of the information required in Rule 912(5). (R 336.1912)
- 8. Approval of this permit does not exempt the permittee from complying with any future applicable requirements which may be promulgated under Part 55 of 1994 PA 451, as amended or the Federal Clean Air Act.
- 9. Approval of this permit does not obviate the necessity of obtaining such permits or approvals from other units of government as required by law.
- 10. Operation of this equipment may be subject to other requirements of Part 55 of 1994 PA 451, as amended and the rules promulgated thereunder.

- 11. Except as provided in subrules (2) and (3) or unless the special conditions of the Permit to Install include an alternate opacity limit established pursuant to subrule (4) of Rule 301, the permittee shall not cause or permit to be discharged into the outer air from a process or process equipment a visible emission of density greater than the most stringent of the following. The grading of visible emissions shall be determined in accordance with Rule 303 (R 336.1303). (R 336.1301)
 - a) A six-minute average of 20 percent opacity, except for one six-minute average per hour of not more than 27 percent opacity.
 - b) A visible emission limit specified by an applicable federal new source performance standard.
 - c) A visible emission limit specified as a condition of this Permit to Install.
- 12. Collected air contaminants shall be removed as necessary to maintain the equipment at the required operating efficiency. The collection and disposal of air contaminants shall be performed in a manner so as to minimize the introduction of contaminants to the outer air. Transport of collected air contaminants in Priority I and II areas requires the use of material handling methods specified in Rule 370(2). (R 336.1370)
- 13. The Department may require the permittee to conduct acceptable performance tests, at the permittee's expense, in accordance with Rule 1001 and Rule 1003, under any of the conditions listed in Rule 1001. (R 336.2001)

EMISSION UNIT SPECIAL CONDITIONS

EMISSION UNIT SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Emission Unit ID	Emission Unit Description (Including Process Equipment & Control Device(s))	Installation Date / Modification Date	Flexible Group ID
EUCIT01	A 2,682 hp (2000 kW) diesel-fueled	TBD	FGCITENGINES
	emergency engine manufactured in 2020.		
EUCIT02	A 2,682 hp (2000 kW) diesel-fueled	TBD	FGCITENGINES
	emergency engine manufactured in 2020.		
EUCIT03	A 2,682 hp (2000 kW) diesel-fueled emergency engine manufactured in 2020.	TBD	FGCITENGINES

Changes to the equipment described in this table are subject to the requirements of R 336.1201, except as allowed by R 336.1278 to R 336.1291.

FLEXIBLE GROUP SPECIAL CONDITIONS

FLEXIBLE GROUP SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Flexible Group ID	Flexible Group Description	Associated Emission Unit IDs
FGCITENGINES	Three 2,682 hp (2000 kW) diesel-fueled emergency engines.	EUCIT01, EUCIT02, EUCIT03

FGCITENGINES FLEXIBLE GROUP CONDITIONS

DESCRIPTION

Three 2,682 hp (2000 kW) diesel-fueled emergency engines.

Emission Unit: EUCIT01, EUCIT02, EUCIT03.

POLLUTION CONTROL EQUIPMENT

NA

I. EMISSION LIMIT(S)

	Pollutant	Limit	Time Period / Operating Scenario	Equipment	Monitoring / Testing Method	Underlying Applicable Requirements
1.	NMHC + NOx	6.4 g/kW-hr	Hourly	Each engine in FGCITENGINES	SC VI.2	40 CFR 60.4205(b), Table 1 of 40 CFR 89.112
2.	СО	3.5 g/kW-hr	Hourly	Each engine in FGCITENGINES	SC VI.2	40 CFR 60.4205(b), Table 1 of 40 CFR 89.112
3.	PM	0.20 g/kW-hr	Hourly	Each engine in FGCITENGINES	SC VI.2	40 CFR 60.4205(b), Table 1 of 40 CFR 89.112

II. MATERIAL LIMIT(S)

1. The permittee shall burn only diesel fuel in FGCITENGINES with the maximum sulfur content of 15 ppm (0.0015 percent) by weight, and a minimum Cetane index of 40 or a maximum aromatic content of 35 volume percent. (R 336.1205(1)(a), 40 CFR 60.4207, 40 CFR 80.510(b))

III. PROCESS/OPERATIONAL RESTRICTION(S)

- 1. The permittee shall not operate each engine in FGCITENGINES for more than 500 hours per year on a 12-month rolling time period basis as determined at the end of each calendar month. The 500 hours includes the hours for the purpose of necessary maintenance checks and readiness testing as described in SC III.2. (R 336.1205(1)(a), R 336.1225, R 336.1702(a), 40 CFR 52.21 (c) & (d))
- 2. The permittee may operate each engine in FGCITENGINES for no more than 100 hours per calendar year for the purpose of necessary maintenance checks and readiness testing, provided that the tests are recommended by Federal, State, or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The permittee may petition the Department for approval of additional hours to be used for maintenance checks and readiness testing. A petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency internal combustion engines beyond 100 hours per calendar year. Each engine in FGCITENGINES may operate up to 50 hours per calendar year in non-emergency situations, but those

50 hours are counted towards the 100 hours per calendar year provided for maintenance and testing. Except as provided in 40 CFR 60.4211(f)(3)(i), the 50 hours per calendar year for non-emergency situations cannot be used for peak shaving or demand response, or to generate income for the permittee to supply non-emergency power as part of a financial arrangement with another entity. (40 CFR 60.4211(f))

- 3. If the permittee purchased a certified engine, according to procedures specified in 40 CFR Part 60, Subpart IIII, for the same model year and maximum engine power, the permittee shall meet the following requirements for each engine in FGCITENGINES:
 - a) Operate and maintain the certified engine and control device according to the manufacturer's emissionrelated written instructions.
 - b) Change only those emission-related settings that are permitted by the manufacturer.
 - c) Meet the requirements as specified in 40 CFR 89, 94, and/or 1068, as they apply to you.

If you do not operate and maintain the certified engine and control device according to the manufacturer's emission-related written instructions, the engine may be considered a non-certified engine. (40 CFR 60.4211(a) and (c))

4. If the permittee purchased a non-certified engine or a certified engine operating in a non-certified manner, the permittee shall keep a maintenance plan for FGCITENGINES and shall, to the extent practicable, maintain and operate each engine in a manner consistent with good air pollution control practice for minimizing emissions. (40 CFR 60.4211(g)(3))

IV. DESIGN/EQUIPMENT PARAMETER(S)

- 1. The permittee shall equip and maintain each engine in FGCITENGINES with non-resettable hours meters to track the operating hours. (R 336.1205(1)(a), R 336.1225, 40 CFR 60.4209)
- 2. The maximum rated power output of each engine in each engine in FGCITENGINES shall not exceed 2000 kW (2682 HP), as certified by the equipment manufacturer. (R 336.1205(1)(a), R 336.1225, 40 CFR 60.4202, 40 CFR 89.112(a))

V. TESTING/SAMPLING

Records shall be maintained on file for a period of five years. (R 336.1201(3))

- 1. If the engine is not installed, configured, operated, and maintained according to the manufacturer's emission-related written instructions, or the permittee changes emission-related settings in a way that is not permitted by the manufacturer, the permittee must demonstrate compliance as follows:
 - a) Conduct an initial performance test to demonstrate compliance with the applicable emission standards within one year of startup, or within one year after an engine and control device is no longer installed, configured, operated, and maintained in accordance with the manufacturer's emission-related written instructions, or within one year after you change emission-related settings in a way that is not permitted by the manufacturer.
 - b) If a performance test is required, the performance tests shall be conducted according to 40 CFR 60.4212.
 - c) Conduct subsequent performance testing every 8,760 hours of engine operation or every three years, whichever comes first, thereafter, to demonstrate compliance with the applicable emission standards.

No less than 30 days prior to testing, a complete test plan shall be submitted to the AQD. Verification of emission rates includes the submittal of a complete report of the test results to the AQD within 60 days following the last date of the test. (40 CFR 60.4211(g)(3), 40 CFR 60.4212)

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. (R 336.1201(3))

1. The permittee shall complete all required calculations in a format acceptable to the AQD District Supervisor by the 30th day of the calendar month, for the previous calendar month, unless otherwise specified in any monitoring/recordkeeping special condition. (R 336.1205(1)(a), 40 CFR 52.21 (c) & (d))

- 2. The permittee shall keep, in a satisfactory manner, the following records for each engine in FGCITENGINES:
 - a) For each certified engine: The permittee shall keep records of the manufacturer certification documentation.
 - b) For each uncertified engine: The permittee shall keep records of testing required in SC V.1.

The permittee shall keep all records on file and make them available to the Department upon request. (40 CFR 60.4211)

- 3. The permittee shall keep, in a satisfactory manner, the following records of maintenance activity for each engine in FGCITENGINES:
 - a) For each certified engine: The permittee shall keep records of the manufacturer's emission-related written instructions, and records demonstrating that the engine has been maintained according to those instructions, as specified in SC III.3.
 - b) For each uncertified engine: The permittee shall keep records of a maintenance plan, as required by SC III.4, and maintenance activities.

The permittee shall keep all records on file and make them available to the Department upon request. (40 CFR 60.4211)

- 4. The permittee shall monitor and record the total hours of operation and the hours of operation during non-emergencies for each engine in FGCITENGINES, on a monthly and 12-month rolling time period basis, in a manner acceptable to the District Supervisor, Air Quality Division. The permittee shall document how many hours are spent for emergency operation of each engine in FGCITENGINES, including what classified the operation as emergency. (R 336.1205(1)(a), 40 CFR 60.4211, 40 CFR 60.4214)
- 5. The permittee shall keep, in a satisfactory manner, fuel supplier certification records or fuel sample test data, for each delivery of diesel fuel oil used in FGCITENGINES, demonstrating that the fuel meets the requirement of 40 CFR 80.510(b). The certification or test data shall include the name of the oil supplier or laboratory, the sulfur content, and cetane index or aromatic content of the fuel oil. (R 336.1205(1)(a), 40 CFR 60.4207, 40 CFR 80.510(b))

VII. REPORTING

- 1. Within 30 days after completion of the installation, construction, reconstruction, relocation, or modification authorized by this Permit to Install, the permittee or the authorized agent pursuant to Rule 204, shall notify the AQD District Supervisor, in writing, of the completion of the activity. Completion of the installation, construction, reconstruction, relocation, or modification is considered to occur not later than commencement of trial operation of each engine in FGCITENGINES. (R 336.1201(7)(a))
- 2. The permittee shall submit a notification specifying whether each engine in FGCITENGINES will be operated in a certified or a non-certified manner to the AQD District Supervisor, in writing, within 30 days following the initial startup of the engine and within 30 days of switching the manner of operation. (40 CFR Part 60, Subpart IIII)
- 4. The permittee shall submit an initial notification as required in 40 CFR 63.6645(f) for each engine in FGCITENGINES. The notification must include the information in 40 CFR 63.9(b)(2)(i)-(v):
 - a) The name and address of the owner or operator.
 - b) The address (i.e., physical location) of each engine in FGCITENGINES.
 - c) An identification of the relevant standard, or other requirement, that is the basis of the notification and the source's compliance date.
 - d) A brief description of the nature, size, design, and method of operation of the source and an identification of the types of emission points within the affected source subject to the relevant standard and types of hazardous air pollutants emitted.
 - e) A statement of whether the affected source is a major source or an area source.

The notification must also include a statement that each engine in FGCITENGINES has no additional requirements and explain the basis of the exclusion (for example, that it operates exclusively as an emergency stationary RICE if it has a site rating of more than 500 brake HP located at a major source of HAP emissions). (40 CFR 63.9(b)(2)(i)-(v), 40 CFR 63.6590(b)(1), 40 CFR 63.6645(f))

VIII. STACK/VENT RESTRICTION(S)

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Diameter / Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SVCIT01	22	221.5	R 336.1225
2. SVCIT02	22	221.5	R 336.1225
3. SVCIT03	22	221.5	R 336.1225

IX. OTHER REQUIREMENT(S)

- 1. The permittee shall comply with the provisions of the federal Standards of Performance for New Stationary Sources as specified in 40 CFR Part 60, Subpart A and Subpart IIII, as they apply to each engine in FGCITENGINES. (40 CFR Part 60, Subparts A & IIII)
- 2. The permittee shall comply with the provisions of the National Emission Standards for Hazardous Air Pollutants, as specified in 40 CFR, Part 63, Subpart A and Subpart ZZZZ, as they apply to each engine in FGCITENGINES. (40 CFR Part 63, Subparts A and ZZZZ, 40 CFR 63.6585)

Footnotes:

¹ This condition is state only enforceable and was established pursuant to Rule 201(1)(b).