

**MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY
AIR QUALITY DIVISION**

EFFECTIVE DATE: June 30, 2024

ISSUED TO

DTE Electric Company – Greenwood Energy Center

State Registration Number (SRN): B6145

LOCATED AT

7000 Kilgore Road, Avoca, St. Clair County, Michigan 48006-2525

RENEWABLE OPERATING PERMIT

Permit Number: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

Administratively Complete ROP Renewal Application
Due Between December 30, 2027 and December 30, 2028

This Renewable Operating Permit (ROP) is issued in accordance with and subject to Section 5506(3) of Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451). Pursuant to Rule 210(1) of the administrative rules promulgated under Act 451, this ROP constitutes the permittee's authority to operate the stationary source identified above in accordance with the general conditions, special conditions and attachments contained herein. Operation of the stationary source and all emission units listed in the permit are subject to all applicable future or amended rules and regulations pursuant to Act 451 and the federal Clean Air Act.

SOURCE-WIDE PERMIT TO INSTALL

Permit Number: MI-PTI-B6145-2024

This Permit to Install (PTI) is issued in accordance with and subject to Section 5505(1) of Act 451. Pursuant to Rule 214a of the administrative rules promulgated under Act 451, the terms and conditions herein, identified by the underlying applicable requirement citation of Rule 201(1)(a), constitute a federally enforceable PTI. The PTI terms and conditions do not expire and remain in effect unless the criteria of Rule 201(6) are met. Operation of all emission units identified in the PTI is subject to all applicable future or amended rules and regulations pursuant to Act 451 and the federal Clean Air Act.

Michigan Department of Environment, Great Lakes, and Energy

Julie Brunner, ROP Central Unit Supervisor

TABLE OF CONTENTS

AUTHORITY AND ENFORCEABILITY 4

SECTION 1 – MAIN BOILER..... 5

A. GENERAL CONDITIONS..... 6

Permit Enforceability 6

General Provisions..... 6

Equipment & Design 7

Emission Limits 7

Testing/Sampling 7

Monitoring/Recordkeeping 8

Certification & Reporting 8

Permit Shield 9

Revisions 10

Reopenings..... 10

Renewals..... 11

Stratospheric Ozone Protection 11

Risk Management Plan 11

Emission Trading 11

Permit to Install (PTI) 12

B. SOURCE-WIDE CONDITIONS 13

C. EMISSION UNIT SPECIAL CONDITIONS 14

EMISSION UNIT SUMMARY TABLE 14

EUBOILER1..... 16

EUEASTAUXBOILER 22

EUGDF 25

EUEMGFIREPUMP 27

D. FLEXIBLE GROUP SPECIAL CONDITIONS..... 30

FLEXIBLE GROUP SUMMARY TABLE 30

FGEASTAUXBOILER-MACT 31

FGCOLDCLEANERS..... 35

E. NON-APPLICABLE REQUIREMENTS 38

APPENDICES 39

Appendix 1-1. Acronyms and Abbreviations..... 39

Appendix 2-1. Schedule of Compliance 40

Appendix 3-1. Monitoring Requirements 40

Appendix 4-1. Recordkeeping 42

Appendix 5-1. Testing Procedures 42

Appendix 6-1. Permits to Install..... 42

Appendix 7-1. Emission Calculations 42

Appendix 8-1. Reporting 42

Appendix 9-1. Acid Rain Permit 43

Appendix 10-1. Cross State Air Pollution Rule (CSAPR) Trading Program Title V Requirements 49

SECTION 2 – COMBUSTION TURBINE GENERATORS	61
A. GENERAL CONDITIONS.....	62
Permit Enforceability	62
General Provisions.....	62
Equipment & Design	63
Emission Limits	63
Testing/Sampling	63
Monitoring/Recordkeeping	64
Certification & Reporting	64
Permit Shield	65
Revisions	66
Reopenings.....	66
Renewals.....	67
Stratospheric Ozone Protection	67
Risk Management Plan.....	67
Emission Trading	67
Permit to Install (PTI)	68
B. SOURCE-WIDE CONDITIONS	69
C. EMISSION UNIT SPECIAL CONDITIONS	70
EMISSION UNIT SUMMARY TABLE.....	70
D. FLEXIBLE GROUP SPECIAL CONDITIONS.....	71
FLEXIBLE GROUP SUMMARY TABLE.....	71
FGCTGS.....	72
E. NON-APPLICABLE REQUIREMENTS	78
APPENDICES	79
Appendix 1-2. Acronyms and Abbreviations.....	79
Appendix 2-2. Schedule of Compliance	80
Appendix 3-2. Monitoring Requirements	80
Appendix 4-2. Recordkeeping	80
Appendix 5-2. Testing Procedures	80
Appendix 6-2. Permits to Install.....	80
Appendix 7-2. Emission Calculations	80
Appendix 8-2. Reporting	81
Appendix 9-2. Acid Rain Permit	82
Appendix 10-2. Cross-State Air Pollution Rule (CSAPR) Trading Program Title V Requirements	88

AUTHORITY AND ENFORCEABILITY

For the purpose of this permit, the **permittee** is defined as any person who owns or operates an emission unit at a stationary source for which this permit has been issued. The **department** is defined in Rule 104(d) as the Director of the Michigan Department of Environment, Great Lakes, and Energy (EGLE) or his or her designee.

The permittee shall comply with all specific details in the permit terms and conditions and the cited underlying applicable requirements. All terms and conditions in this ROP are both federally enforceable and state enforceable unless otherwise footnoted. Certain terms and conditions are applicable to most stationary sources for which an ROP has been issued. These general conditions are included in Part A of this ROP. Other terms and conditions may apply to a specific emission unit, several emission units which are represented as a flexible group, or the entire stationary source which is represented as a Source-Wide group. Special conditions are identified in Parts B, C, D and/or the appendices.

In accordance with Rule 213(2)(a), all underlying applicable requirements are identified for each ROP term or condition. All terms and conditions that are included in a PTI are streamlined, subsumed and/or is state-only enforceable will be noted as such.

In accordance with Section 5507 of Act 451, the permittee has included in the ROP application a compliance certification, a schedule of compliance, and a compliance plan. For applicable requirements with which the source is in compliance, the source will continue to comply with these requirements. For applicable requirements with which the source is not in compliance, the source will comply with the detailed schedule of compliance requirements that are incorporated as an appendix in this ROP. Furthermore, for any applicable requirements effective after the date of issuance of this ROP, the stationary source will meet the requirements on a timely basis, unless the underlying applicable requirement requires a more detailed schedule of compliance.

Issuance of this permit does not obviate the necessity of obtaining such permits or approvals from other units of government as required by law.

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

SECTION 1 – MAIN BOILER

A. GENERAL CONDITIONS

Permit Enforceability

- All conditions in this permit are both federally enforceable and state enforceable unless otherwise noted. **(R 336.1213(5))**
- Those conditions that are hereby incorporated in a state-only enforceable Source-Wide PTI pursuant to Rule 201(2)(d) are designated by footnote one. **(R 336.1213(5)(a), R 336.1214a(5))**
- Those conditions that are hereby incorporated in a federally enforceable Source-Wide PTI pursuant to Rule 201(2)(c) are designated by footnote two. **(R 336.1213(5)(b), R 336.1214a(3))**

General Provisions

1. The permittee shall comply with all conditions of this ROP. Any ROP noncompliance constitutes a violation of Act 451, and is grounds for enforcement action, for ROP revocation or revision, or for denial of the renewal of the ROP. All terms and conditions of this ROP that are designated as federally enforceable are enforceable by the Administrator of the United States Environmental Protection Agency (USEPA) and by citizens under the provisions of the federal Clean Air Act (CAA). Any terms and conditions based on applicable requirements which are designated as “state-only” are not enforceable by the USEPA or citizens pursuant to the CAA. **(R 336.1213(1)(a))**
2. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this ROP. **(R 336.1213(1)(b))**
3. This ROP may be modified, revised, or revoked for cause. The filing of a request by the permittee for a permit modification, revision, or termination, or a notification of planned changes or anticipated noncompliance does not stay any ROP term or condition. This does not supersede or affect the ability of the permittee to make changes, at the permittee’s own risk, pursuant to Rule 215 and Rule 216. **(R 336.1213(1)(c))**
4. The permittee shall allow the department, or an authorized representative of the department, upon presentation of credentials and other documents as may be required by law and upon stating the authority for and purpose of the investigation, to perform any of the following activities: **(R 336.1213(1)(d))**
 - a. Enter, at reasonable times, a stationary source or other premises where emissions-related activity is conducted or where records must be kept under the conditions of the ROP.
 - b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the ROP.
 - c. Inspect, at reasonable times, any of the following:
 - i. Any stationary source.
 - ii. Any emission unit.
 - iii. Any equipment, including monitoring and air pollution control equipment.
 - iv. Any work practices or operations regulated or required under the ROP.
 - d. As authorized by Section 5526 of Act 451, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the ROP or applicable requirements.
5. The permittee shall furnish to the department, within a reasonable time, any information the department may request, in writing, to determine whether cause exists for modifying, revising, or revoking the ROP or to determine compliance with this ROP. Upon request, the permittee shall also furnish to the department copies of any records that are required to be kept as a term or condition of this ROP. For information which is claimed by the permittee to be confidential, consistent with the requirements of the 1976 PA 442, MCL §15.231 et seq., and known as the Freedom of Information Act, the person may also be required to furnish the records directly to the USEPA together with a claim of confidentiality. **(R 336.1213(1)(e))**

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

6. A challenge by any person, the Administrator of the USEPA, or the department to a particular condition or a part of this ROP shall not set aside, delay, stay, or in any way affect the applicability or enforceability of any other condition or part of this ROP. **(R 336.1213(1)(f))**
7. The permittee shall pay fees consistent with the fee schedule and requirements pursuant to Section 5522 of Act 451. **(R 336.1213(1)(g))**
8. This ROP does not convey any property rights or any exclusive privilege. **(R 336.1213(1)(h))**

Equipment & Design

9. Any collected air contaminants shall be removed as necessary to maintain the equipment at the required operating efficiency. The collection and disposal of air contaminants shall be performed in a manner so as to minimize the introduction of contaminants to the outer air. Transport of collected air contaminants in Priority I and II areas requires the use of material handling methods specified in Rule 370(2).² **(R 336.1370)**
10. Any air cleaning device shall be installed, maintained, and operated in a satisfactory manner and in accordance with the Michigan Air Pollution Control rules and existing law. **(R 336.1910)**

Emission Limits

11. Unless otherwise specified in this ROP, the permittee shall comply with Rule 301, which states, in part, “Except as provided in Subrules 2, 3, and 4 of this rule, a person shall not cause or permit to be discharged into the outer air from a process or process equipment a visible emission of a density greater than the most stringent of the following:”² **(R 336.1301(1))**
 - a. A 6-minute average of 20% opacity, except for one 6-minute average per hour of not more than 27% opacity.
 - b. A limit specified by an applicable federal new source performance standard.

The grading of visible emissions shall be determined in accordance with Rule 303.

12. The permittee shall not cause or permit the emission of an air contaminant or water vapor in quantities that cause, alone or in reaction with other air contaminants, either of the following:
 - a. Injurious effects to human health or safety, animal life, plant life of significant economic value, or property.¹ **(R 336.1901(a))**
 - b. Unreasonable interference with the comfortable enjoyment of life and property.¹ **(R 336.1901(b))**

Testing/Sampling

13. The department may require the owner or operator of any source of an air contaminant to conduct acceptable performance tests, at the owner’s or operator’s expense, in accordance with Rule 1001 and Rule 1003, under any of the conditions listed in Rule 1001(1).² **(R 336.2001)**
14. Any required performance testing shall be conducted in accordance with Rule 1001(2), Rule 1001(3) and Rule 1003. **(R 336.2001(2), R 336.2001(3), R 336.2003(1))**
15. Any required test results shall be submitted to the Air Quality Division (AQD) in the format prescribed by the applicable reference test method within 60 days following the last date of the test. **(R 336.2001(5))**

Monitoring/Recordkeeping

16. Records of any periodic emission or parametric monitoring required in this ROP shall include the following information specified in Rule 213(3)(b)(i), where appropriate. **(R 336.1213(3)(b))**
 - a. The date, location, time, and method of sampling or measurements.
 - b. The dates the analyses of the samples were performed.
 - c. The company or entity that performed the analyses of the samples.
 - d. The analytical techniques or methods used.
 - e. The results of the analyses.
 - f. The related process operating conditions or parameters that existed at the time of sampling or measurement.
17. All required monitoring data, support information and all reports, including reports of all instances of deviation from permit requirements, shall be kept and furnished to the department upon request for a period of not less than 5 years from the date of the monitoring sample, measurement, report or application. Support information includes all calibration and maintenance records and all original strip-chart recordings, or other original data records, for continuous monitoring instrumentation and copies of all reports required by the ROP. **(R 336.1213(1)(e), R 336.1213(3)(b)(ii))**

Certification & Reporting

18. Except for the alternate certification schedule provided in Rule 213(3)(c)(iii)(B), any document required to be submitted to the department as a term or condition of this ROP shall contain an original certification by a Responsible Official which state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. **(R 336.1213(3)(c))**
19. A Responsible Official shall certify to the appropriate AQD District Office and to the USEPA that the stationary source is and has been in compliance with all terms and conditions contained in the ROP except for deviations that have been or are being reported to the appropriate AQD District Office pursuant to Rule 213(3)(c). This certification shall include all the information specified in Rule 213(4)(c)(i) through (v) and shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the certification are true, accurate, and complete. The annual compliance certification (pursuant to Rule 213(4)(c)) shall be submitted to the USEPA through the USEPA's Central Data Exchange (CDX) using the Compliance and Emissions Data Reporting Interface (CEDRI), which can be accessed through CDX (<https://cdx.epa.gov/>), unless it contains confidential business information then use the following address: USEPA, Air Compliance Data - Michigan, Air and Radiation Division, 77 West Jackson Boulevard, Chicago, Illinois 60604-3507. **(R 336.1213(4)(c))**
20. The certification of compliance shall be submitted annually for the term of this ROP as detailed in the special conditions, or more frequently if specified in an applicable requirement or in this ROP. **(R 336.1213(4)(c))**
21. The permittee shall promptly report any deviations from ROP requirements and certify the reports. The prompt reporting of deviations from ROP requirements is defined in Rule 213(3)(c)(ii) as follows, unless otherwise described in this ROP. **(R 336.1213(3)(c))**
 - a. For deviations that exceed the emissions allowed under the ROP, prompt reporting means reporting consistent with the requirements of Rule 912 as detailed in Condition 25. All reports submitted pursuant to this paragraph shall be promptly certified as specified in Rule 213(3)(c)(iii).
 - b. For deviations which exceed the emissions allowed under the ROP and which are not reported pursuant to Rule 912 due to the duration of the deviation, prompt reporting means the reporting of all deviations in the semiannual reports required by Rule 213(3)(c)(i). The report shall describe reasons for each deviation and the actions taken to minimize or correct each deviation.
 - c. For deviations that do not exceed the emissions allowed under the ROP, prompt reporting means the reporting of all deviations in the semiannual reports required by Rule 213(3)(c)(i). The report shall describe the reasons for each deviation and the actions taken to minimize or correct each deviation.

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

22. For reports required pursuant to Rule 213(3)(c)(ii), prompt certification of the reports is described in Rule 213(3)(c)(iii) as either of the following: **(R 336.1213(3)(c))**
 - a. Submitting a certification by a Responsible Official with each report which states that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.
 - b. Submitting, within 30 days following the end of a calendar month during which one or more prompt reports of deviations from the emissions allowed under the ROP were submitted to the department pursuant to Rule 213(3)(c)(ii), a certification by a Responsible Official which states that; “based on information and belief formed after reasonable inquiry, the statements and information contained in each of the reports submitted during the previous month were true, accurate, and complete.” The certification shall include a listing of the reports that are being certified. Any report submitted pursuant to Rule 213(3)(c)(ii) that will be certified on a monthly basis pursuant to this paragraph shall include a statement that certification of the report will be provided within 30 days following the end of the calendar month.
23. Semiannually for the term of the ROP as detailed in the special conditions, or more frequently if specified, the permittee shall submit certified reports of any required monitoring to the appropriate AQD District Office. All instances of deviations from ROP requirements during the reporting period shall be clearly identified in the reports. **(R 336.1213(3)(c)(i))**
24. On an annual basis, the permittee shall report the actual emissions, or the information necessary to determine the actual emissions, of each regulated air pollutant as defined in Rule 212(6) for each emission unit utilizing the emissions inventory forms provided by the department. **(R 336.1212(6))**
25. The permittee shall provide notice of an abnormal condition, start-up, shutdown, or malfunction that results in emissions of a hazardous or toxic air pollutant which continue for more than one hour in excess of any applicable standard or limitation, or emissions of any air contaminant continuing for more than two hours in excess of an applicable standard or limitation, as required in Rule 912, to the appropriate AQD District Office. The notice shall be provided not later than two business days after the start-up, shutdown, or discovery of the abnormal conditions or malfunction. Notice shall be by any reasonable means, including electronic, telephonic, or oral communication. Written reports, if required under Rule 912, must be submitted to the appropriate AQD District Supervisor within 10 days after the start-up or shutdown occurred, within 10 days after the abnormal conditions or malfunction has been corrected, or within 30 days of discovery of the abnormal conditions or malfunction, whichever is first. The written reports shall include all of the information required in Rule 912(5) and shall be certified by a Responsible Official in a manner consistent with the CAA.² **(R 336.1912)**

Permit Shield

26. Compliance with the conditions of the ROP shall be considered compliance with any applicable requirements as of the date of ROP issuance if either of the following provisions is satisfied. **(R 336.1213(6)(a)(i), R 336.1213(6)(a)(ii))**
 - a. The applicable requirements are included and are specifically identified in the ROP.
 - b. The permit includes a determination or concise summary of the determination by the department that other specifically identified requirements are not applicable to the stationary source.

Any requirements identified in Part E of this ROP have been identified as non-applicable to this ROP and are included in the permit shield.
27. Nothing in this ROP shall alter or affect any of the following:
 - a. The provisions of Section 303 of the CAA, emergency orders, including the authority of the USEPA under Section 303 of the CAA. **(R 336.1213(6)(b)(i))**
 - b. The liability of the owner or operator of this source for any violation of applicable requirements prior to or at the time of this ROP issuance. **(R 336.1213(6)(b)(ii))**
 - c. The applicable requirements of the acid rain program, consistent with Section 408(a) of the CAA. **(R 336.1213(6)(b)(iii))**

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

- d. The ability of the USEPA to obtain information from a source pursuant to Section 114 of the CAA. **(R 336.1213(6)(b)(iv))**
28. The permit shield shall not apply to provisions incorporated into this ROP through procedures for any of the following:
 - a. Operational flexibility changes made pursuant to Rule 215. **(R 336.1215(5))**
 - b. Administrative Amendments made pursuant to Rule 216(1)(a)(i)-(iv). **(R 336.1216(1)(b)(iii))**
 - c. Administrative Amendments made pursuant to Rule 216(1)(a)(v) until the amendment has been approved by the department. **(R 336.1216(1)(c)(iii))**
 - d. Minor Permit Modifications made pursuant to Rule 216(2). **(R 336.1216(2)(f))**
 - e. State-Only Modifications made pursuant to Rule 216(4) until the changes have been approved by the department. **(R 336.1216(4)(e))**
29. Expiration of this ROP results in the loss of the permit shield. If a timely and administratively complete application for renewal is submitted not more than 18 months, but not less than 6 months, before the expiration date of the ROP, but the department fails to take final action before the end of the ROP term, the existing ROP does not expire until the renewal is issued or denied, and the permit shield shall extend beyond the original ROP term until the department takes final action. **(R 336.1217(1)(c), R 336.1217(1)(a))**

Revisions

30. For changes to any process or process equipment covered by this ROP that do not require a revision of the ROP pursuant to Rule 216, the permittee must comply with Rule 215. **(R 336.1215, R 336.1216)**
31. A change in ownership or operational control of a stationary source covered by this ROP shall be made pursuant to Rule 216(1). **(R 336.1219(2))**
32. For revisions to this ROP, an administratively complete application shall be considered timely if it is received by the department in accordance with the time frames specified in Rule 216. **(R 336.1210(10))**
33. Pursuant to Rule 216(1)(b)(iii), Rule 216(2)(d) and Rule 216(4)(d), after a change has been made, and until the department takes final action, the permittee shall comply with both the applicable requirements governing the change and the ROP terms and conditions proposed in the application for the modification. During this time period, the permittee may choose to not comply with the existing ROP terms and conditions that the application seeks to change. However, if the permittee fails to comply with the ROP terms and conditions proposed in the application during this time period, the terms and conditions in the ROP are enforceable. **(R 336.1216(1)(c)(iii), R 336.1216(2)(d), R 336.1216(4)(d))**

Reopenings

34. A ROP shall be reopened by the department prior to the expiration date and revised by the department under any of the following circumstances:
 - a. If additional requirements become applicable to this stationary source with three or more years remaining in the term of the ROP, but not if the effective date of the new applicable requirement is later than the ROP expiration date. **(R 336.1217(2)(a)(i))**
 - b. If additional requirements pursuant to Title IV of the CAA become applicable to this stationary source. **(R 336.1217(2)(a)(ii))**
 - c. If the department determines that the ROP contains a material mistake, information required by any applicable requirement was omitted, or inaccurate statements were made in establishing emission limits or the terms or conditions of the ROP. **(R 336.1217(2)(a)(iii))**
 - d. If the department determines that the ROP must be revised to ensure compliance with the applicable requirements. **(R 336.1217(2)(a)(iv))**

Renewals

35. For renewal of this ROP, an administratively complete application shall be considered timely if it is received by the department not more than 18 months, but not less than 6 months, before the expiration date of the ROP. **(R 336.1210(9))**

Stratospheric Ozone Protection

36. If the permittee is subject to Title 40 of the Code of Federal Regulations (CFR), Part 82 and services, maintains, or repairs appliances except for motor vehicle air conditioners (MVAC), or disposes of appliances containing refrigerant, including MVAC and small appliances, or if the permittee is a refrigerant reclaimer, appliance owner or a manufacturer of appliances or recycling and recovery equipment, the permittee shall comply with all applicable standards for recycling and emissions reduction pursuant to 40 CFR Part 82, Subpart F.
37. If the permittee is subject to 40 CFR Part 82 and performs a service on motor (fleet) vehicles when this service involves refrigerant in the MVAC, the permittee is subject to all the applicable requirements as specified in 40 CFR Part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners. The term “motor vehicle” as used in Subpart B does not include a vehicle in which final assembly of the vehicle has not been completed by the original equipment manufacturer. The term MVAC as used in Subpart B does not include the air-tight sealed refrigeration system used for refrigerated cargo or an air conditioning system on passenger buses using Hydrochlorofluorocarbon-22 refrigerant.

Risk Management Plan

38. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall register and submit to the USEPA the required data related to the risk management plan for reducing the probability of accidental releases of any regulated substances listed pursuant to Section 112(r)(3) of the CAA as amended in 40 CFR 68.130. The list of substances, threshold quantities, and accident prevention regulations promulgated under 40 CFR Part 68, do not limit in any way the general duty provisions under Section 112(r)(1).
39. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall comply with the requirements of 40 CFR Part 68, no later than the latest of the following dates as provided in 40 CFR 68.10(a):
- June 21, 1999,
 - Three years after the date on which a regulated substance is first listed under 40 CFR 68.130, or
 - The date on which a regulated substance is first present above a threshold quantity in a process.
40. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall submit any additional relevant information requested by any regulatory agency necessary to ensure compliance with the requirements of 40 CFR Part 68.
41. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall annually certify compliance with all applicable requirements of Section 112(r) as detailed in Rule 213(4)(c)). **(40 CFR Part 68)**

Emission Trading

42. Emission averaging and emission reduction credit trading are allowed pursuant to any applicable interstate or regional emission trading program that has been approved by the Administrator of the USEPA as a part of Michigan's State Implementation Plan. Such activities must comply with Rule 215 and Rule 216. **(R 336.1213(12))**

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

Permit to Install (PTI)

43. The process or process equipment included in this permit shall not be reconstructed, relocated, or modified unless a PTI authorizing such action is issued by the department, except to the extent such action is exempt from the PTI requirements by any applicable rule.² **(R 336.1201(1))**
44. The department may, after notice and opportunity for a hearing, revoke PTI terms or conditions if evidence indicates the process or process equipment is not performing in accordance with the terms and conditions of the PTI or is violating the department's rules or the CAA.² **(R 336.1201(8), Section 5510 of Act 451)**
45. The terms and conditions of a PTI shall apply to any person or legal entity that now or hereafter owns or operates the process or process equipment at the location authorized by the PTI. If a new owner or operator submits a written request to the department pursuant to Rule 219 and the department approves the request, this PTI will be amended to reflect the change of ownership or operational control. The request must include all of the information required by Subrules (1)(a), (b) and (c) of Rule 219. The written request shall be sent to the appropriate AQD District Supervisor, EGLE.² **(R 336.1219)**
46. If the installation, reconstruction, relocation, or modification of the equipment for which PTI terms and conditions have been approved has not commenced within 18 months of the original PTI issuance date, or has been interrupted for 18 months, the applicable terms and conditions from that PTI, as incorporated into the ROP, shall become void unless otherwise authorized by the department. Furthermore, the person to whom that PTI was issued, or the designated authorized agent, shall notify the department via the Supervisor, Permit Section, EGLE, AQD, P. O. Box 30260, Lansing, Michigan 48909, if it is decided not to pursue the installation, reconstruction, relocation, or modification of the equipment allowed by the terms and conditions from that PTI.² **(R 336.1201(4))**

Footnotes:

¹This condition is state-only enforceable and was established pursuant to Rule 201(1)(b).

²This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

B. SOURCE-WIDE CONDITIONS

Part B outlines the Source-Wide Terms and Conditions that apply to this stationary source. The permittee is subject to these special conditions for the stationary source in addition to the general conditions in Part A and any other terms and conditions contained in this ROP.

The permittee shall comply with all specific details in the special conditions and the underlying applicable requirements cited. If a specific condition type does not apply to this source, NA (not applicable) has been used in the table. If there are no Source-Wide Conditions, this section will be left blank.

C. EMISSION UNIT SPECIAL CONDITIONS

Part C outlines terms and conditions that are specific to individual emission units listed in the Emission Unit Summary Table. The permittee is subject to the special conditions for each emission unit in addition to the General Conditions in Part A and any other terms and conditions contained in this ROP.

The permittee shall comply with all specific details in the special conditions and the underlying applicable requirements cited. If a specific condition type does not apply, NA (not applicable) has been used in the table. If there are no conditions specific to individual emission units, this section will be left blank.

EMISSION UNIT SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Emission Unit ID	Emission Unit Description (Including Process Equipment & Control Device(s))	Installation Date/ Modification Date	Flexible Group ID
EUBOILER1	Greenwood Energy Center Unit 1 boiler, nominally rated at 785 MW gross output primarily fueled by natural gas but can also burn No. 2 fuel oil, No. 6 fuel oil, specification used oil, or a combination thereof (hereinafter termed "oil fuels"), Flue gas injection is used for NOx control.	05-01-1972 / 09-11-1997	NA
EUEASTAUXBOILER	East auxiliary boiler nominally rated at 181.4 MMBTU per hour heat input, equipped with a continuous oxygen trim system and fired only with pipeline quality natural gas. Maximum steam output is 150,000 pounds per hour.	05-01-1972 / 09-11-1997	FGEASTAUXBOILER- MACT
EUCOLDCLEANER1	EUCOLDCLEANER1 is located at the Machine shop. Model#E1000, Serial#3077801, Reid Vapor Pressure #0.067 kPa, 0.0097 psi, Type of Solvent# Zep Dyna 143, Air/Vapor Interface#2.8 sqft(27"x15")	04-01-1998	FGCOLDCLEANERS
EUCOLDCLEANER2	EUCOLDCLEANER2 is located at the plant first floor. Model#90320W, Serial#5081388, Reid Vapor Pressure #0.067 kPa, 0.0097 psi, Type of Solvent# Zep Dyna 143, Air/Vapor Interface#5.5 sqft (35"x23")	08-08-2007	FGCOLDCLEANERS
EUGDF	A new (placed into operation on or after July 1, 1979) gasoline underground storage tank of 2,500--gallon capacity (9.46 cubic meters) for gasoline dispensing at the facility. This emission unit is exempt from the requirements of R 336.1201 per R 336.1284(2)(g)(ii).	09-09-1992	NA

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024
 Expiration Date: June 30, 2029
 PTI No: MI-PTI-B6145-2024

Emission Unit ID	Emission Unit Description (Including Process Equipment & Control Device(s))	Installation Date/ Modification Date	Flexible Group ID
EUEMGFIREPUMP	This engine is a turbo-charged, air-cooled, 4-cycle, and in-line 6-cylinder diesel compression ignition engine with 8.9-liter total cylinder displacement. Maximum heat input of 1.98 MMBTU/hr with an output at 260 HP at 1760 RPM. This engine is subject to 40 CFR Part 60, Subpart IIII and 40 CFR Part 63, Subpart ZZZZ. The fire pump engine is exempt from R 336.1201 per R 336.1285(2)(g).	08-03-2016	NA

EUBOILER1 EMISSION UNIT CONDITIONS

DESCRIPTION

Greenwood Energy Center Unit 1 boiler, nominally rated at 785 MW gross output, primarily fueled by natural gas but can also burn No. 2 fuel oil, No. 6 fuel oil, specification used oil, or a combination thereof (hereinafter termed “oil fuels”), Flue gas injection is used for NOx control.

Flexible Group ID: NA

POLLUTION CONTROL EQUIPMENT

Flue gas injection system

I. EMISSION LIMIT(S)

Pollutant	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. Sulfur dioxide (SO ₂)	0.80 lb/MMBTU heat input ^{2,a}	Hourly (3-hour average ^{c,d})	EUBOILER1	SC VI.1	40 CFR 60.43(a)(1)
2. Sulfur dioxide (SO ₂)	5760 lbs. per hour ²	Hourly (3-hour average ^c)	EUBOILER1	SC VI.1	R 336.1201(3)
3. Particulate matter (PM)	0.072 lb/MMBTU heat input ²	Hourly	EUBOILER1	SC V.4	R 336.1331(1)(c)
4. Particulate matter (PM)	0.10 lb/MMBTU heat input	Hourly	EUBOILER1	SC V.4	40 CFR 60.42(a)(1)
5. Particulate matter (PM)	518.4 lbs. per hour ²	Hourly	EUBOILER1	SC V.4	R 336.1331(1)(c)
6. Particulate matter (PM)	0.10 lb. per 1,000 lbs. of exhaust gases on a wet basis, corrected to 50% excess air ²	Hourly	EUBOILER1	SC V.2	R 336.1331(1)(c)
7. Nitrogen Oxides (NOx) <i>(when firing oil fuels only)</i>	0.30 lb/MMBTU heat input ²	Hourly (3-hour average ^{c,d})	EUBOILER1	SC VI.1	40 CFR 60.44(a)(2)
8. Nitrogen Oxides (NOx) <i>(When firing oil fuels only)</i>	2,160 lbs. per hour ²	Hourly (3-hour average ^c)	EUBOILER1	SC VI.1	R 336.1201(3)
9. Nitrogen Oxides (NOx) <i>(When firing natural gas only)</i>	0.20 lb/MMBTU heat input ²	Hourly (3-hour average ^{c,d})	EUBOILER1	SC VI.1	40 CFR 60.44(a)(1)

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

Pollutant	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
10. Nitrogen Oxides (NOx) <i>(When firing natural gas only)</i>	1,494 lbs. per hour ²	Hourly (3-hour average ^c)	EUBOILER1	SC VI.1	R 336.1201(3)
11. Nitrogen Oxides (NOx) <i>(When co-firing oil fuels and natural gas only)</i>	Prorated between 0.20 and 0.30 lb/MMBTU ^{2,b}	Hourly (3-hour average ^{c,d})	EUBOILER1	SC VI.1	40 CFR 60.44(b)
12. Visible Emissions	20% opacity average per 6-minute period except for one 6-minute period per hour of not more than 27% opacity ²	6-minute average	EUBOILER1	SC VI.1	R 336.1301(1)(b), 40 CFR 60.42(a)(2)

^a This is equivalent to using oil fuels with 0.78% sulfur content and a heat value of 19,390 BTU's per pound. Compliance with this limit shall be considered compliance with the limit of R 336.1401.

^b Based on the ratio of the total heat input provided by the natural gas and the total heat input provided by the oil that is being combusted as a mixture in the boiler.

^c Compliance with SO₂/NOx emission rate limits shall be based upon any three-hour average determined in accordance with the performance test established by 40 CFR 60.8.

^d Operations during periods of startup, shutdown, or malfunction shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the applicable emission limit during periods of startup, shutdown, and malfunction be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard per 40 CFR 60.8(c).

II. MATERIAL LIMIT(S)

- The permittee shall burn only No. 2 fuel oil, No. 6 fuel oil, specification used oil, or natural gas or blends of these fuels in EUBOILER1.² (R 336.1201(3))

Material	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. Total halogens in specification used oil	≤ 4,000 ppm ^{2,*} (by weight)	Each batch Received	EUBOILER1	SC V.3	R 336.1201(3)
2. Total lead (Pb) in specification used oil	≤ 100 ppm ²	Each batch Received	EUBOILER1	SC V.3	R 336.1201(3)
3. Total cadmium (Cd) in specification used oil	≤ 2 ppm ²	Each batch Received	EUBOILER1	SC V.3	R 336.1201(3)
4. Total chromium (Cr) in specification used oil	≤ 10 ppm ²	Each batch Received	EUBOILER1	SC V.3	R 336.1201(3)

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

Material	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
5. Total arsenic (As) in specification used oil	≤ 5 ppm ²	Each batch Received	EUBOILER1	SC V.3	R 336.1201(3)
6. Flashpoint of specification used oil	≥ 100 °F ² (closed cup)	Each batch Received	EUBOILER1	SC V.3	R 336.1201(3)
7. Polychlorinated biphenyls (PCB) in specification used oil	< 2 ppm ²	Each batch received	EUBOILER1	SC V.3	R 336.1201(3)

* If total halogens are >1,000 ppm, an analysis shall be conducted to ensure that no halogenated compound listed in Appendix VIII of 40 CFR Part 261 is present in concentrations greater than 100 ppm.

III. PROCESS/OPERATIONAL RESTRICTION(S)

1. The permittee shall not receive, unload, or store, any specification used oil which is not accompanied by the vendor's certification and analytical data. Analytical data must show compliance with the limits set forth in Section II prior to unloading and/or storing the specification used oil.² **(R 336.1201(3))**
2. The permittee shall not operate EUBOILER1 unless all of the requirements of 40 CFR 52.21, the federal Prevention of Significant Deterioration rules and regulations, are being met. This permit is issued pursuant to the determination that the equipment covered by this permit can comply with all of the requirements under these rules and regulations.² **(R 336.1201(3))**
3. The permittee shall submit within 90 days of permit issuance, and implement and maintain, a malfunction abatement plan (MAP) as described in Rule 911(2), for EUBOILER1. The MAP shall, at a minimum, specify the following:
 - a. A complete preventative maintenance program including identification of the supervisory personnel responsible for overseeing the inspection, maintenance, and repair of air-cleaning devices, a description of the items or conditions that shall be inspected, the frequency of the inspections or repairs, and an identification of the major replacement parts that shall be maintained in inventory for quick replacement.
 - b. An identification of the source and air-cleaning device operating variables that shall be monitored to detect a malfunction or failure, the normal operating range of these variables, and a description of the method of monitoring or surveillance procedures.
 - c. A description of the corrective procedures or operational changes that shall be taken in the event of a malfunction or failure to achieve compliance with the applicable emission limits.

If at any time the MAP fails to address or inadequately addresses an event that meets the characteristics of a malfunction, the permittee shall amend the MAP within 45 days after such an event occurs. The permittee shall also amend the MAP within 45 days, if new equipment is installed or upon request from the District Supervisor. The permittee shall submit the MAP and any amendments to the MAP to the AQD District Supervisor for review and approval. If the AQD does not notify the permittee within 90 days of submittal, the MAP or amended MAP shall be considered approved. Until an amended plan is approved, the permittee shall implement corrective procedures or operational changes to achieve compliance with all applicable emission limits. **(R 336.1911, R 336.1912(6))**

IV. DESIGN/EQUIPMENT PARAMETER(S)

1. The permittee shall not operate EUBOILER1 unless the flue gas injection system is installed, maintained, and operated in a manner satisfactory to the District Supervisor.² **(R 336.1910)**

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

V. TESTING/SAMPLING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall analyze and record the sulfur content of the oil fuel.² **(R 336.1201(3))**
2. Every third year, or more frequently upon AQD request, the permittee shall verify PM emission rates from EUBOILER1 by testing at owner's expense, in accordance with Department requirements. The permittee shall test the particulate matter emission rate using Reference Method 5, results reported on a wet basis, corrected to 50% excess air. Alternate methods may be used, subject to AQD approval. No less than 30 days prior to testing, the permittee shall submit a complete test plan to the AQD Technical Programs Unit and District Office. The AQD must approve the final plan prior to testing. Verification of emission rates includes the submittal of a complete report of the test results to the AQD Technical Programs Unit and District Office within 60 days following the last date of the test.² **(R 336.1201(3), R 336.2001(3), R 336.2001(4), R 336.2001(5))**
3. Testing shall be performed using an approved EPA Method listed in:

Pollutant	Test Method Reference
PM	40 CFR Part 60, Appendix A; Part 10 of the Michigan Air Pollution Control Rules

An alternate method, or a modification to the approved EPA Method, may be specified in an AQD approved Test Protocol and must meet the requirements of the federal Clean Air Act, all applicable state and federal rules and regulations, and be within the authority of the AQD to make the change. No less than 30 days prior to testing, the permittee shall submit a complete test plan to the AQD Technical Programs Unit and District Office. The AQD must approve the final plan prior to testing, including any modifications to the method in the test protocol that are proposed after initial submittal. The permittee must submit a complete report of the test results to the AQD Technical Programs Unit and District Office within 60 days following the last date of the test. **(R 336.1213(3), R 336.2001, R 336.2003, R 336.2004)**

4. The permittee shall verify the PM emission rates from EUBOILER1, and at a minimum, every three years from the date of the last test, thereafter. **(R 336.1213(3), R 336.2001, R 336.2003, R 336.2004)**
5. The permittee shall not operate EUBOILER1 unless the approved facility Quality Control Program for Burning Specification Used Oil is implemented and maintained.² **(R 336.1201(3))**
6. The permittee shall notify the AQD Technical Programs Unit Supervisor and the District Supervisor not less than 30 days before testing of the time and place performance tests will be conducted. **(R 336.1213(3))**

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall install, calibrate, maintain and operate continuous emission monitoring systems for sulfur dioxide, nitrogen oxides, and carbon dioxide, and a continuous opacity monitoring system of the exhaust gases in accordance with the Emission and Fuel Monitoring section of 40 CFR Part 60, Subpart D.² **(40 CFR Part 60, Subpart D, 40 CFR 60.45)**
2. The permittee shall maintain the following records on a monthly basis:² **(R 336.1201(3))**
 - a. Heating value of oil fuels, as fired, expressed in BTU per pound
 - b. Heat input to EUBOILER1 from natural gas, expressed in MMBTU per hour
 - c. Heat input to EUBOILER1 from oil fuels, expressed in MMBTU per hour
 - d. Sulfur content of oil fuels, expressed as a percentage by weight
 - e. Total operating hours of EUBOILER1
 - f. Quantity of used oil burned of EUBOILER1

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

3. The permittee shall not operate EUBOILER1 unless the monitoring and recordkeeping provisions of the approved facility Quality Control Program for Burning Specification Used Oil are implemented and maintained.² **(R 336.1201(3))**
4. The permittee shall maintain, in a satisfactory manner, maintenance records for EUBOILER1. The permittee shall keep all records on file and make them available to the Department upon request. **(R 336.1213(3))**

See Appendix 3-1

VII. REPORTING

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
4. The permittee shall submit any performance test reports to the AQD Technical Programs Unit and District Office, in a format approved by the AQD. **(R 336.1213(3)(c), R 336.2001(5))**
5. Quarterly reporting of emissions and operating information. Due 30 calendar days following the end of the quarter in which the data were collected. Compliance with this requirement shall be considered compliance with the reporting requirement specified in 40 CFR Part 60, Subpart D.² **(R 336.2170, 40 CFR 60.45(g) and (h))**
6. The permittee shall report sulfur dioxide, nitrogen oxide and carbon dioxide emission, volumetric flow, and opacity data in accordance with 40 CFR Part 75 (Continuous Emission Monitoring).² **(R 336.1201(3))**
7. For the continuous monitoring system for the measurement of opacity, the permittee shall submit to the District Supervisor and Compliance Support Unit Supervisor, Air Quality Division and to the Chief of the Air Compliance Branch, U.S. Environmental Protection Agency, within 30 days of the end of the calendar quarter, a written report for each calendar quarter which shall include all of the following information.² **(R 336.2170(1)(a), (b), and (c), Title I (Air Pollution Prevention and Control), Clean Air Act, Section 114(a))**
 - a. Excess emissions, corrective action taken and the nature and cause of excess emissions, if known, as follows: For opacity measurements, the report shall consist of the magnitude, in actual percent opacity, of all six-minute averages of opacity more than the applicable opacity standard for each hour of operation (all allowable exceptions are to be deducted prior to determining the excess averages of opacity). Average values shall be obtained by integration over the averaging period of by arithmetically averaging a minimum of 24 equally spaced, instantaneous opacity measurements per six minutes.
 - b. The date and time identifying each period during which the continuous monitoring system was inoperative, except for zero and span checks, and the nature of repairs or adjustments made.
 - c. If the monitoring system has not been inoperative, repaired, or adjusted, and if no excess emissions occurred, a statement attesting to this fact.
8. The permittee shall submit to the Chief of the Air Compliance Branch, U.S. Environmental Protection Agency and the District Supervisor of the Air Quality Division, within 30 days of the end of the calendar quarter, a written report for each calendar quarter which shall include sulfur dioxide monthly emission rate averages.² **(R 336.1201(3), Title I (Air Pollution Prevention and Control) of the Clean Air Act, Section 114(a))**

See Appendix 8-1

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

VIII. STACK/VENT RESTRICTION(S)

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Diameter / Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SV001	279 ²	496 ²	R 336.1201(3)

IX. OTHER REQUIREMENT(S)

1. The permittee shall comply with all provisions of the federal Standards of Performance for New Stationary Sources as specified in 40 CFR Part 60, Subparts A and D. **(40 CFR Part 60, Subparts A and D)**
2. The permittee shall comply with the acid rain permitting provisions of 40 CFR 72.1 to 72.94, as outlined in a complete Phase II, Acid Rain Permit issued by the AQD. Phase II, Acid Rain Permit No. MI-AR-6035-2024 is hereby incorporated into this ROP as Appendix 9. **(R 336.1902(1)(p))**
3. The permittee shall not allow the emission of an air pollutant to exceed the amount of any emission allowances that an affected source lawfully holds as of the allowance transfer deadline pursuant to R 336.1902(1)(p) and 40 CFR 72.9(c)(1)(i). **(R 336.1213(10))**
4. The permittee shall comply with the provisions of the Cross-State Air Pollution Rule NO_x Annual Trading Program, as specified in 40 CFR Part 97, Subpart AAAAA, and identified in Appendix 10-1. **(40 CFR Part 97, Subpart AAAAA)**
5. The permittee shall comply with the provisions of the Cross-State Air Pollution Rule NO_x Ozone Season Group 3 Trading program, as specified in 40 CFR Part 97, Subpart GGGGG, and identified in Appendix 10-1. **(40 CFR Part 97, Subpart GGGGG)**
6. The permittee shall comply with the provisions of the Cross-State Air Pollution Rule SO₂ Group 1 Trading Program, as specified in 40 CFR Part 97, Subpart CCCCC, and identified in Appendix 10-1. **(40 CFR Part 97, Subpart CCCCC)**

Footnotes:

¹ This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

² This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

**EUEASTAUXBOILER
EMISSION UNIT CONDITIONS**

DESCRIPTION

East auxiliary boiler nominally rated at 181.4 MMBTU per hour heat input, equipped with a continuous oxygen trim system and fired only with pipeline quality natural gas. Maximum steam output is 150,000 pounds per hour.

Flexible Group ID: FGEASTAUXBOILER-MACT

POLLUTION CONTROL EQUIPMENT

NA

I. EMISSION LIMIT(S)

Pollutant	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. Nitrogen oxides (NOx)	0.90 lb/MMBTU heat input ²	Hourly	EUEASTAUXBOILER	SC V.1	R 336.1201(3)
2. Nitrogen oxides (NOx)	202.5 lbs. per hour ²	Hourly	EUEASTAUXBOILER	SC V.1	R 336.1201(3)
3. Visible Emissions	20% opacity average per 6-minute period except for one 6-minute period per hour of not more than 27% opacity ²	Six-minute average	EUEASTAUXBOILER	SC VI.1	R 336.1301(1)(a)

II. MATERIAL LIMIT(S)

1. The permittee shall burn only pipeline quality natural gas in EUEASTAUXBOILER.² (**R 336.1205(1)(a)**)

III. PROCESS/OPERATIONAL RESTRICTION(S)

1. The permittee shall submit within 90 days of permit issuance, and implement and maintain, a malfunction abatement plan (MAP) as described in Rule 911(2), for EUEASTAUXBOILER. The MAP shall, at a minimum, specify the following:
 - a. A complete preventative maintenance program including identification of the supervisory personnel responsible for overseeing the inspection, maintenance, and repair of air-cleaning devices, a description of the items or conditions that shall be inspected, the frequency of the inspections or repairs, and an identification of the major replacement parts that shall be maintained in inventory for quick replacement.
 - b. An identification of the source and air-cleaning device operating variables that shall be monitored to detect a malfunction or failure, the normal operating range of these variables, and a description of the method of monitoring or surveillance procedures.
 - c. A description of the corrective procedures or operational changes that shall be taken in the event of a malfunction or failure to achieve compliance with the applicable emission limits.

If at any time the MAP fails to address or inadequately addresses an event that meets the characteristics of a malfunction, the permittee shall amend the MAP within 45 days after such an event occurs. The permittee shall

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

also amend the MAP within 45 days, if new equipment is installed or upon request from the District Supervisor. The permittee shall submit the MAP and any amendments to the MAP to the AQD District Supervisor for review and approval. If the AQD does not notify the permittee within 90 days of submittal, the MAP or amended MAP shall be considered approved. Until an amended plan is approved, the permittee shall implement corrective procedures or operational changes to achieve compliance with all applicable emission limits. **(R 336.1911, R 336.1912(6))**

IV. DESIGN/EQUIPMENT PARAMETER(S)

1. The permittee shall install, calibrate, maintain and operate in a manner satisfactory to the District Supervisor, a device to monitor and record the natural gas usage in EUEASTAUXBOILER on a continuous basis.² **(R 336.1201(3))**

V. TESTING/SAMPLING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall verify the NOx emission rates from EUEASTAUXBOILER, by testing at owner's expense, in accordance with Department requirements. Testing shall be performed using an approved USEPA Method listed in:

Pollutant	Test Method Reference
NOx	40 CFR Part 60, Appendix A

An alternate method, or a modification to the approved EPA Method, may be specified in an AQD approved Test Protocol and must meet the requirements of the federal Clean Air Act, all applicable state and federal rules and regulations, and be within the authority of the AQD to make the change. No less than 30 days prior to testing, the permittee shall submit a complete test plan to the AQD Technical Programs Unit and District Office. The AQD must approve the final plan prior to testing, including any modifications to the method in the test protocol that are proposed after initial submittal. The permittee must submit a complete report of the test results to the AQD Technical Programs Unit and District Office within 60 days following the last date of the test. **(R 336.1213(3), R 336.2001, R 336.2003, R 336.2004)**

2. Within 180 days after permit issuance, the permittee shall verify the NOx emission rates from EUEASTAUXBOILER at a minimum, every five years from the date of the last test thereafter. **(R 336.1213(3), R 336.2001, R 336.2003, R 336.2004)**
3. The permittee shall notify the AQD Technical Programs Unit Supervisor and the District Supervisor not less than 30 days before testing of the time and place performance tests will be conducted. **(R 336.1213(3))**

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall verify the presence of visible emissions by taking six-minute visible emission readings for EUEASTAUXBOILER pursuant to the schedule outlined in Appendix 3-1.4. The VE reader shall take each visible emission reading during routine operating conditions. Multiple stacks may be observed simultaneously. If visible emissions are present, the procedures outlined in Appendix 3-1.4 shall be implemented and the permittee shall maintain a written record of the corrective actions taken. The permittee may monitor visible emissions for EUEASTAUXBOILER from SV001-025 in a satisfactory manner.² **(R 336.1301, R 336.1303)**
2. The permittee shall keep, in a satisfactory manner, records of all visible emission readings for EUEASTAUXBOILER. At a minimum, records shall include the date, time, name of observer/reader, whether the reader is certified, and status of visible emissions. The permittee shall keep all records on file at the facility and make them available to the Department upon request.² **(R 336.1301, R 336.1303)**
3. The permittee shall maintain the following records on a monthly basis:² **(R 336.1201(3))**
 - a. Hours of operation of EUEASTAUXBOILER.

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

- b. Total volume of natural gas consumed in EUEASTAUXBOILER.
 - c. Heat input EUEASTAUXBOILER expressed in MMBTU.
4. The permittee shall maintain, in a satisfactory manner, maintenance records for EUEASTAUXBOILER. The permittee shall keep all records on file and make them available to the Department upon request. **(R 336.1213(3))**

See Appendix 3-1

VII. REPORTING

- 1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
- 2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
- 3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
- 4. The permittee shall submit any performance test reports to the AQD Technical Programs Unit and District Office, in a format approved by the AQD. **(R 336.1213(3)(c), R 336.2001(5))**

See Appendix 8-1

VIII. STACK/VENT RESTRICTION(S)

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Diameter / Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SV0001-025	144 ²	220 ²	R 336.1201(3)

IX. OTHER REQUIREMENT(S)

- 1. The permittee shall comply with all provisions of the National Emission Standards for Hazardous Air Pollutants as specified in 40 CFR Part 63, Subparts A and DDDDD, as they apply to EUEASTAUXBOILER.² **(40 CFR Part 63, Subparts A and DDDDD)**

Footnotes:

¹ This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

² This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

EUGDF EMISSION UNIT CONDITIONS

DESCRIPTION

A new (placed into operation on or after July 1, 1979) gasoline underground storage tank of 2,500-gallon capacity (9.46 cubic meters) for gasoline dispensing at the facility. This emission unit is exempt from the requirements of R 336.1201 per R 336.1284(2)(g)(ii).

Flexible Group ID: NA

POLLUTION CONTROL EQUIPMENT

Vapor balance system

I. EMISSION LIMIT(S)

NA

II. MATERIAL LIMIT(S)

NA

III. PROCESS/OPERATIONAL RESTRICTION(S)

NA

IV. DESIGN/EQUIPMENT PARAMETER(S)

1. EUGDF shall be equipped with a permanent submerged fill pipe. **(R 336.1703(1))**
2. EUGDF shall be controlled by a vapor balance system or an equivalent control system approved by the department. The vapor balance system shall capture displaced gasoline vapor and air via a vapor tight collection line and shall be designed to return not less than 90% by weight of the displaced gasoline vapor from the stationary vessel to the delivery vessel. **(R 336.1703(2))**
3. EUGDF shall be equipped, maintained, or controlled with both of the following: **(R 336.1703(3))**
 - a. An interlocking system or procedure to ensure that the vapor tight collection line is connected before any gasoline can be loaded.
 - b. A device to ensure that the vapor tight collection line shall close upon disconnection so as to prevent release of gasoline vapor.

V. TESTING/SAMPLING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

NA

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall keep a copy of the manufacturer's installation, operating, maintenance instructions, and emission-related specifications throughout the life of EUGDF. **(R 336.1213(3)(b)(ii))**

VII. REPORTING

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**

See Appendix 8-1

VIII. STACK/VENT RESTRICTION(S)

NA

IX. OTHER REQUIREMENT(S)

NA

**EUEMGFIREPUMP
EMISSION UNIT CONDITIONS**

DESCRIPTION

This engine is a turbo-charged, air-cooled, 4-cycle, and in-line 6-cylinder diesel compression ignition engine with 8.9-liter total cylinder displacement. Maximum heat input of 1.98 MMBTU/hr. The engine nameplate rates the engine output at 260 HP at 1760 RPM. This engine is subject to 40 CFR Part 60, Subpart IIII and 40 CFR Part 63, Subpart ZZZZ. Per 40 CFR 63.6590(c), this fire pump engine must meet the requirements of 40 CFR Part 63, Subpart ZZZZ by meeting the requirements of 40 CFR Part 60, Subpart IIII. The fire pump engine is exempt from R 336.1201 per R 336.1285(2)(g).

Flexible Group ID: NA

POLLUTION CONTROL EQUIPMENT

NA

I. EMISSION LIMIT(S)

Pollutant	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. NMHC + NOx	4.0 g/KW-hr. or 3.0 g/HP-hr	Hourly	EUEMGFIREPUMP	SC V.1 SC VI.3	40 CFR 60.4205(c), Table 4 of 40 CFR 60, Subpart IIII
2. CO	3.5 g/KW-hr or 2.6 g/HP-hr	Hourly	EUEMGFIREPUMP	SC V.1 SC VI.3	40 CFR 60.4205(c), Table 4 of 40 CFR 60, Subpart IIII
3. PM	0.20 g/KW-hr. or 0.15 g/HP-hr	Hourly	EUEMGFIREPUMP	SC V.1 SC VI.3	40 CFR 60.4205(c), Table 4 of 40 CFR 60, Subpart IIII

II. MATERIAL LIMIT(S)

1. The permittee shall burn only diesel fuel with the maximum sulfur content of 15 ppm (0.0015 percent) by weight, and either minimum cetane index of 40 or maximum aromatic content of 35 volume percent. **(40 CFR 60.4207(b), 40 CFR 1090.305)**

III. PROCESS/OPERATIONAL RESTRICTION(S)

1. The permittee must meet the following requirements for EUEMGFIREPUMP: **(40 CFR 60.4211(c))**
 - a. Operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer’s emission-related written instructions, **(40 CFR 60.4211(a)(1))**
 - b. Change only those emission-related settings that are permitted by the manufacturer, and **(40 CFR 60.4211(a)(2))**
 - c. Meet the requirements as specified in 40 CFR Part 1068, as they apply. **(40 CFR 60.4211(a)(3))**
2. If the permittee does not install, configure, operate, and maintain each engine and control device according to the manufacturer’s emission-related written instructions, or changes emission-related settings in a way that is not permitted by the manufacturer, the permittee must keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain and operate EUEMGFIREPUMP in a manner consistent with good air pollution control practice for minimizing emissions. **(40 CFR 60.4211(g))**

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

3. EUEMGFIREPUMP may be operated up to 100 hours per calendar year for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, or the insurance company associated with the engine. The permittee may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of EUEMGFIREPUMP beyond 100 hours per calendar year. **(40 CFR 60.4211(f)(2)(i))**
4. EUEMGFIREPUMP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing provided in SC III.3. **(40 CFR 60.4211(f)(3))**

IV. DESIGN/EQUIPMENT PARAMETER(S)

1. The permittee must install a non-resettable hour meter, to track the operating hours. **(40 CFR 60.4209(a))**

V. TESTING/SAMPLING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. If EUEMGFIREPUMP is not installed, configured, operated, and maintained according to the manufacturer's emission-related written instructions, or the permittee changes emission-related settings in a way that is not permitted by the manufacturer, the permittee must demonstrate compliance as follows:
 - a. Conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of startup, or within 1 year after an engine and control device is no longer installed, configured, operated, and maintained in accordance with the manufacturer's emission-related written instructions, or within 1 year after changing emission-related settings in a way that is not permitted by the manufacturer.
 - b. If a performance test is required, the performance tests shall be conducted according to 40 CFR 60.4212.

No less than 30 days prior to testing, a complete test plan shall be submitted to the AQD. The permittee must submit a complete report of the test results to the AQD Technical Programs Unit and District Office within 60 days following the last date of the test. **(R 336.1213(3), R 336.2001, R 336.2003, R 336.2004, 40 CFR 60.4211(g), 40 CFR 60.4212)**

2. The permittee shall notify the AQD Technical Programs Unit Supervisor and the District Supervisor not less than 30 days before testing of the time and place performance tests will be conducted. **(R 336.1213(3))**

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee must keep records, on a monthly basis, of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The permittee must record the time of operation of the engine and the reason the engine was in operation during that time. **(40 CFR 60.4214(b))**
2. The permittee shall maintain, in a satisfactory manner, fuel supplier certification records or fuel sample test data, for diesel fuel oil used in EUEMGFIREPUMP, demonstrating that the fuel meets the requirement of 40 CFR 1090.305. The certification or test data shall include the name of the oil supplier or laboratory, the sulfur content, and cetane index or aromatic content of the fuel oil. **(R 336.1213(3), 40 CFR 60.4207(b), 40 CFR 1090.305)**
3. The permittee shall keep, in a satisfactory manner, the following records indicating that EUEMGFIREPUMP meets the applicable emission limitations contained in SC I.1 through I.3: **(40 CFR 60.4211(g)(2))**
 - a. If the certified engine is being operated in a certified manner, the permittee shall keep manufacturer certification documentation and records of conducted maintenance.
 - b. If the certified engine is operated in a non-certified manner, the permittee shall keep a maintenance plan, records of conducted maintenance, and the records of testing required in SC V.1.

VII. REPORTING

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
4. The permittee shall submit any performance test reports to the AQD Technical Programs Unit and District Office, in a format approved by the AQD. **(R 336.1213(3)(c), R 336.2001(5))**
5. The permittee shall submit a notification specifying whether EUEMGFIREPUMP will be operated in a certified or a non-certified manner to the AQD District Supervisor, in writing, within 30 days of switching the manner of operation. **(R 336.1213(3))**

See Appendix 8-1

VIII. STACK/VENT RESTRICTION(S)

NA

IX. OTHER REQUIREMENT(S)

1. The permittee shall comply with the provisions of the federal Standards of Performance for New Stationary Sources as specified in 40 CFR Part 60, Subpart A and Subpart IIII, as they apply to EUEMGFIREPUMP. **(40 CFR Part 60, Subparts A and IIII)**
2. The permittee shall comply with all applicable requirements of the National Emission Standards for Hazardous Air Pollutants, as specified in 40 CFR Part 63, Subpart A and Subpart ZZZZ for Stationary Reciprocating Internal Combustion Engines. **(40 CFR 63.6590(c)(7), 40 CFR Part 63, Subparts A and ZZZZ)**

D. FLEXIBLE GROUP SPECIAL CONDITIONS

Part D outlines the terms and conditions that apply to more than one emission unit. The permittee is subject to the special conditions for each flexible group in addition to the General Conditions in Part A and any other terms and conditions contained in this ROP.

The permittee shall comply with all specific details in the special conditions and the underlying applicable requirements cited. If a specific condition type does not apply, NA (not applicable) has been used in the table. If there are no special conditions that apply to more than one emission unit, this section will be left blank.

FLEXIBLE GROUP SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Flexible Group ID	Flexible Group Description	Associated Emission Unit IDs
FGEASTAUXBOILER-MACT	Requirements for an existing boiler (equipped with a continuous oxygen trim system) designed to burn gas 1 subcategory fuel with a heat input capacity of 10 MMBTU/hr or greater at major sources of HAP emissions per 40 CFR Part 63, Subpart DDDDD (Boiler MACT). Units designed to burn gas 1 subcategory fuels include boilers or process heaters that burn only natural gas, refinery gas, and/or Other Gas 1 fuels. Units that burn liquid fuel for testing or maintenance purposes for less than a total of 48 hours per year, or that burn liquid fuel during periods of curtailment or supply interruptions are included in this definition.	EUEASTAUXBOILER
FGCOLDCLEANERS	Any cold cleaner that is grandfathered or exempt from Rule 201 pursuant to Rule 278, Rule 278a and Rule 281(2)(h) or Rule 285(2)(r)(iv). Existing cold cleaners were placed into operation prior to July 1, 1979. New cold cleaners were placed into operation on or after July 1, 1979.	EUCOLDCLEANER1 EUCOLDCLEANER2

FGEASTAUXBOILER-MACT FLEXIBLE GROUP CONDITIONS

DESCRIPTION

Requirements for an existing boiler (equipped with a continuous oxygen trim system) designed to burn gas 1 subcategory fuel with a heat input capacity of 10 MMBTU/hr or greater at major sources of HAP emissions per 40 CFR Part 63, Subpart DDDDD (Boiler MACT). Units designed to burn gas 1 subcategory fuels include boilers or process heaters that burn only natural gas, refinery gas, and/or Other Gas 1 fuels. Units that burn liquid fuel for testing or maintenance purposes for less than a total of 48 hours per year, or that burn liquid fuel during periods of curtailment or supply interruptions are included in this definition.

Emission Unit: EUEASTAUXBOILER

POLLUTION CONTROL EQUIPMENT

NA

I. EMISSION LIMIT(S)

NA

II. MATERIAL LIMIT(S)

NA

III. PROCESS/OPERATIONAL RESTRICTION(S)

1. The permittee shall conduct a tune up of each boiler or process heater as specified below. **(40 CFR 63.7500(a)(1), 40 CFR 63.7515(d), Table 3 of 40 CFR Part 63, Subpart DDDDD)**
 - a. As applicable, inspect the burner, and clean or replace any components of the burner as necessary. The permittee may perform the burner inspection any time prior to the tune-up or delay the burner inspection until the next scheduled unit shutdown. Units that produce electricity for sale may delay the burner inspection until the first outage, not to exceed 36 months from the previous inspection. At units where entry into a piece of process equipment or into a storage vessel is required to complete the tune-up inspections, inspections are required only during planned entries into the storage vessel or process equipment. **(40 CFR 63.7540(a)(10)(i))**
 - b. Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern. The adjustment should be consistent with the manufacturer's specifications, if available. **(40 CFR 63.7540(a)(10)(ii))**
 - c. Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure that it is correctly calibrated and functioning properly (the permittee may delay the inspection until the next scheduled unit shutdown). Units that produce electricity for sale may delay the inspection until the first outage, not to exceed 36 months from the previous inspection. **(40 CFR 63.7540(a)(10)(iii))**
 - d. Optimize total emissions of CO. This optimization should be consistent with the manufacturer's specifications, if available, and with any NO_x requirement to which the unit is subject. **(40 CFR 63.7540(a)(10)(iv))**

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

- e. Measure the concentrations in the effluent stream of CO in parts per million, by volume, and oxygen in volume percent, before and after the adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made). Measurements may be taken using a portable CO analyzer. **(40 CFR 63.7540(a)(10)(v))**
2. If the unit is not operated on the required date for the tune-up, the tune-up must be conducted within 30 calendar days of startup. **(40 CFR 63.7540(a)(13))**
3. The permittee shall conduct a tune-up of each emission unit that has an oxygen trim system installed in FGEASTAUXBOILER-MACT of the burner(s) and combustion controls, as applicable, every 5 years as specified in 40 CFR 63.7540(a)(10)(i) through (vi). **(40 CFR 63.7500(d), 40 CFR 63.7540(a)(12), Table 3 of 40 CFR Part 63, Subpart DDDDD)**
 - a. Each 5-year tune-up must be conducted no more than 61 months after the previous tune-up. **(40 CFR 63.7515(d))**
 - b. The permittee may delay the burner inspection until the next scheduled or unscheduled unit shutdown, but each burner must be inspected at least once every 72 months. **(40 CFR 63.7540(a)(12))**
 - c. If the unit is not operating on the required date for the tune-up, the tune-up must be conducted within 30 calendar days of startup. **(40 CFR 63.7540(a)(13))**
4. At all times, the permittee must operate and maintain each existing gas 1 boiler or process heater, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator that may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source. **(40 CFR 63.7500(a)(3))**

IV. DESIGN/EQUIPMENT PARAMETER(S)

NA

V. TESTING/SAMPLING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

NA

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee must keep a copy of each notification and report that the permittee submitted to comply with 40 CFR Part 63, Subpart DDDDD, including all documentation supporting any Initial Notification or Notification of Compliance Status or annual compliance report that the permittee submitted. **(40 CFR 63.7555(a)(1))**
2. If the permittee uses an alternative fuel other than natural gas, refinery gas, gaseous fuel subject to another subpart under 40 CFR Part 63, Other Gas 1 fuel, or gaseous fuel subject to another subpart of 40 CFR Part 60 or Part 61, or Part 65, the permittee must keep records of the total hours per calendar year that alternative fuel is burned and the total hours per calendar year that the unit operated during periods of gas curtailment or gas supply emergencies. **(40 CFR 63.7555(h))**
3. The permittee shall maintain on-site and submit, if requested by the AQD, an annual tune-up report containing the information listed below.
 - a. The concentrations of CO in the effluent stream in parts per million by volume, and oxygen in volume percent, measured at high fire or typical operating load, before and after the tune-up of the boiler or process heater. **(40 CFR 63.7540(a)(10)(vi)(A))**

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

- b. A description of any corrective actions taken as a part of the tune-up. **(40 CFR 63.7540(a)(10)(vi)(B))**
- c. The type and amount of fuel used over the 12 months prior to the tune-up, but only if the unit was physically and legally capable of using more than one type of fuel during that period. Units sharing a fuel meter may estimate the fuel used by each unit. **(40 CFR 63.7540(a)(10)(vi)(C))**
4. The permittee's records must be in a form suitable and readily available for expeditious review, according to 40 CFR 63.10(b)(1). **(40 CFR 63.7560(a))**
5. As specified in 40 CFR 63.10(b)(1), the permittee must keep each record for 5-years following the date of each occurrence, measurement, maintenance, corrective action, report, or record. **(40 CFR 63.7560(b))**
6. The permittee must keep each record on site, or they must be accessible from on-site (for example, through a computer network), for at least 2-years after the date of each occurrence, measurement, maintenance, corrective action, report, or record. The permittee can keep the records off site for the remaining 3-years. **(40 CFR 63.7560(c))**

VII. REPORTING

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
4. If the permittee intends to use a fuel other than natural gas, refinery gas, gaseous fuel subject to another subpart of 40 CFR Part 63, Part 60, Part 61, or Part 65, or Other Gas 1 fuel to fire the affected unit during a period of natural gas curtailment or supply interruption, as defined in 40 CFR 63.7575, the permittee must submit a notification of alternative fuel use within 48 hours of the declaration of each period of natural gas curtailment or supply interruption, as defined in 40 CFR 63.7575. The notification must include the information as listed below.
 - a. Company name and address. **(40 CFR 63.7545(f)(1))**
 - b. Identification of the affected unit. **(40 CFR 63.7545(f)(2))**
 - c. Reason the permittee is unable to use natural gas or equivalent fuel, including the date when the natural gas curtailment was declared, or the natural gas supply interruption began. **(40 CFR 63.7545(f)(3))**
 - d. Type of alternative fuel that the permittee intends to use. **(40 CFR 63.7545(f)(4))**
 - e. Dates when the alternative fuel use is expected to begin and end. **(40 CFR 63.7545(f)(5))**
5. The permittee must submit boiler and process heater tune-up compliance reports to the appropriate AQD District Office. The reports must be postmarked or submitted by March 15 and must cover the period of January 1 through December 31 of the reporting year. For new units, the first report should cover the period of startup to December 31 of the reporting year. Compliance reports must also be submitted to EPA using the Compliance and Emissions Data Reporting Interface (CEDRI) which is accessed through EPA's Central Data Exchange (CDX) (www.epa.gov/cdx). **(40 CFR 63.7550(b))**
6. The permittee must submit a compliance report containing the following information.
 - a. Company and Facility name and address. **(40 CFR 63.7550(c)(5)(i))**
 - b. Process unit information, emissions limitations, and operating parameter limitations. **(40 CFR 63.7550(c)(5)(ii))**
 - c. Date of report and beginning and ending dates of the reporting period. **(40 CFR 63.7550(c)(5)(iii))**

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

- d. Include the date of the most recent tune-up for each unit. Include the date of the most recent burner inspection if it was not done annually and was delayed until the next scheduled or unscheduled unit shutdown. **(40 CFR 63.7550(c)(5)(xiv))**
 - e. Statement by a responsible official with that official's name, title, and signature, certifying the truth, accuracy, and completeness of the content of the report. **(40 CFR 63.7550(c)(5)(xvii))**
7. The permittee must submit all reports required by Table 9 of this subpart electronically using CEDRI that is accessed through the EPA's Central Data Exchange (CDX) (www.epa.gov/cdx). However, if the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, submit the report to the EPA Region V at the appropriate address listed in 40 CFR 63.13 and to the appropriate AQD District Office. **(40 CFR 63.7550(h)(3))**

See Appendix 8-1

VIII. STACK/VENT RESTRICTION(S)

NA

IX. OTHER REQUIREMENT(S)

1. The permittee shall comply with all applicable provisions of the National Emissions Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters as specified in 40 CFR Part 63, Subparts A and DDDDD. **(40 CFR Part 63, Subparts A and DDDDD)**

FGCOLDCLEANERS FLEXIBLE GROUP CONDITIONS

DESCRIPTION

Any cold cleaner that is grandfathered or exempt from Rule 201 pursuant to Rule 278, Rule 278a and Rule 281(2)(h) or Rule 285(2)(r)(iv). Existing cold cleaners were placed into operation prior to July 1, 1979. New cold cleaners were placed into operation on or after July 1, 1979.

Emission Units: EUCOLDCLEANER1, EUCOLDCLEANER2

POLLUTION CONTROL EQUIPMENT

NA

I. EMISSION LIMIT(S)

NA

II. MATERIAL LIMIT(S)

1. The permittee shall not use cleaning solvents containing more than five percent by weight of the following halogenated compounds: methylene chloride, perchloroethylene, trichloroethylene, 1,1,1-trichloroethane, carbon tetrachloride, chloroform, or any combination thereof. **(R 336.1213(2))**

III. PROCESS/OPERATIONAL RESTRICTION(S)

1. Cleaned parts shall be drained for no less than 15 seconds or until dripping ceases. **(R 336.1611(2)(b), R 336.1707(3)(b))**
2. The permittee shall perform routine maintenance on each cold cleaner as recommended by the manufacturer. **(R 336.1213(3))**

IV. DESIGN/EQUIPMENT PARAMETER(S)

1. The cold cleaner must meet one of the following design requirements:
 - a. The air/vapor interface of the cold cleaner is no more than ten square feet. **(R 336.1281(2)(h))**
 - b. The cold cleaner is used for cleaning metal parts and the emissions are released to the general in-plant environment. **(R 336.1285(2)(r)(iv))**
2. The cold cleaner shall be equipped with a device for draining cleaned parts. **(R 336.1611(2)(b), R 336.1707(3)(b))**
3. All new and existing cold cleaners shall be equipped with a cover and the cover shall be closed whenever parts are not being handled in the cold cleaner. **(R 336.1611(2)(a), R 336.1707(3)(a))**
4. The cover of a new cold cleaner shall be mechanically assisted if the Reid vapor pressure of the solvent is more than 0.3 psia or if the solvent is agitated or heated. **(R 336.1707(3)(a))**
5. If the Reid vapor pressure of any solvent used in a new cold cleaner is greater than 0.6 psia; or, if any solvent used in a new cold cleaner is heated above 120 degrees Fahrenheit, then the cold cleaner must comply with at least one of the following provisions:

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

- a. The cold cleaner must be designed such that the ratio of the freeboard height to the width of the cleaner is equal to or greater than 0.7. **(R 336.1707(2)(a))**
- b. The solvent bath must be covered with water if the solvent is insoluble and has a specific gravity of more than 1.0. **(R 336.1707(2)(b))**
- c. The cold cleaner must be controlled by a carbon adsorption system, condensation system, or other method of equivalent control approved by the AQD. **(R 336.1707(2)(c))**

V. TESTING/SAMPLING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

NA

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. For each new cold cleaner in which the solvent is heated, the solvent temperature shall be monitored and recorded at least once each calendar week during routine operating conditions. **(R 336.1213(3))**
2. The permittee shall maintain the following information on file for each cold cleaner: **(R 336.1213(3))**
 - a. A serial number, model number, or other unique identifier for each cold cleaner.
 - b. The date the unit was installed, manufactured or that it commenced operation.
 - c. The air/vapor interface area for any unit claimed to be exempt under Rule 281(2)(h).
 - d. The applicable Rule 201 exemption.
 - e. The Reid vapor pressure of each solvent used.
 - f. If applicable, the option chosen to comply with Rule 707(2).
3. The permittee shall maintain a current listing from the manufacturer of the chemical composition of each material, including the weight percent of each component, used in each cold cleaner. The data may consist of Safety Data Sheets, manufacturer's formulation data, or both as deemed acceptable by the AQD District Supervisor. The permittee shall keep all records on file and make them available to the Department upon request. **(R 336.1213(3))**
4. The permittee shall maintain written operating procedures for each cold cleaner. These written procedures shall be posted in an accessible, conspicuous location near each cold cleaner. **(R 336.1611(3), R 336.1707(4))**
5. As noted in Rule 611(2)(c) and Rule 707(3)(c), if applicable, an initial demonstration that the waste solvent is a safety hazard shall be made prior to storage in non-closed containers. If the waste solvent is a safety hazard and is stored in non-closed containers, verification that the waste solvent is disposed of so that not more than 20 percent, by weight, is allowed to evaporate into the atmosphere shall be made on a monthly basis. **(R 336.1213(3), R 336.1611(2)(c), R 336.1707(3)(c))**

VII. REPORTING

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

See Appendix 8-1

VIII. STACK/VENT RESTRICTION(S)

NA

IX. OTHER REQUIREMENT(S)

NA

E. NON-APPLICABLE REQUIREMENTS

At the time of the ROP issuance, the AQD has determined that the requirements identified in the table below are not applicable to the specified emission unit(s) and/or flexible group(s). This determination is incorporated into the permit shield provisions set forth in the General Conditions in Part A pursuant to Rule 213(6)(a)(ii). If the permittee makes a change that affects the basis of the non-applicability determination, the permit shield established as a result of that non-applicability decision is no longer valid for that emission unit or flexible group.

Emission Unit/Flexible Group ID	Non-Applicable Requirement	Justification
EUBOILER1	National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters promulgated in 40 CFR Part 63, Subpart DDDDD, and the National Emission Standards for Hazardous Air Pollutants: Coal- and Oil-Fired Electric Utility Steam Generating Units promulgated in 40 CFR Part 63, Subpart UUUUU.	EPA reviewed the applicability determination request submitted on August 22, 2023 by DTE and determined that the electric generating unit (EGU) identified as EUBOILER1 is not subject to 40 CFR Part 63, Subpart DDDDD as well as Subpart UUUUU. While EUBOILER1 is not subject to Subparts DDDDD and UUUUU, given the information provided to EPA, DTE must ensure that EUBOILER1 remains within the definition of a “natural gas-fired electric utility steam generating unit” as defined under 40 CFR 63.10042 of Subpart UUUUU and firing at least 85 percent natural gas on an annual heat input basis.

APPENDICES

Appendix 1-1. Acronyms and Abbreviations

Common Acronyms		Pollutant / Measurement Abbreviations	
AQD	Air Quality Division	acfm	Actual cubic feet per minute
BACT	Best Available Control Technology	BTU	British Thermal Unit
CAA	Clean Air Act	°C	Degrees Celsius
CAM	Compliance Assurance Monitoring	CO	Carbon Monoxide
CEM	Continuous Emission Monitoring	CO ₂ e	Carbon Dioxide Equivalent
CEMS	Continuous Emission Monitoring System	dscf	Dry standard cubic foot
CFR	Code of Federal Regulations	dscm	Dry standard cubic meter
COM	Continuous Opacity Monitoring	°F	Degrees Fahrenheit
Department/ department	Michigan Department of Environment, Great Lakes, and Energy	gr	Grains
EGLE	Michigan Department of Environment, Great Lakes, and Energy	HAP	Hazardous Air Pollutant
EU	Emission Unit	Hg	Mercury
FG	Flexible Group	hr	Hour
GACS	Gallons of Applied Coating Solids	HP	Horsepower
GC	General Condition	H ₂ S	Hydrogen Sulfide
GHGs	Greenhouse Gases	kW	Kilowatt
HVLP	High Volume Low Pressure*	lb	Pound
ID	Identification	m	Meter
IRSL	Initial Risk Screening Level	mg	Milligram
ITSL	Initial Threshold Screening Level	mm	Millimeter
LAER	Lowest Achievable Emission Rate	MM	Million
MACT	Maximum Achievable Control Technology	MW	Megawatts
MAERS	Michigan Air Emissions Reporting System	NMOC	Non-methane Organic Compounds
MAP	Malfunction Abatement Plan	NO _x	Oxides of Nitrogen
MSDS	Material Safety Data Sheet	ng	Nanogram
NA	Not Applicable	PM	Particulate Matter
NAAQS	National Ambient Air Quality Standards	PM10	Particulate Matter equal to or less than 10 microns in diameter
NESHAP	National Emission Standard for Hazardous Air Pollutants	PM2.5	Particulate Matter equal to or less than 2.5 microns in diameter
NSPS	New Source Performance Standards	pph	Pounds per hour
NSR	New Source Review	ppm	Parts per million
PS	Performance Specification	ppmv	Parts per million by volume
PSD	Prevention of Significant Deterioration	ppmw	Parts per million by weight
PTE	Permanent Total Enclosure	%	Percent
PTI	Permit to Install	psia	Pounds per square inch absolute
RACT	Reasonable Available Control Technology	psig	Pounds per square inch gauge
ROP	Renewable Operating Permit	scf	Standard cubic feet
SC	Special Condition	sec	Seconds
SCR	Selective Catalytic Reduction	SO ₂	Sulfur Dioxide
SDS	Safety Data Sheet	TAC	Toxic Air Contaminant
SNCR	Selective Non-Catalytic Reduction	Temp	Temperature
SRN	State Registration Number	THC	Total Hydrocarbons
TEQ	Toxicity Equivalence Quotient	tpy	Tons per year
USEPA/EPA	United States Environmental Protection Agency	µg	Microgram
VE	Visible Emissions	µm	Micrometer or Micron
		VOC	Volatile Organic Compounds
		yr	Year

*For HVLP applicators, the pressure measured at the gun air cap shall not exceed 10 psig.

Appendix 2-1. Schedule of Compliance

The permittee certified in the ROP application that this stationary source is in compliance with all applicable requirements and the permittee shall continue to comply with all terms and conditions of this ROP. A Schedule of Compliance is not required. (R 336.1213(4)(a), R 336.1119(a)(ii))

Appendix 3-1. Monitoring Requirements

The following monitoring procedures, methods, or specifications provide the details for the monitoring requirements identified and referenced in EUBOILER1 and EUEASTAUXBOILER.

3-1.1. Fuel Oil Sulfur Monitoring

For EUBOILER1, the permittee shall maintain a complete record of fuel oil specifications and/or fuel analysis for each delivery, or storage tank, of fuel oil. These records may include purchase records for ASTM specification fuel oil, specifications or analyses provided by the vendor at the time of delivery, analytical results from laboratory testing, or any other records adequate to demonstrate compliance with the percent sulfur limit in fuel oil.

3-1.2. Continuous Emission Rate Monitoring System (CEMS/CERMS)

1. Within 60 days of completion of testing, the permittee shall submit to the AQD two copies of the final report demonstrating the CEMS/CERMS complies with the requirements of the corresponding Performance Specifications (PS) in the following table.

Pollutant	Applicable PS
NOx	2
SO2	2
CO2	3
CERMS	6

2. The span value shall be 2.0 times the lowest emission standard or as specified in the federal regulations.
3. The CEMS/CERMS shall be installed, calibrated, maintained, and operated in accordance with the procedures set forth in 40 CFR 60.13 and PS 6 of Appendix B to 40 CFR Part 60.
4. Each calendar quarter, the permittee shall perform the Quality Assurance Procedures of the CEMS/CERMS set forth in Appendix F of 40 CFR Part 60. Within 30 days following the end of each calendar quarter, the permittee shall submit the results to the AQD in the format of the data assessment report (Figure 1, Appendix F).
5. In accordance with 40 CFR 60.7(c) and (d), the permittee shall submit two copies of an excess emission report (EER) and summary report in an acceptable format to the AQD, within 30 days following the end of each calendar quarter. The Summary Report shall follow the format of Figure 1 in 40 CFR 60.7(d). The EER shall include the following information:
 - a. A report of each exceedance above emission limits. This includes the date, time, magnitude, cause and corrective actions of all occurrences during the reporting period.
 - b. A report of all periods of CEMS/CERMS downtime and corrective action.
 - c. A report of the total operating time of the EUBOILER1 during the reporting period.
 - d. A report of any periods that the CEMS/CERMS exceeds the instrument range.
 - e. If no exceedances or CEMS/CERMS downtime occurred during the reporting period, the permittee shall report that fact.

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

The permittee shall keep all monitoring data on file for a period of at least five years and make them available to the AQD upon request.

3-1.3. Continuous Opacity Monitoring System (COMS) Requirements

1. The span value shall be 2.0 times the lowest emission standard or as specified in the federal regulations.
2. The COMS shall be installed, calibrated, maintained, and operated in accordance with the procedures set forth in 40 CFR 60.13 and PS 1 of Appendix B, 40 CFR Part 60.
3. The permittee shall perform the COMS quality assurance set forth in 40 CFR Part 60, Appendix F, Procedure 3, or a method acceptable to AQD. Within 30 days after the completion of the Procedure 3, the results shall be submitted to the AQD.
4. In accordance with 40 CFR 60.7(c) and (d), the permittee shall submit two copies of an excess emission report (EER) and summary report in an acceptable format to Air Quality Division, within 30 days following the end of each calendar quarter. The Summary Report shall follow the format of Figure 1 in 40 CFR 60.7(d). The EER shall include the following information:
 - a. A report of each exceedance above emission limit . This includes the date, time, magnitude, cause, and corrective actions of all occurrences during the reporting period.
 - b. A report of all periods of COMS downtime and corrective action.
 - c. A report of the total operating time of the EUBOILER1 during the reporting period.
 - d. If no exceedances or COMS downtime occurred during the reporting period, the permittee shall report that fact.

All monitoring data is shall be kept on file for a period of at least five (5) years and made available to the AQD upon request.

3-1.4. Auxiliary Boilers Visible Emission Procedure

The permittee shall perform a non-certified visible emission observation of the Auxiliary Boiler common stack when an Auxiliary Boiler is combusting oil or natural gas according to the following operation schedule:

Number of Operating Hours per Week	Number of Observations per week
0 - 12	0
12 – 36	1
36 – 60	2
60 – 84	3
Etc.	+1, to a maximum of 7

Upon noting visible emissions during the non-certified visible emissions observation specified in EUEASTAUXBOILER SC VI.1, the permittee shall initiate any of the following corrective actions until visible emissions return to permissible limits:

1. Conduct a certified visible emissions observation in compliance with EPA Method 9 -- Visual Determination of the Opacity of Emissions from Stationary Sources (40 CFR Part 60, Appendix A-4) to determine if the six-minute average emissions exceeded the 20 percent opacity limit (except for one, six-minute period of 27 percent once per hour).
2. Inspect auxiliary boiler and operating parameters for possible cause of visible emissions and implement changes (if any).

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

3. Perform another non-certified visible emission observation of the exhaust stack to determine if visible emissions have stopped.

Once the visible emissions have stopped or are shown to be within permissible limits by certified Method 9 reading, then the corrective action situation is complete. If the corrective actions are not sufficient to reduce the visible emissions to permissible levels, the boiler shall be shut down.

Appendix 4-1. Recordkeeping

Specific recordkeeping requirement formats and procedures are detailed in Part A or the appropriate Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Therefore, this appendix is not applicable.

Appendix 5-1. Testing Procedures

There are no specific testing requirement plans or procedures for this ROP. Therefore, this appendix is not applicable.

Appendix 6-1. Permits to Install

The following table lists any PTIs issued or ROP revision applications received since the effective date of the previously issued ROP No. MI-ROP-B6145-2018. Those ROP revision applications that are being issued concurrently with this ROP renewal are identified by an asterisk (*). Those revision applications not listed with an asterisk were processed prior to this renewal.

Source-Wide PTI No MI-PTI-B6145-2018 is being reissued as Source-Wide PTI No. MI-PTI-B6145-2024.

Permit to Install Number	ROP Revision Application Number	Description of Equipment or Change	Corresponding Emission Unit(s) or Flexible Group(s)
NA	NA	NA	NA

Appendix 7-1. Emission Calculations

There are no specific emission calculations to be used for this ROP. Therefore, this appendix is not applicable.

Appendix 8-1. Reporting

A. Annual, Semiannual, and Deviation Certification Reporting

The permittee shall use EGLE, AQD, Report Certification form (EQP 5736) and EGLE, AQD, Deviation Report form (EQP 5737) for the annual, semiannual and deviation certification reporting referenced in the Reporting Section of the Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Alternative formats must meet the provisions of Rule 213(4)(c) and Rule 213(3)(c)(i), respectively, and be approved by the AQD District Supervisor.

B. Other Reporting

Specific reporting requirement formats and procedures are detailed in Part A or the appropriate Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Therefore, Part B of this appendix is not applicable.

Appendix 9-1. Acid Rain Permit

**PHASE II ACID RAIN PERMIT
Permit No. MI-AR-6035-2024**

Permittee	Greenwood Energy Center
Address	7000 Kilgore Road, Avoca, MI
SRN	B6145
Plant Code	6035
Issue Date	June 30, 2024
Effective	Issuance date of this facility's Renewable Operating Permit at the facility in accordance with 40 CFR 72.73.
Expiration	This permit shall expire when the facility's Renewable Operating Permit expires, in accordance with 40 CFR 72.73.
ROP No.	MI-ROP-B6145-2024

The Acid Rain Permit Contents

1. A statement of basis prepared by the Air Quality Division (AQD) containing:

References to statutory and regulatory authorities, and with comments, notes, and justification that apply to the source in general;
2. Terms and conditions including:

A table of sulfur dioxide allowances to be allocated during the term of the permit, if applicable, authorized by this permit during Phase II. Unless they are subject to Sections 405(g)(2) or (3) of the federal Clean Air Act, new units are not allocated allowances in 40 CFR Part 73 and must obtain allowances by other means (Section 403(e) of the federal Clean Air Act);

Comments, notes and justifications regarding permit decisions and changes made to the permit application forms during the review process, and any additional requirements; and,

Any applicable nitrogen oxides compliance plan. Unless they are coal fired utility units regulated pursuant to Sections 404, 405, or 409 of the federal Clean Air Act, new units are not subject to the acid rain nitrogen oxides requirements (40 CFR 76.1(a)).
3. The permit application that this source submitted, as corrected by the AQD. The owners and operators of the source must comply with the standard requirements and special provisions set forth in the application.

Statement of Basis

Statutory and Regulatory Authorities.

In accordance with the Natural Resources and Environmental Protection Act, 1994 PA 451 and Titles IV and V of the federal Clean Air Act, the Michigan Department of Environment, Great Lakes, and Energy, Air Quality Division (AQD), issues this permit pursuant to the provisions of R 336.1210 to R 336.1218, and R 336.1902(1)(q).

For further information contact:

Mr. Brian Carley
Environmental Quality Specialist
Michigan Department of Environment, Great Lakes, and Energy
Air Quality Division, Jackson District Office
State Office Building, 4th Floor
301 East Louis B. Glick Highway
Jackson, Michigan 49201-1556

Telephone: 517-416-4631
Facsimile: 517-780-7855

There are no comments, notes and/or justification that apply to the source in general for this section.

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

Terms and Conditions:

Phase II Sulfur Dioxide Allowance Allocation and Nitrogen Oxides Requirements for each affected unit.

		2024	2025	2026	2027	2028
Unit 1	SO ₂ allowances	541	541	541	541	541

		2024	2025	2026	2027	2028
Unit CTG 11-1	SO ₂ allowances	This affected unit shall hold allowances, as of the allowance transfer deadline, in the source's compliance account (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the affected units at the source; and comply with the applicable Acid Rain emissions limitation for sulfur dioxide in accordance with 40 CFR 72.9 (c).				

		2024	2025	2026	2027	2028
Unit CTG 11-2	SO ₂ allowances	This affected unit shall hold allowances, as of the allowance transfer deadline, in the source's compliance account (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the affected units at the source; and comply with the applicable Acid Rain emissions limitation for sulfur dioxide in accordance with 40 CFR 72.9 (c).				

		2024	2025	2026	2027	2028
Unit CTG 12-1	SO ₂ allowances	This affected unit shall hold allowances, as of the allowance transfer deadline, in the source's compliance account (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the affected units at the source; and comply with the applicable Acid Rain emissions limitation for sulfur dioxide in accordance with 40 CFR 72.9 (c).				

Comments, notes and justifications regarding permit decisions, and changes made to the permit application forms during the review process:

Permit Application: (attached)

Acid Rain Permit Application submitted August 23, 2022

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024



United States
Environmental Protection Agency
Acid Rain Program

OMB No. 2060-0258
Approval Expires 12/31/2021

Acid Rain Permit Application

For more information, see Instructions and 40 CFR 72.30 and 72.31

This submission is: new revised for ARP permit renewal

STEP 1

Identify the facility name, State, and plant (ORIS) code.

DTE Electric – Greenwood Energy Center	MI	6035
Facility (Source) Name		

STEP 2

Enter the unit ID# for every affected unit at the affected source in column "a."

a	b
Unit ID#	Unit Will Hold Allowances in Accordance with 40 CFR 72.9(e)(1)
1	Yes
CTG 11-1	Yes
CTG 11-2	Yes
CTG 12-1	Yes

STEP 3

Read the standard requirements.

Permit Requirements

- (1) The designated representative of each affected source and each affected unit at the source shall:
 - (i) Submit a complete Acid Rain permit application (including a compliance plan) under 40 CFR part 72 in accordance with the deadlines specified in 40 CFR 72.30; and
 - (ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary in order to review an Acid Rain permit application and issue or deny an Acid Rain permit;
- (2) The owners and operators of each affected source and each affected unit at the source shall:
 - (i) Operate the unit in compliance with a complete Acid Rain permit application or a superseding Acid Rain permit issued by the permitting authority; and
 - (ii) Have an Acid Rain Permit.

Monitoring Requirements

- (1) The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the source or unit, as appropriate, with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

Sulfur Dioxide Requirements

- (1) The owners and operators of each source and each affected unit at the source shall:
 - (i) Hold allowances, as of the allowance transfer deadline, in the source's compliance account (after deductions under 40 CFR 73.34(c)), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the affected units at the source; and
 - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An affected unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
 - (i) Starting January 1, 2000, an affected unit under 40 CFR 72.6(a)(2); or

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

DTE Electric – Greenwood Energy Center Facility (Source) Name (from STEP 1)	Acid Rain Permit – Page 2 of 3
---------------------------------------------------------------------------------------	--------------------------------

- (ii) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements

The owners and operators of the source and each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements

- (1) The designated representative of an affected source that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77.
- (2) The owners and operators of an affected source that has excess emissions in any calendar year shall:
 - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR part 77; and
 - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77.

Recordkeeping and Reporting Requirements

- (1) Unless otherwise provided, the owners and operators of the source and each affected unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the Administrator or permitting authority:
 - (i) The certificate of representation for the designated representative for the source and each affected unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
 - (ii) All emissions monitoring information, in accordance with 40 CFR part 75, provided that to the extent that 40 CFR part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply.
 - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,
 - (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.
- (2) The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR part 72 subpart I and 40 CFR part 75.

Liability

- (1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
- (2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
- (3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
- (4) Each affected source and each affected unit shall meet the requirements of the Acid Rain Program.

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024
 Expiration Date: June 30, 2029
 PTI No: MI-PTI-B6145-2024

DTE Electric – Greenwood Energy Center Facility (Source) Name (from STEP 1)	Acid Rain Permit – Page 3 of 3
---------------------------------------------------------------------------------------	--------------------------------

- (5) Any provision of the Acid Rain Program that applies to an affected source (including a provision applicable to the designated representative of an affected source) shall also apply to the owners and operators of such source and of the affected units at the source.
- (6) Any provision of the Acid Rain Program that applies to an affected unit (including a provision applicable to the designated representative of an affected unit) shall also apply to the owners and operators of such unit.
- (7) Each violation of a provision of 40 CFR parts 72, 73, 74, 75, 76, 77, and 78 by an affected source or affected unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities

No provision of the Acid Rain Program, an Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 shall be construed as:

- (1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an affected source or affected unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;
- (2) Limiting the number of allowances a source can hold; provided, that the number of allowances held by the source shall not affect the source's obligation to comply with any other provisions of the Act;
- (3) Requiring a change of any kind in any State law regulating electric utility rates and charges, affecting any State law regarding such State regulation, or limiting such State regulation, including any prudence review requirements under such State law;
- (4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
- (5) Interfering with or impairing any program for competitive bidding for power supply in a State in which such program is established.

STEP 4

Certification

Read the certification statement, sign, and date.

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name: Mr. Benjamin F. Felton, Senior VP – Energy Supply	
Signature: 	Date: 7/27/2022

Appendix 10-1. Cross State Air Pollution Rule (CSAPR) Trading Program Title V Requirements

Description of CSAPR Monitoring Provisions

The CSAPR subject units, and the unit-specific monitoring provisions, at this source are identified in the following tables. These units are subject to the requirements for the CSAPR NO_x Annual Trading Program, CSAPR NO_x Ozone Season Group 3 Trading Program, and CSAPR SO₂ Group 1 Trading Program, which are included below as Sections I, II, and III, respectively.

Each unit will use one of the following as the monitoring methodology for each parameter as provided below and shall comply with the general monitoring, recordkeeping, reporting and other requirements in conditions 1 through 5 below and in paragraph (b) of Sections I, II, and III:

- Continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR Part 75, Subpart B (for SO₂ monitoring) or 40 CFR Part 75, Subpart H (for NO_x monitoring)
- Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR Part 75, Appendix D
- Excepted monitoring system requirements for gas- and oil-fired peaking units pursuant to 40 CFR Part 75, Appendix E
- Low Mass Emissions excepted monitoring (LME) requirements for gas- and oil-fired units pursuant to 40 CFR 75.19
- EPA-approved alternative monitoring system requirements pursuant to 40 CFR Part 75, Subpart E

Unit ID: Unit 1 {EUBOILER1}	
Parameter	Monitoring Methodology
SO ₂	CEMS requirements pursuant to 40 CFR Part 75, Subpart B
NO _x	CEMS requirements pursuant to 40 CFR Part 75, Subpart H
Heat Input	CEMS requirements pursuant to 40 CFR Part 75, Subpart B and 40 CFR Part 75, Subpart H

Unit ID: CTG 11-1 {EUCTG11-1}	
Parameter	Monitoring Methodology
SO ₂	Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR Part 75, Appendix D
NO _x	Excepted monitoring system requirements for gas- and oil-fired peaking units pursuant to 40 CFR Part 75, Appendix E
Heat Input	Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR Part 75, Appendix D

Unit ID: CTG 11-2 {EUCTG11-2}	
Parameter	Monitoring Methodology
SO ₂	Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR Part 75, Appendix D
NO _x	Excepted monitoring system requirements for gas- and oil-fired peaking units pursuant to 40 CFR Part 75, Appendix E
Heat Input	Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR Part 75, Appendix D

Unit ID: CTG 12-1 {EUCTG12-1}	
Parameter	Monitoring Methodology
SO ₂	Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR Part 75, Appendix D
NO _x	Excepted monitoring system requirements for gas- and oil-fired peaking units pursuant to 40 CFR Part 75, Appendix E
Heat Input	Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR Part 75, Appendix D

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

1. The above description of the monitoring used by a unit does not change, create an exemption from, or otherwise affect the monitoring, recordkeeping, and reporting requirements applicable to the unit under 40 CFR 97.430 through 97.435 (CSAPR NO_x Annual Trading Program), 97.1030 through 97.1035 (CSAPR NO_x Ozone Season Group 3 Trading Program), and 97.630 through 97.635 (CSAPR SO₂ Group 1 Trading Program). The monitoring, recordkeeping and reporting requirements applicable to each unit are included below in the standard conditions for the applicable CSAPR trading programs.
2. Owners and operators must submit to the Administrator a monitoring plan for each unit in accordance with 40 CFR 75.53, 75.62 and 75.73, as applicable. The monitoring plan for each unit is available at the EPA's website at <https://www.epa.gov/airmarkets/monitoring-plans-part-75-sources>.
3. Owners and operators that want to use an alternative monitoring system must submit to the Administrator a petition requesting approval of the alternative monitoring system in accordance with 40 CFR Part 75, Subpart E and 40 CFR 75.66 and 97.435 (CSAPR NO_x Annual Trading Program), 97.1035 (CSAPR NO_x Ozone Season Group 3 Trading Program), and/or 97.635 (CSAPR SO₂ Group 1 Trading Program). The Administrator's response approving or disapproving any petition for an alternative monitoring system is available on the EPA's website at <https://www.epa.gov/airmarkets/part-75-petition-responses>.
4. Owners and operators that want to use an alternative to any monitoring, recordkeeping, or reporting requirement under 40 CFR 97.430 through 97.434 (CSAPR NO_x Annual Trading Program), 97.1030 through 97.1034 (CSAPR NO_x Ozone Season Group 3 Trading Program), and/or 97.630 through 97.634 (CSAPR SO₂ Group 1 Trading Program) must submit to the Administrator a petition requesting approval of the alternative in accordance with 40 CFR 75.66 and 97.435 (CSAPR NO_x Annual Trading Program), 97.1035 (CSAPR NO_x Ozone Season Group 3 Trading Program), and/or 97.635 (CSAPR SO₂ Group 1 Trading Program). The Administrator's response approving or disapproving any petition for an alternative to a monitoring, recordkeeping, or reporting requirement is available on the EPA's website at <https://www.epa.gov/airmarkets/part-75-petition-responses>.
5. The descriptions of monitoring applicable to the unit included above meet the requirement of 40 CFR 97.430 through 97.434 (CSAPR NO_x Annual Trading Program), 97.1030 through 97.1034 (CSAPR NO_x Ozone Season Group 3 Trading Program), and 97.630 through 97.634 (CSAPR SO₂ Group 1 Trading Program), and therefore minor permit modification procedures, in accordance with 40 CFR 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B), may be used to add or change this unit's monitoring system description.

SECTION I: CSAPR NO_x Annual Trading Program requirements (40 CFR 97.406)

(a) Designated representative requirements.

The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.413 through 97.418.

(b) Emissions monitoring, reporting, and recordkeeping requirements.

- (1) The owners and operators, and the designated representative, of each CSAPR NO_x Annual source and each CSAPR NO_x Annual unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.430 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.431 (initial monitoring system certification and recertification procedures), 97.432 (monitoring system out-of-control periods), 97.433 (notifications concerning monitoring), 97.434 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.435 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

- (2) The emissions data determined in accordance with 40 CFR 97.430 through 97.435 shall be used to calculate allocations of CSAPR NO_x Annual allowances under 40 CFR 97.411(a)(2) and (b) and 97.412 and to determine compliance with the CSAPR NO_x Annual emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.430 through 97.435 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

(c) NO_x emissions requirements.

(1) CSAPR NO_x Annual emissions limitation.

- (i). As of the allowance transfer deadline for a control period in a given year, the owners and operators of each CSAPR NO_x Annual source and each CSAPR NO_x Annual unit at the source shall hold, in the source's compliance account, CSAPR NO_x Annual allowances available for deduction for such control period under 40 CFR 97.424(a) in an amount not less than the tons of total NO_x emissions for such control period from all CSAPR NO_x Annual units at the source.
- (ii). If total NO_x emissions during a control period in a given year from the CSAPR NO_x Annual units at a CSAPR NO_x Annual source are in excess of the CSAPR NO_x Annual emissions limitation set forth in paragraph (c)(1)(i) above, then:
- (A). The owners and operators of the source and each CSAPR NO_x Annual unit at the source shall hold the CSAPR NO_x Annual allowances required for deduction under 40 CFR 97.424(d); and
- (B). The owners and operators of the source and each CSAPR NO_x Annual unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart AAAAA and the Clean Air Act.

(2) CSAPR NO_x Annual assurance provisions.

- (i). If total NO_x emissions during a control period in a given year from all CSAPR NO_x Annual units at CSAPR NO_x Annual sources in the state and Indian country within the borders of such State exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such NO_x emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) CSAPR NO_x Annual allowances available for deduction for such control period under 40 CFR 97.425(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.425(b), of multiplying— (A) The quotient of the amount by which the common designated representative's share of such NO_x emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state and Indian country within the borders of such state for such control period, by which each common designated representative's share of such NO_x emissions exceeds the respective common designated representative's assurance level; and (B) The amount by which total NO_x emissions from all CSAPR NO_x Annual units at CSAPR NO_x Annual sources in the state and Indian country within the borders of such state for such control period exceed the state assurance level.
- (ii). The owners and operators shall hold the CSAPR NO_x Annual allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

- (iii). Total NO_x emissions from all CSAPR NO_x Annual units at CSAPR NO_x Annual sources in the State and Indian country within the borders of such state during a control period in a given year exceed the state assurance level if such total NO_x emissions exceed the sum, for such control period, of the state NO_x Annual trading budget under 40 CFR 97.410(a) and the state's variability limit under 40 CFR 97.410(b).
- (iv). It shall not be a violation of 40 CFR Part 97, Subpart AAAAA or of the Clean Air Act if total NO_x emissions from all CSAPR NO_x Annual units at CSAPR NO_x Annual sources in the State and Indian country within the borders of such State during a control period exceed the state assurance level or if a common designated representative's share of total NO_x emissions from the CSAPR NO_x Annual units at CSAPR NO_x Annual sources in the state and Indian country within the borders of such state during a control period exceeds the common designated representative's assurance level.
- (v). To the extent the owners and operators fail to hold CSAPR NO_x Annual allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,
 - (A). The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and
 - (B). Each CSAPR NO_x Annual allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart AAAAA and the Clean Air Act.
- (3) Compliance periods.
 - (i). A CSAPR NO_x Annual unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of January 1, 2015, or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.430(b) and for each control period thereafter.
 - (ii). A CSAPR NO_x Annual unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting on the later of January 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.430(b) and for each control period thereafter.
- (4) Vintage of allowances held for compliance.
 - (i). A CSAPR NO_x Annual allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a CSAPR NO_x Annual allowance that was allocated for such control period or a control period in a prior year.
 - (ii). A CSAPR NO_x Annual allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a CSAPR NO_x Annual allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.
- (5) Allowance Management System requirements. Each CSAPR NO_x Annual allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR Part 97, Subpart AAAAA.
- (6) Limited authorization. A CSAPR NO_x Annual allowance is a limited authorization to emit one ton of NO_x during the control period in one year. Such authorization is limited in its use and duration as follows:
 - (i). Such authorization shall only be used in accordance with the CSAPR NO_x Annual Trading Program; and
 - (ii). Notwithstanding any other provision of 40 CFR Part 97, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.
- (7) Property right. A CSAPR NO_x Annual allowance does not constitute a property right.

(d) Title V permit revision requirements.

- (1) No title V permit revision shall be required for any allocation, holding, deduction, or transfer of CSAPR NO_x Annual allowances in accordance with 40 CFR Part 97, Subpart AAAAA.

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

- (2) This permit incorporates the CSAPR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.430 through 97.435, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR Part 75, Subparts B and H), an excepted monitoring system (pursuant to 40 CFR Part 75, Appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR 75.19), and an alternative monitoring system (pursuant to 40 CFR Part 75, Subpart E). Therefore, the Description of CSAPR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.406(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).

(e) Additional recordkeeping and reporting requirements.

- (1) Unless otherwise provided, the owners and operators of each CSAPR NO_x Annual source and each CSAPR NO_x Annual unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
- (i). The certificate of representation under 40 CFR 97.416 for the designated representative for the source and each CSAPR NO_x Annual unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.416 changing the designated representative.
 - (ii). All emissions monitoring information, in accordance with 40 CFR Part 97, Subpart AAAAA.
 - (iii). Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the CSAPR NO_x Annual Trading Program.
- (2) The designated representative of a CSAPR NO_x Annual source and each CSAPR NO_x Annual unit at the source shall make all submissions required under the CSAPR NO_x Annual Trading Program, except as provided in 40 CFR 97.418. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR Parts 70 and 71.

(f) Liability.

- (1) Any provision of the CSAPR NO_x Annual Trading Program that applies to a CSAPR NO_x Annual source or the designated representative of a CSAPR NO_x Annual source shall also apply to the owners and operators of such source and of the CSAPR NO_x Annual units at the source.
- (2) Any provision of the CSAPR NO_x Annual Trading Program that applies to a CSAPR NO_x Annual unit or the designated representative of a CSAPR NO_x Annual unit shall also apply to the owners and operators of such unit.

(g) Effect on other authorities.

No provision of the CSAPR NO_x Annual Trading Program or exemption under 40 CFR 97.405 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a CSAPR NO_x Annual source or CSAPR NO_x Annual unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

(h) Effect on units in Indian country.

Notwithstanding the provisions of paragraphs (a) through (g) above, paragraphs (a) through (g) shall be deemed not to impose any requirements on any source or unit, or any owner, operator, or designated representative with regard to any source or unit, in Indian country within the borders of the state.

SECTION II: CSAPR NO_x Ozone Season Group 3 Trading Program Requirements (40 CFR 97.1006)**(a) Designated representative requirements.**

The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.813 through 97.818.

(b) Emissions monitoring, reporting, and recordkeeping requirements.

- (1) The owners and operators, and the designated representative, of each CSAPR NO_x Ozone Season Group 3 source and each CSAPR NO_x Ozone Season Group 3 unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.830 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.831 (initial monitoring system certification and recertification procedures), 97.832 (monitoring system out-of-control periods), 97.833 (notifications concerning monitoring), 97.834 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.835 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).
- (2) The emissions data determined in accordance with 40 CFR 97.830 through 97.835 shall be used to calculate allocations of CSAPR NO_x Ozone Season Group 3 allowances under 40 CFR 97.811(a)(2) and (b) and 97.812 and to determine compliance with the CSAPR NO_x Ozone Season Group 3 emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.830 through 97.835 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

(c) NO_x emissions requirements.

- (1) CSAPR NO_x Ozone Season Group 3 emissions limitation.
 - (i). As of the allowance transfer deadline for a control period in a given year, the owners and operators of each CSAPR NO_x Ozone Season Group 3 source and each CSAPR NO_x Ozone Season Group 3 unit at the source shall hold, in the source's compliance account, CSAPR NO_x Ozone Season Group 3 allowances available for deduction for such control period under 40 CFR 97.824(a) in an amount not less than the tons of total NO_x emissions for such control period from all CSAPR NO_x Ozone Season Group 3 units at the source.
 - (ii). If total NO_x emissions during a control period in a given year from the CSAPR NO_x Ozone Season Group 3 units at a CSAPR NO_x Ozone Season Group 3 source are in excess of the CSAPR NO_x Ozone Season Group 3 emissions limitation set forth in paragraph (c)(1)(i) above, then:
 - (A). The owners and operators of the source and each CSAPR NO_x Ozone Season Group 3 unit at the source shall hold the CSAPR NO_x Ozone Season Group 3 allowances required for deduction under 40 CFR 97.824(d); and
 - (B). The owners and operators of the source and each CSAPR NO_x Ozone Season Group 3 unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart GGGGG and the Clean Air Act.
- (2) CSAPR NO_x Ozone Season Group 3 assurance provisions.
 - (i). If total NO_x emissions during a control period in a given year from all CSAPR NO_x Ozone Season Group 3 units at CSAPR NO_x Ozone Season Group 3 sources in the state and Indian country within the borders of such state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

NO_x emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) CSAPR NO_x Ozone Season Group 3 allowances available for deduction for such control period under 40 CFR 97.825(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.825(b), of multiplying—

- (A). The quotient of the amount by which the common designated representative's share of such NO_x emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state and Indian country within the borders of such state for such control period, by which each common designated representative's share of such NO_x emissions exceeds the respective common designated representative's assurance level; and
 - (B). The amount by which total NO_x emissions from all CSAPR NO_x Ozone Season Group 3 units at CSAPR NO_x Ozone Season Group 3 sources in the state and Indian country within the borders of such state for such control period exceed the state assurance level.
- (ii). The owners and operators shall hold the CSAPR NO_x Ozone Season Group 3 allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.
 - (iii). Total NO_x emissions from all CSAPR NO_x Ozone Season Group 3 units at CSAPR NO_x Ozone Season Group 3 sources in the state and Indian country within the borders of such state during a control period in a given year exceed the state assurance level if such total NO_x emissions exceed the sum, for such control period, of the State NO_x Ozone Season Group 3 trading budget under 40 CFR 97.810(a) and the state's variability limit under 40 CFR 97.810(b).
 - (iv). It shall not be a violation of 40 CFR Part 97, Subpart GGGGG or of the Clean Air Act if total NO_x emissions from all CSAPR NO_x Ozone Season Group 3 units at CSAPR NO_x Ozone Season Group 3 sources in the state and Indian country within the borders of such state during a control period exceed the state assurance level or if a common designated representative's share of total NO_x emissions from the CSAPR NO_x Ozone Season Group 3 units at CSAPR NO_x Ozone Season Group 3 sources in the state and Indian country within the borders of such state during a control period exceeds the common designated representative's assurance level.
 - (v). To the extent the owners and operators fail to hold CSAPR NO_x Ozone Season Group 3 allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,
 - (A). The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and
 - (B). Each CSAPR NO_x Ozone Season Group 3 allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart GGGGG and the Clean Air Act.
- (3) Compliance periods.
- (i). A CSAPR NO_x Ozone Season Group 3 unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of May 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.830(b) and for each control period thereafter.
 - (ii). A CSAPR NO_x Ozone Season Group 3 unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting on the later of May 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.830(b) and for each control period thereafter.

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

- (4) Vintage of allowances held for compliance.
 - (i). A CSAPR NO_x Ozone Season Group 3 allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a CSAPR NO_x Ozone Season Group 3 allowance that was allocated for such control period or a control period in a prior year.
 - (ii). A CSAPR NO_x Ozone Season Group 3 allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a CSAPR NO_x Ozone Season Group 3 allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.
- (5) Allowance Management System requirements. Each CSAPR NO_x Ozone Season Group 3 allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR Part 97, Subpart GGGGG.
- (6) Limited authorization. A CSAPR NO_x Ozone Season Group 3 allowance is a limited authorization to emit one ton of NO_x during the control period in one year. Such authorization is limited in its use and duration as follows:
 - (i). Such authorization shall only be used in accordance with the CSAPR NO_x Ozone Season Group 3 Trading Program; and
 - (ii). Notwithstanding any other provision of 40 CFR Part 97, Subpart GGGGG, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.
- (7) Property right. A CSAPR NO_x Ozone Season Group 3 allowance does not constitute a property right.

(d) Title V permit revision requirements.

- (1) No title V permit revision shall be required for any allocation, holding, deduction, or transfer of CSAPR NO_x Ozone Season Group 3 allowances in accordance with 40 CFR Part 97, Subpart GGGGG.
- (2) This permit incorporates the CSAPR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.830 through 97.835, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR Part 75, Subparts B and H), an excepted monitoring system (pursuant to 40 CFR Part 75, Appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR 75.19), and an alternative monitoring system (pursuant to 40 CFR Part 75, Subpart E). Therefore, the Description of CSAPR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.806(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).

(e) Additional recordkeeping and reporting requirements.

- (1) Unless otherwise provided, the owners and operators of each CSAPR NO_x Ozone Season Group 3 source and each CSAPR NO_x Ozone Season Group 3 unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
 - (i). The certificate of representation under 40 CFR 97.816 for the designated representative for the source and each CSAPR NO_x Ozone Season Group 3 unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.816 changing the designated representative.
 - (ii). All emissions monitoring information, in accordance with 40 CFR Part 97, Subpart GGGGG.
 - (iii). Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the CSAPR NO_x Ozone Season Group 3 Trading Program.

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

- (2) The designated representative of a CSAPR NO_x Ozone Season Group 3 source and each CSAPR NO_x Ozone Season Group 3 unit at the source shall make all submissions required under the CSAPR NO_x Ozone Season Group 3 Trading Program, except as provided in 40 CFR 97.818. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR Parts 70 and 71.

(f) Liability.

- (1) Any provision of the CSAPR NO_x Ozone Season Group 3 Trading Program that applies to a CSAPR NO_x Ozone Season Group 3 source or the designated representative of a CSAPR NO_x Ozone Season Group 3 source shall also apply to the owners and operators of such source and of the CSAPR NO_x Ozone Season Group 3 units at the source.
- (2) Any provision of the CSAPR NO_x Ozone Season Group 3 Trading Program that applies to a CSAPR NO_x Ozone Season Group 3 unit or the designated representative of a CSAPR NO_x Ozone Season Group 3 unit shall also apply to the owners and operators of such unit.

(g) Effect on other authorities.

No provision of the CSAPR NO_x Ozone Season Group 3 Trading Program or exemption under 40 CFR 97.805 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a CSAPR NO_x Ozone Season Group 3 source or CSAPR NO_x Ozone Season Group 3 unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

(h) Effect on units in Indian country.

Notwithstanding the provisions of paragraphs (a) through (g) above, paragraphs (a) through (g) shall be deemed not to impose any requirements on any source or unit, or any owner, operator, or designated representative with regard to any source or unit, in Indian country within the borders of the state.

SECTION III: CSAPR SO₂ Group 1 Trading Program requirements (40 CFR 97.606)

(a) Designated representative requirements.

The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.613 through 97.618.

(b) Emissions monitoring, reporting, and recordkeeping requirements.

- (1) The owners and operators, and the designated representative, of each CSAPR SO₂ Group 1 source and each CSAPR SO₂ Group 1 unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.630 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.631 (initial monitoring system certification and recertification procedures), 97.632 (monitoring system out-of-control periods), 97.633 (notifications concerning monitoring), 97.634 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.635 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).
- (2) The emissions data determined in accordance with 40 CFR 97.630 through 97.635 shall be used to calculate allocations of CSAPR SO₂ Group 1 allowances under 40 CFR 97.611(a)(2) and (b) and 97.612 and to determine compliance with the CSAPR SO₂ Group 1 emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.630 through 97.635 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

(c) SO₂ emissions requirements.

(1) CSAPR SO₂ Group 1 emissions limitation.

- (i). As of the allowance transfer deadline for a control period in a given year, the owners and operators of each CSAPR SO₂ Group 1 source and each CSAPR SO₂ Group 1 unit at the source shall hold, in the source's compliance account, CSAPR SO₂ Group 1 allowances available for deduction for such control period under 40 CFR 97.624(a) in an amount not less than the tons of total SO₂ emissions for such control period from all CSAPR SO₂ Group 1 units at the source.
- (ii). If total SO₂ emissions during a control period in a given year from the CSAPR SO₂ Group 1 units at a CSAPR SO₂ Group 1 source are in excess of the CSAPR SO₂ Group 1 emissions limitation set forth in paragraph (c)(1)(i) above, then:
 - (A). The owners and operators of the source and each CSAPR SO₂ Group 1 unit at the source shall hold the CSAPR SO₂ Group 1 allowances required for deduction under 40 CFR 97.624(d); and
 - (B). The owners and operators of the source and each CSAPR SO₂ Group 1 unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation 40 CFR Part 97, Subpart CCCCC and the Clean Air Act.

(2) CSAPR SO₂ Group 1 assurance provisions.

- (i). If total SO₂ emissions during a control period in a given year from all CSAPR SO₂ Group 1 units at CSAPR SO₂ Group 1 sources in the state and Indian country within the borders of such state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such SO₂ emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) CSAPR SO₂ Group 1 allowances available for deduction for such control period under 40 CFR 97.625(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.625(b), of multiplying—
 - (A). The quotient of the amount by which the common designated representative's share of such SO₂ emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state and Indian country within the borders of such state for such control period, by which each common designated representative's share of such SO₂ emissions exceeds the respective common designated representative's assurance level; and
 - (B). The amount by which total SO₂ emissions from all CSAPR SO₂ Group 1 units at CSAPR SO₂ Group 1 sources in the state and Indian country within the borders of such state for such control period exceed the state assurance level.
- (ii). The owners and operators shall hold the CSAPR SO₂ Group 1 allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.
- (iii). Total SO₂ emissions from all CSAPR SO₂ Group 1 units at CSAPR SO₂ Group 1 sources in the state and Indian country within the borders of such state during a control period in a given year exceed the state assurance level if such total SO₂ emissions exceed the sum, for such control period, of the state SO₂ Group 1 trading budget under 40 CFR 97.610(a) and the state's variability limit under 40 CFR 97.610(b).
- (iv). It shall not be a violation of 40 CFR Part 97, Subpart CCCCC or of the Clean Air Act if total SO₂ emissions from all CSAPR SO₂ Group 1 units at CSAPR SO₂ Group 1 sources in the state and Indian country within the borders of such state during a control period exceed the state assurance level or if

Section 1 – Main Boiler

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

a common designated representative's share of total SO₂ emissions from the CSAPR SO₂ Group 1 units at CSAPR SO₂ Group 1 sources in the state and Indian country within the borders of such state during a control period exceeds the common designated representative's assurance level.

- (v). To the extent the owners and operators fail to hold CSAPR SO₂ Group 1 allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,
 - (A). The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and
 - (B). Each CSAPR SO₂ Group 1 allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart CCCCC and the Clean Air Act.
- (3) Compliance periods.
 - (i). A CSAPR SO₂ Group 1 unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of January 1, 2015 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.630(b) and for each control period thereafter.
 - (ii). A CSAPR SO₂ Group 1 unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting on the later of January 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.630(b) and for each control period thereafter.
- (4) Vintage of allowances held for compliance.
 - (i). A CSAPR SO₂ Group 1 allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a CSAPR SO₂ Group 1 allowance that was allocated for such control period or a control period in a prior year.
 - (ii). A CSAPR SO₂ Group 1 allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a CSAPR SO₂ Group 1 allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.
- (5) Allowance Management System requirements. Each CSAPR SO₂ Group 1 allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR Part 97, Subpart CCCCC.
- (6) Limited authorization. A CSAPR SO₂ Group 1 allowance is a limited authorization to emit one ton of SO₂ during the control period in one year. Such authorization is limited in its use and duration as follows:
 - (i). Such authorization shall only be used in accordance with the CSAPR SO₂ Group 1 Trading Program; and
 - (ii). Notwithstanding any other provision of 40 CFR Part 97, Subpart CCCCC, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.
- (7) Property right. A CSAPR SO₂ Group 1 allowance does not constitute a property right.

(d) Title V permit revision requirements.

- (1) No title V permit revision shall be required for any allocation, holding, deduction, or transfer of CSAPR SO₂ Group 1 allowances in accordance with 40 CFR Part 97, Subpart CCCCC.
- (2) This permit incorporates the CSAPR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.630 through 97.635, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR Part 75, Subparts B and H), an excepted monitoring system (pursuant to 40 CFR Part 75, Appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR 75.19), and an alternative monitoring system (pursuant to 40 CFR Part 75, Subpart E). Therefore, the Description of CSAPR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.606(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).

(e) Additional recordkeeping and reporting requirements.

- (1) Unless otherwise provided, the owners and operators of each CSAPR SO₂ Group 1 source and each CSAPR SO₂ Group 1 unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
 - (i). The certificate of representation under 40 CFR 97.616 for the designated representative for the source and each CSAPR SO₂ Group 1 unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.616 changing the designated representative.
 - (ii). All emissions monitoring information, in accordance with 40 CFR Part 97, Subpart CCCCC.
 - (iii). Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the CSAPR SO₂ Group 1 Trading Program.
- (2) The designated representative of a CSAPR SO₂ Group 1 source and each CSAPR SO₂ Group 1 unit at the source shall make all submissions required under the CSAPR SO₂ Group 1 Trading Program, except as provided in 40 CFR 97.618. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR Parts 70 and 71.

(f) Liability.

- (1) Any provision of the CSAPR SO₂ Group 1 Trading Program that applies to a CSAPR SO₂ Group 1 source or the designated representative of a CSAPR SO₂ Group 1 source shall also apply to the owners and operators of such source and of the CSAPR SO₂ Group 1 units at the source.
- (2) Any provision of the CSAPR SO₂ Group 1 Trading Program that applies to a CSAPR SO₂ Group 1 unit or the designated representative of a CSAPR SO₂ Group 1 unit shall also apply to the owners and operators of such unit.

(g) Effect on other authorities.

No provision of the CSAPR SO₂ Group 1 Trading Program or exemption under 40 CFR 97.605 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a CSAPR SO₂ Group 1 source or CSAPR SO₂ Group 1 unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

(h) Effect on units in Indian country.

Notwithstanding the provisions of paragraphs (a) through (g) above, paragraphs (a) through (g) shall be deemed not to impose any requirements on any source or unit, or any owner, operator, or designated representative with regard to any source or unit, in Indian country within the borders of the state.

SECTION 2 – COMBUSTION TURBINE GENERATORS

A. GENERAL CONDITIONS

Permit Enforceability

- All conditions in this permit are both federally enforceable and state enforceable unless otherwise noted. **(R 336.1213(5))**
- Those conditions that are hereby incorporated in a state-only enforceable Source-Wide PTI pursuant to Rule 201(2)(d) are designated by footnote one. **(R 336.1213(5)(a), R 336.1214a(5))**
- Those conditions that are hereby incorporated in a federally enforceable Source-Wide PTI pursuant to Rule 201(2)(c) are designated by footnote two. **(R 336.1213(5)(b), R 336.1214a(3))**

General Provisions

1. The permittee shall comply with all conditions of this ROP. Any ROP noncompliance constitutes a violation of Act 451, and is grounds for enforcement action, for ROP revocation or revision, or for denial of the renewal of the ROP. All terms and conditions of this ROP that are designated as federally enforceable are enforceable by the Administrator of the United States Environmental Protection Agency (USEPA) and by citizens under the provisions of the federal Clean Air Act (CAA). Any terms and conditions based on applicable requirements which are designated as “state-only” are not enforceable by the USEPA or citizens pursuant to the CAA. **(R 336.1213(1)(a))**
2. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this ROP. **(R 336.1213(1)(b))**
3. This ROP may be modified, revised, or revoked for cause. The filing of a request by the permittee for a permit modification, revision, or termination, or a notification of planned changes or anticipated noncompliance does not stay any ROP term or condition. This does not supersede or affect the ability of the permittee to make changes, at the permittee’s own risk, pursuant to Rule 215 and Rule 216. **(R 336.1213(1)(c))**
4. The permittee shall allow the department, or an authorized representative of the department, upon presentation of credentials and other documents as may be required by law and upon stating the authority for and purpose of the investigation, to perform any of the following activities: **(R 336.1213(1)(d))**
 - a. Enter, at reasonable times, a stationary source or other premises where emissions-related activity is conducted or where records must be kept under the conditions of the ROP.
 - b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the ROP.
 - c. Inspect, at reasonable times, any of the following:
 - i. Any stationary source.
 - ii. Any emission unit.
 - iii. Any equipment, including monitoring and air pollution control equipment.
 - iv. Any work practices or operations regulated or required under the ROP.
 - d. As authorized by Section 5526 of Act 451, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the ROP or applicable requirements.
5. The permittee shall furnish to the department, within a reasonable time, any information the department may request, in writing, to determine whether cause exists for modifying, revising, or revoking the ROP or to determine compliance with this ROP. Upon request, the permittee shall also furnish to the department copies of any records that are required to be kept as a term or condition of this ROP. For information which is claimed by the permittee to be confidential, consistent with the requirements of the 1976 PA 442, MCL §15.231 et seq., and known as the Freedom of Information Act, the person may also be required to furnish the records directly to the USEPA together with a claim of confidentiality. **(R 336.1213(1)(e))**

Section 2 – Combustion Turbine Generators

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

6. A challenge by any person, the Administrator of the USEPA, or the department to a particular condition or a part of this ROP shall not set aside, delay, stay, or in any way affect the applicability or enforceability of any other condition or part of this ROP. **(R 336.1213(1)(f))**
7. The permittee shall pay fees consistent with the fee schedule and requirements pursuant to Section 5522 of Act 451. **(R 336.1213(1)(g))**
8. This ROP does not convey any property rights or any exclusive privilege. **(R 336.1213(1)(h))**

Equipment & Design

9. Any collected air contaminants shall be removed as necessary to maintain the equipment at the required operating efficiency. The collection and disposal of air contaminants shall be performed in a manner so as to minimize the introduction of contaminants to the outer air. Transport of collected air contaminants in Priority I and II areas requires the use of material handling methods specified in Rule 370(2).² **(R 336.1370)**
10. Any air cleaning device shall be installed, maintained, and operated in a satisfactory manner and in accordance with the Michigan Air Pollution Control rules and existing law. **(R 336.1910)**

Emission Limits

11. Unless otherwise specified in this ROP, the permittee shall comply with Rule 301, which states, in part, "Except as provided in Subrules 2, 3, and 4 of this rule, a person shall not cause or permit to be discharged into the outer air from a process or process equipment a visible emission of a density greater than the most stringent of the following:"² **(R 336.1301(1))**
 - a. A 6-minute average of 20% opacity, except for one 6-minute average per hour of not more than 27% opacity.
 - b. A limit specified by an applicable federal new source performance standard.

The grading of visible emissions shall be determined in accordance with Rule 303.

12. The permittee shall not cause or permit the emission of an air contaminant or water vapor in quantities that cause, alone or in reaction with other air contaminants, either of the following:
 - a. Injurious effects to human health or safety, animal life, plant life of significant economic value, or property.¹ **(R 336.1901(a))**
 - b. Unreasonable interference with the comfortable enjoyment of life and property.¹ **(R 336.1901(b))**

Testing/Sampling

13. The department may require the owner or operator of any source of an air contaminant to conduct acceptable performance tests, at the owner's or operator's expense, in accordance with Rule 1001 and Rule 1003, under any of the conditions listed in Rule 1001(1).² **(R 336.2001)**
14. Any required performance testing shall be conducted in accordance with Rule 1001(2), Rule 1001(3) and Rule 1003. **(R 336.2001(2), R 336.2001(3), R 336.2003(1))**
15. Any required test results shall be submitted to the Air Quality Division (AQD) in the format prescribed by the applicable reference test method within 60 days following the last date of the test. **(R 336.2001(5))**

Monitoring/Recordkeeping

16. Records of any periodic emission or parametric monitoring required in this ROP shall include the following information specified in Rule 213(3)(b)(i), where appropriate. **(R 336.1213(3)(b))**
 - a. The date, location, time, and method of sampling or measurements.
 - b. The dates the analyses of the samples were performed.
 - c. The company or entity that performed the analyses of the samples.
 - d. The analytical techniques or methods used.
 - e. The results of the analyses.
 - f. The related process operating conditions or parameters that existed at the time of sampling or measurement.
17. All required monitoring data, support information and all reports, including reports of all instances of deviation from permit requirements, shall be kept and furnished to the department upon request for a period of not less than 5 years from the date of the monitoring sample, measurement, report or application. Support information includes all calibration and maintenance records and all original strip-chart recordings, or other original data records, for continuous monitoring instrumentation and copies of all reports required by the ROP. **(R 336.1213(1)(e), R 336.1213(3)(b)(ii))**

Certification & Reporting

18. Except for the alternate certification schedule provided in Rule 213(3)(c)(iii)(B), any document required to be submitted to the department as a term or condition of this ROP shall contain an original certification by a Responsible Official which state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. **(R 336.1213(3)(c))**
19. A Responsible Official shall certify to the appropriate AQD District Office and to the USEPA that the stationary source is and has been in compliance with all terms and conditions contained in the ROP except for deviations that have been or are being reported to the appropriate AQD District Office pursuant to Rule 213(3)(c). This certification shall include all the information specified in Rule 213(4)(c)(i) through (v) and shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the certification are true, accurate, and complete. The annual compliance certification (pursuant to Rule 213(4)(c)) shall be submitted to the USEPA through the USEPA's Central Data Exchange (CDX) using the Compliance and Emissions Data Reporting Interface (CEDRI), which can be accessed through CDX (<https://cdx.epa.gov/>), unless it contains confidential business information then use the following address: USEPA, Air Compliance Data - Michigan, Air and Radiation Division, 77 West Jackson Boulevard, Chicago, Illinois 60604-3507. **(R 336.1213(4)(c))**
20. The certification of compliance shall be submitted annually for the term of this ROP as detailed in the special conditions, or more frequently if specified in an applicable requirement or in this ROP. **(R 336.1213(4)(c))**
21. The permittee shall promptly report any deviations from ROP requirements and certify the reports. The prompt reporting of deviations from ROP requirements is defined in Rule 213(3)(c)(ii) as follows, unless otherwise described in this ROP. **(R 336.1213(3)(c))**
 - a. For deviations that exceed the emissions allowed under the ROP, prompt reporting means reporting consistent with the requirements of Rule 912 as detailed in Condition 25. All reports submitted pursuant to this paragraph shall be promptly certified as specified in Rule 213(3)(c)(iii).
 - b. For deviations which exceed the emissions allowed under the ROP and which are not reported pursuant to Rule 912 due to the duration of the deviation, prompt reporting means the reporting of all deviations in the semiannual reports required by Rule 213(3)(c)(i). The report shall describe reasons for each deviation and the actions taken to minimize or correct each deviation.
 - c. For deviations that do not exceed the emissions allowed under the ROP, prompt reporting means the reporting of all deviations in the semiannual reports required by Rule 213(3)(c)(i). The report shall describe the reasons for each deviation and the actions taken to minimize or correct each deviation.

Section 2 – Combustion Turbine Generators

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

22. For reports required pursuant to Rule 213(3)(c)(ii), prompt certification of the reports is described in Rule 213(3)(c)(iii) as either of the following: **(R 336.1213(3)(c))**
 - a. Submitting a certification by a Responsible Official with each report which states that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.
 - b. Submitting, within 30 days following the end of a calendar month during which one or more prompt reports of deviations from the emissions allowed under the ROP were submitted to the department pursuant to Rule 213(3)(c)(ii), a certification by a Responsible Official which states that; “based on information and belief formed after reasonable inquiry, the statements and information contained in each of the reports submitted during the previous month were true, accurate, and complete.” The certification shall include a listing of the reports that are being certified. Any report submitted pursuant to Rule 213(3)(c)(ii) that will be certified on a monthly basis pursuant to this paragraph shall include a statement that certification of the report will be provided within 30 days following the end of the calendar month.
23. Semiannually for the term of the ROP as detailed in the special conditions, or more frequently if specified, the permittee shall submit certified reports of any required monitoring to the appropriate AQD District Office. All instances of deviations from ROP requirements during the reporting period shall be clearly identified in the reports. **(R 336.1213(3)(c)(i))**
24. On an annual basis, the permittee shall report the actual emissions, or the information necessary to determine the actual emissions, of each regulated air pollutant as defined in Rule 212(6) for each emission unit utilizing the emissions inventory forms provided by the department. **(R 336.1212(6))**
25. The permittee shall provide notice of an abnormal condition, start-up, shutdown, or malfunction that results in emissions of a hazardous or toxic air pollutant which continue for more than one hour in excess of any applicable standard or limitation, or emissions of any air contaminant continuing for more than two hours in excess of an applicable standard or limitation, as required in Rule 912, to the appropriate AQD District Office. The notice shall be provided not later than two business days after the start-up, shutdown, or discovery of the abnormal conditions or malfunction. Notice shall be by any reasonable means, including electronic, telephonic, or oral communication. Written reports, if required under Rule 912, must be submitted to the appropriate AQD District Supervisor within 10 days after the start-up or shutdown occurred, within 10 days after the abnormal conditions or malfunction has been corrected, or within 30 days of discovery of the abnormal conditions or malfunction, whichever is first. The written reports shall include all of the information required in Rule 912(5) and shall be certified by a Responsible Official in a manner consistent with the CAA.² **(R 336.1912)**

Permit Shield

26. Compliance with the conditions of the ROP shall be considered compliance with any applicable requirements as of the date of ROP issuance if either of the following provisions is satisfied. **(R 336.1213(6)(a)(i), R 336.1213(6)(a)(ii))**
 - a. The applicable requirements are included and are specifically identified in the ROP.
 - b. The permit includes a determination or concise summary of the determination by the department that other specifically identified requirements are not applicable to the stationary source.

Any requirements identified in Part E of this ROP have been identified as non-applicable to this ROP and are included in the permit shield.

27. Nothing in this ROP shall alter or affect any of the following:
 - a. The provisions of Section 303 of the CAA, emergency orders, including the authority of the USEPA under Section 303 of the CAA. **(R 336.1213(6)(b)(i))**
 - b. The liability of the owner or operator of this source for any violation of applicable requirements prior to or at the time of this ROP issuance. **(R 336.1213(6)(b)(ii))**
 - c. The applicable requirements of the acid rain program, consistent with Section 408(a) of the CAA. **(R 336.1213(6)(b)(iii))**

Section 2 – Combustion Turbine Generators

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

- d. The ability of the USEPA to obtain information from a source pursuant to Section 114 of the CAA. **(R 336.1213(6)(b)(iv))**
28. The permit shield shall not apply to provisions incorporated into this ROP through procedures for any of the following:
 - a. Operational flexibility changes made pursuant to Rule 215. **(R 336.1215(5))**
 - b. Administrative Amendments made pursuant to Rule 216(1)(a)(i)-(iv). **(R 336.1216(1)(b)(iii))**
 - c. Administrative Amendments made pursuant to Rule 216(1)(a)(v) until the amendment has been approved by the department. **(R 336.1216(1)(c)(iii))**
 - d. Minor Permit Modifications made pursuant to Rule 216(2). **(R 336.1216(2)(f))**
 - e. State-Only Modifications made pursuant to Rule 216(4) until the changes have been approved by the department. **(R 336.1216(4)(e))**
29. Expiration of this ROP results in the loss of the permit shield. If a timely and administratively complete application for renewal is submitted not more than 18 months, but not less than 6 months, before the expiration date of the ROP, but the department fails to take final action before the end of the ROP term, the existing ROP does not expire until the renewal is issued or denied, and the permit shield shall extend beyond the original ROP term until the department takes final action. **(R 336.1217(1)(c), R 336.1217(1)(a))**

Revisions

30. For changes to any process or process equipment covered by this ROP that do not require a revision of the ROP pursuant to Rule 216, the permittee must comply with Rule 215. **(R 336.1215, R 336.1216)**
31. A change in ownership or operational control of a stationary source covered by this ROP shall be made pursuant to Rule 216(1). **(R 336.1219(2))**
32. For revisions to this ROP, an administratively complete application shall be considered timely if it is received by the department in accordance with the time frames specified in Rule 216. **(R 336.1210(10))**
33. Pursuant to Rule 216(1)(b)(iii), Rule 216(2)(d) and Rule 216(4)(d), after a change has been made, and until the department takes final action, the permittee shall comply with both the applicable requirements governing the change and the ROP terms and conditions proposed in the application for the modification. During this time period, the permittee may choose to not comply with the existing ROP terms and conditions that the application seeks to change. However, if the permittee fails to comply with the ROP terms and conditions proposed in the application during this time period, the terms and conditions in the ROP are enforceable. **(R 336.1216(1)(c)(iii), R 336.1216(2)(d), R 336.1216(4)(d))**

Reopenings

34. A ROP shall be reopened by the department prior to the expiration date and revised by the department under any of the following circumstances:
 - a. If additional requirements become applicable to this stationary source with three or more years remaining in the term of the ROP, but not if the effective date of the new applicable requirement is later than the ROP expiration date. **(R 336.1217(2)(a)(i))**
 - b. If additional requirements pursuant to Title IV of the CAA become applicable to this stationary source. **(R 336.1217(2)(a)(ii))**
 - c. If the department determines that the ROP contains a material mistake, information required by any applicable requirement was omitted, or inaccurate statements were made in establishing emission limits or the terms or conditions of the ROP. **(R 336.1217(2)(a)(iii))**
 - d. If the department determines that the ROP must be revised to ensure compliance with the applicable requirements. **(R 336.1217(2)(a)(iv))**

Renewals

35. For renewal of this ROP, an administratively complete application shall be considered timely if it is received by the department not more than 18 months, but not less than 6 months, before the expiration date of the ROP. **(R 336.1210(9))**

Stratospheric Ozone Protection

36. If the permittee is subject to Title 40 of the Code of Federal Regulations (CFR), Part 82 and services, maintains, or repairs appliances except for motor vehicle air conditioners (MVAC), or disposes of appliances containing refrigerant, including MVAC and small appliances, or if the permittee is a refrigerant reclaimer, appliance owner or a manufacturer of appliances or recycling and recovery equipment, the permittee shall comply with all applicable standards for recycling and emissions reduction pursuant to 40 CFR Part 82, Subpart F.
37. If the permittee is subject to 40 CFR Part 82 and performs a service on motor (fleet) vehicles when this service involves refrigerant in the MVAC, the permittee is subject to all the applicable requirements as specified in 40 CFR Part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners. The term “motor vehicle” as used in Subpart B does not include a vehicle in which final assembly of the vehicle has not been completed by the original equipment manufacturer. The term MVAC as used in Subpart B does not include the air-tight sealed refrigeration system used for refrigerated cargo or an air conditioning system on passenger buses using Hydrochlorofluorocarbon-22 refrigerant.

Risk Management Plan

38. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall register and submit to the USEPA the required data related to the risk management plan for reducing the probability of accidental releases of any regulated substances listed pursuant to Section 112(r)(3) of the CAA as amended in 40 CFR 68.130. The list of substances, threshold quantities, and accident prevention regulations promulgated under 40 CFR Part 68, do not limit in any way the general duty provisions under Section 112(r)(1).
39. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall comply with the requirements of 40 CFR Part 68, no later than the latest of the following dates as provided in 40 CFR 68.10(a):
- June 21, 1999,
 - Three years after the date on which a regulated substance is first listed under 40 CFR 68.130, or
 - The date on which a regulated substance is first present above a threshold quantity in a process.
40. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall submit any additional relevant information requested by any regulatory agency necessary to ensure compliance with the requirements of 40 CFR Part 68.
41. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall annually certify compliance with all applicable requirements of Section 112(r) as detailed in Rule 213(4)(c)). **(40 CFR Part 68)**

Emission Trading

42. Emission averaging and emission reduction credit trading are allowed pursuant to any applicable interstate or regional emission trading program that has been approved by the Administrator of the USEPA as a part of Michigan's State Implementation Plan. Such activities must comply with Rule 215 and Rule 216. **(R 336.1213(12))**

Permit to Install (PTI)

43. The process or process equipment included in this permit shall not be reconstructed, relocated, or modified unless a PTI authorizing such action is issued by the department, except to the extent such action is exempt from the PTI requirements by any applicable rule.² **(R 336.1201(1))**
44. The department may, after notice and opportunity for a hearing, revoke PTI terms or conditions if evidence indicates the process or process equipment is not performing in accordance with the terms and conditions of the PTI or is violating the department's rules or the CAA.² **(R 336.1201(8), Section 5510 of Act 451)**
45. The terms and conditions of a PTI shall apply to any person or legal entity that now or hereafter owns or operates the process or process equipment at the location authorized by the PTI. If a new owner or operator submits a written request to the department pursuant to Rule 219 and the department approves the request, this PTI will be amended to reflect the change of ownership or operational control. The request must include all of the information required by Subrules (1)(a), (b) and (c) of Rule 219. The written request shall be sent to the appropriate AQD District Supervisor, EGLE.² **(R 336.1219)**
46. If the installation, reconstruction, relocation, or modification of the equipment for which PTI terms and conditions have been approved has not commenced within 18 months of the original PTI issuance date, or has been interrupted for 18 months, the applicable terms and conditions from that PTI, as incorporated into the ROP, shall become void unless otherwise authorized by the department. Furthermore, the person to whom that PTI was issued, or the designated authorized agent, shall notify the department via the Supervisor, Permit Section, EGLE, AQD, P. O. Box 30260, Lansing, Michigan 48909, if it is decided not to pursue the installation, reconstruction, relocation, or modification of the equipment allowed by the terms and conditions from that PTI.² **(R 336.1201(4))**

Footnotes:

¹This condition is state-only enforceable and was established pursuant to Rule 201(1)(b).

²This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

B. SOURCE-WIDE CONDITIONS

Part B outlines the Source-Wide Terms and Conditions that apply to this stationary source. The permittee is subject to these special conditions for the stationary source in addition to the general conditions in Part A and any other terms and conditions contained in this ROP.

The permittee shall comply with all specific details in the special conditions and the underlying applicable requirements cited. If a specific condition type does not apply to this source, NA (not applicable) has been used in the table. If there are no Source-Wide Conditions, this section will be left blank.

C. EMISSION UNIT SPECIAL CONDITIONS

Part C outlines terms and conditions that are specific to individual emission units listed in the Emission Unit Summary Table. The permittee is subject to the special conditions for each emission unit in addition to the General Conditions in Part A and any other terms and conditions contained in this ROP.

The permittee shall comply with all specific details in the special conditions and the underlying applicable requirements cited. If a specific condition type does not apply, NA (not applicable) has been used in the table. If there are no conditions specific to individual emission units, this section will be left blank.

EMISSION UNIT SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Emission Unit ID	Emission Unit Description (Including Process Equipment & Control Device(s))	Installation Date/ Modification Date	Flexible Group ID
EUCTG11-1	Combustion Turbine Generator Peaking Unit No. 11-1 (82.4 MW). Natural gas fired, simple-cycle turbine with dry low-NOx combustor.	01-01-1998/ 10-23-2008	FGCTGS
EUCTG11-2	Combustion Turbine Generator Peaking Unit No. 11-2 (82.4 MW). Natural gas fired, simple-cycle turbine with dry low-NOx combustor.	01-01-1998/ 10-23-2008	FGCTGS
EUCTG12-1	Combustion Turbine Generator Peaking Unit No. 12-1 (82.4 MW). Natural gas fired, simple-cycle turbine with dry low-NOx combustor.	01-01-1998/ 10-23-2008	FGCTGS

D. FLEXIBLE GROUP SPECIAL CONDITIONS

Part D outlines the terms and conditions that apply to more than one emission unit. The permittee is subject to the special conditions for each flexible group in addition to the General Conditions in Part A and any other terms and conditions contained in this ROP.

The permittee shall comply with all specific details in the special conditions and the underlying applicable requirements cited. If a specific condition type does not apply, NA (not applicable) has been used in the table. If there are no special conditions that apply to more than one emission unit, this section will be left blank.

FLEXIBLE GROUP SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Flexible Group ID	Flexible Group Description	Associated Emission Unit IDs
FGCTGS	Three natural gas-fired combustion turbine generator peaking units, each nominally rated at 82.4 MW (960 MMBTU/hr) at ISO conditions and equipped with dry low-NOx combustors.	EUCTG11-1 EUCTG11-2 EUCTG12-1

FGCTGS FLEXIBLE GROUP CONDITIONS

DESCRIPTION

Three natural gas-fired combustion turbine generator peaking units, each nominally rated at 82.4 MW (960 MMBTU/hr) at ISO conditions and equipped with dry low-NOx combustors.

Emission Units: EUCTG11-1, EUCTG11-2, EUCTG12-1

POLLUTION CONTROL EQUIPMENT

The turbines are equipped with dry low-NOx combustors.

I. EMISSION LIMIT(S)

Pollutant	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. NOx	9 ppm dry gas basis at 15% O ₂ and 100% load ^{*.2}	Averaged over operating hours in a calendar day	Each turbine	SC V.1, SC V.2	R 336.1205(1)(a) and (b) 40 CFR 52.21(j) 40 CFR 60.332(a)(1)
2. NOx	100 ppmv at 15% O ₂ , dry	Hourly	Each turbine	SC V.1, SC V.2	40 CFR 60.332(a)(1)
3. NOx	522 tons per year ^{*.2}	12-month rolling total determined at the end of each calendar month	FGCTGS	SC VI.3	R 336.1205(1)(a) and (b) 40 CFR 52.21(j)
4. CO	25 ppm by volume, dry gas basis at 15%O ₂ ^{*.2}	Averaged over operating hours in a calendar day	Each turbine	SC V.2, SC V.3	R 336.1205(1) and (3) 40 CFR 52.21
5. CO	856 tons per year ^{*.2}	12-month rolling total determined at the end of each calendar month	FGCTGS	SC VI.3	R 336.1205(1) and (3) 40 CFR 52.21
6. Formaldehyde (HCHO)	9.9 tons per year ^{*.2}	12-month rolling total determined at the end of each calendar month	FGCTGS	SC V.6 SC VI.3	R 336.1205(2) R 336.1225
7. Visible emissions	10% six-minute average opacity ^{*.2}	At least once every 1,812 hours of operation	Each turbine	SC V.5	R 336.1301(1)(c), 40 CFR 52.21
8. PM10	9.0 pounds per hour ^{*.2}	Averaged over operating hours in a calendar day	Each turbine	SC V.6 SC V.8	R 336.1205(1)(a) and (b) 40 CFR 52.21(j)
9. PM10	102 tons per year ^{*.2}	12-month rolling total determined at the end of each calendar month	FGCTGS	SC V.6 SC VI.3	R 336.1205(1)(a) and (b) 40 CFR 52.21

*These emission limits do not apply during startup, shutdown, or malfunction events.

Section 2 – Combustion Turbine Generators

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

II. MATERIAL LIMIT(S)

Material	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. Natural gas	27,300 million cubic feet ²	12-month rolling total determined at the end of each calendar month	FGCTGS	SC VI.1	R 336.1205(1)(a) and (b) R 336.1225 40 CFR 52.21(j)

- No permittee subject to the provisions of 40 CFR Part 60, Subpart GG shall burn in any stationary gas turbine in FGCTGS any fuel which contains total sulfur in excess of 0.8 percent by weight (8000 ppmw). **(40 CFR 60.333(b))**

III. PROCESS/OPERATIONAL RESTRICTION(S)

- The permittee shall minimize the NOx, CO and PM10 emission rates during startup, shutdown, and malfunction conditions in accordance with the approved Emission Minimization Plan. The plan shall incorporate procedures recommended by the equipment manufacturer as well as incorporating standard industry practices. Alternate plans or modifications to the approved plan must be approved by the District Supervisor. Unless notified by the District Supervisor within 30 business days after plan submittal, the plan shall be deemed approved.² **(R 336.1911, R 336.1912, 40 CFR 52.21(j))**
- The total hours for startup and shutdown for FGCTGS shall not exceed 500 hours per turbine per 12-month rolling time period as determined at the end of each calendar month. Startup is defined as the period of time from initiation of combustion firing until the unit reaches steady state operation (i.e., when premix conditions are achieved). Shutdown is defined as that period of time from the initial lowering of the turbine output, with the intent to shut down, until the point at which the combustion process has stopped.² **(40 CFR 52.21(j))**
- The permittee shall not operate FGCTGS unless all provisions of the federal Prevention of Significant Deterioration regulations, 40 CFR 52.21, are met.² **(40 CFR 52.21)**
- The permittee shall burn only pipeline quality natural gas in FGCTGS.² **(R 336.1225, R 336.1702(a), 40 CFR 60.333(b), 40 CFR 52.21)**
- The permittee shall submit within 90 days of permit issuance, and implement and maintain, a malfunction abatement plan (MAP) as described in Rule 911(2), for each emission unit in FGCTGS. The MAP shall, at a minimum, specify the following:
 - A complete preventative maintenance program including identification of the supervisory personnel responsible for overseeing the inspection, maintenance, and repair of air-cleaning devices, a description of the items or conditions that shall be inspected, the frequency of the inspections or repairs, and an identification of the major replacement parts that shall be maintained in inventory for quick replacement.
 - An identification of the source and air-cleaning device operating variables that shall be monitored to detect a malfunction or failure, the normal operating range of these variables, and a description of the method of monitoring or surveillance procedures.
 - A description of the corrective procedures or operational changes that shall be taken in the event of a malfunction or failure to achieve compliance with the applicable emission limits.

If at any time the MAP fails to address or inadequately addresses an event that meets the characteristics of a malfunction, the permittee shall amend the MAP within 45 days after such an event occurs. The permittee shall also amend the MAP within 45 days, if new equipment is installed or upon request from the District Supervisor. The permittee shall submit the MAP and any amendments to the MAP to the AQD District Supervisor for review and approval. If the AQD does not notify the permittee within 90 days of submittal, the MAP or amended MAP shall be considered approved. Until an amended plan is approved, the permittee shall implement corrective procedures or operational changes to achieve compliance with all applicable emission limits. **(R 336.1911, R 336.1912(6))**

IV. DESIGN/EQUIPMENT PARAMETER(S)

1. The permittee shall equip and maintain each turbine included in FGCTGS with a dry low-NOx combustor.² **(R 336.1910, 40 CFR 52.21)**

V. TESTING/SAMPLING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. In accordance with 40 CFR 75, Appendix E, the permittee shall retest the NOx emission rate of each turbine at least once every 20 calendar quarters. The permittee shall perform NOx testing for at least four (4) approximately equally spaced operating load points, ranging from the maximum operating load to the minimum operating load. All testing shall be in accordance with the applicable federal Reference Methods.² **(40 CFR 60.8, 40 CFR 60.335, 40 CFR Part 60, Subpart GG, 40 CFR Part 60, Appendix A, 40 CFR 75, Appendix E, 40 CFR 75)**

2. The permittee shall verify NOx and CO emission rates from each turbine in FGCTGS by testing at owner's expense, in accordance with the Department requirements. Testing shall be performed using an approved EPA Method listed in:

Pollutant	Test Method Reference
NOx	40 CFR Part 60, Appendix A
CO	40 CFR Part 60, Appendix A

In accordance with 40 CFR 75, Appendix E, the permittee shall retest the NOx emission rate of each turbine at least once every 12 calendar quarters. The permittee shall perform NOx and CO testing for at least four (4) approximately equally spaced operating load points, ranging from the maximum operating load to the minimum operating load. An alternate method, or a modification to the approved EPA Method, may be specified in an AQD approved Test Protocol and must meet the requirements of the federal Clean Air Act, all applicable state and federal rules and regulations, and be within the authority of the AQD to make the change. No less than 30 days prior to testing, the permittee shall submit a complete test plan to the AQD Technical Programs Unit and District Office. The AQD must approve the final plan prior to testing, including any modifications to the method in the test protocol that are proposed after initial submittal. The permittee must submit a complete report of the test results to the AQD Technical Programs Unit and District Office within 60 days following the last date of the test. **(R 336.1213(3), R 336.2001, R 336.2003, R 336.2004, 40 CFR 60.335)**

3. The permittee shall verify CO emission rates from each turbine in accordance with Department requirements. Testing must be done for each turbine in conjunction with NOx testing and under the same operating load and test averaging period requirements.² **(R 336.2001, R 336.2003, R 336.2004)**
4. Compliance with the visible emissions limit shall be determined at least once per 1,812 hours of operation per turbine using Federal Reference Method 9 (40 CFR Part 60, Appendix A).² **(R 336.1301, 40 CFR 52.21)**
5. Emission factors developed from previous formaldehyde and PM10 stack test will be used along with hourly fuel usage data to demonstrate compliance with annual limits.² **(R 336.2001, R 336.2003, R 336.2004)**
6. Within 180 days after permit issuance, the permittee shall verify formaldehyde and PM10 emission rates from each turbine or a representative turbine in FGCTGS by testing at owner's expense, in accordance with the Department requirements. Testing shall be performed using an approved USEPA Method listed in:

Pollutant	Test Method Reference
PM10	40 CFR Part 51, Appendix M
HAPs	40 CFR Part 63, Appendix A

An alternate method, or a modification to the approved USEPA Method, may be specified in an AQD-approved Test Protocol and must meet the requirements of the federal Clean Air Act, all applicable state and federal rules and regulations, and be within the authority of the AQD to make the change. No less than 30 days prior to testing, the permittee shall submit a complete test plan to the AQD Technical Programs Unit and District Office. The AQD must approve the final plan prior to testing, including any modifications to the method in the test protocol that are proposed after initial submittal. The permittee must submit a complete report of the test results to the AQD Technical Programs Unit and District Office within 60 days following the last date of the test. **(R 336.1213(3), R 336.2001, R 336.2003, R 336.2004)**

7. The permittee shall verify the NO_x and CO emission rates from FGCTGS, at a minimum, every three years from the date of the last test. **(R 336.1213(3), R 336.2001, R 336.2003, R 336.2004)**
8. The permittee shall verify the formaldehyde and PM₁₀ emission rates from each turbine or a representative turbine in FGCTGS, at a minimum, every five years from the date of the last test. **(R 336.1213(3), R 336.2001, R 336.2003, R 336.2004)**
9. The permittee shall notify the AQD Technical Programs Unit Supervisor and the District Supervisor not less than 30 days before testing of the time and place performance tests will be conducted. **(R 336.1213(3))**

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall continuously monitor, and record hourly, the natural gas usage from each turbine included in FGCTGS in a manner and with instrumentation acceptable to the District Supervisor, Air Quality Division.² **(R 336.1205(1)(a) and (b), 40 CFR 52.21)**
2. The permittee shall record the total number of start-up and shutdown hours per month for each turbine included in FGCTGS. Startup and shutdown hours are defined as those periods of time in which the turbine is not operating in a premix mode of operation.² **(R 336.1201(3))**
3. The permittee shall keep records, for each turbine included in FGCTGS, of the calendar day average, monthly, and previous 12-month emission calculations for the following pollutants:
 - a. NO_x **(R 336.1205(1)(a) and (b), 40 CFR 52.21, 40 CFR Part 60, Subpart GG)**
 - b. CO **(R 336.1205(1)(a) and (b), 40 CFR 52.21)**
 - c. PM₁₀ **(R 336.1205(1)(a) and (b), 40 CFR 52.21)**
 - d. HCHO **(R 336.1205(2), R 336.1225)**

All such records and calculations are for the purpose of compliance demonstration shall be kept on file and made available to the AQD upon request.²

4. Results of the visible emission readings shall be kept on file and made available to the AQD upon request.² **(R 336.1301, 40 CFR 52.21)**
5. The permittee shall monitor and record the capacity factor of each turbine included in FGCTGS each calendar year. If the capacity factor for each individual turbine exceeds 20 percent in any calendar year, or exceeds 10 percent averaged over the previous three calendar years, a continuous emission monitor for NO_x must be installed, certified and operated no later than December 31 of the following calendar year. These records shall be kept on file and made available to the AQD upon request.² **(40 CFR 52.21, 40 CFR 75.12(c)(2))**
6. The permittee shall keep records in a satisfactory manner, of the total sulfur content of the fuel being fired in FGCTGS. Records demonstrating that the fuel meets the definition of natural gas in 40 CFR 60.331(u) include the gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less. These records shall be kept on file and made available to the AQD upon request. **(40 CFR 60.334(h)(1) and (3))**

Section 2 – Combustion Turbine Generators

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

7. The permittee shall maintain, in a satisfactory manner, maintenance records for each emission unit in FGCTGS. The permittee shall keep all records on file and make them available to the Department upon request. **(R 336.1213(3))**
8. If the permittee elects under 40 CFR 60.334(f) to monitor combustion parameters or parameters indicative of proper operation of NOx emission controls, the appropriate parameters shall be continuously monitored and recorded during each run of the initial (and subsequent) performance tests, to establish acceptable operating ranges, for purposes of the parameter monitoring plan for the affected unit, as specified in 40 CFR 60.334(g). **(R 336.1213(3), 40 CFR 60.335(b)(8))**

See Appendices 3-2 and 7-2

VII. REPORTING

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
4. The permittee shall submit any performance test reports to the AQD Technical Programs Unit and District Office, in a format approved by the AQD. **(R 336.1213(3)(c), R 336.2001(5))**

See Appendix 8-2

VIII. STACK/VENT RESTRICTION(S)

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Diameter / Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SV-CTG-111	228 x 108 ²	56 ²	R 336.1225 40 CFR 52.21(c) and (d)
2. SV-CTG-112	228 x 108 ²	56 ²	R 336.1225 40 CFR 52.21(c) and (d)
3. SV-CTG-121	228 x 108 ²	56 ²	R 336.1225 40 CFR 52.21(c) and (d)

IX. OTHER REQUIREMENT(S)

1. The permittee shall comply with all provisions of the federal Standards of Performance for New Stationary Sources as specified in 40 CFR Part 60, Subparts A and GG. **(40 CFR Part 60, Subparts A and GG)**
2. The permittee shall comply with all applicable requirements of the National Emission Standards for Hazardous Air Pollutants, as specified in 40 CFR Part 63, Subparts A and YYYY for Stationary Combustion Turbines. **(40 CFR 63.6090(b)(4), 40 CFR Part 63, Subparts A and YYYY)**
3. The permittee shall comply with the acid rain permitting provisions of 40 CFR 72.1 to 72.94, as outlined in a complete Phase II, Acid Rain Permit issued by the AQD. Phase II, Acid Rain Permit No. MI-AR-6035-2024 is hereby incorporated into this ROP as Appendix 9-2. **(R 336.1902(1)(p))**
4. The permittee shall not allow the emission of an air pollutant to exceed the amount of any emission allowances that an affected source lawfully holds as of the allowance transfer deadline pursuant to R 336.1902(1)(p) and 40 CFR 72.9(c)(1)(i). **(R 336.1213(10))**
5. The permittee shall comply with the provisions of the Cross-State Air Pollution Rule NO_x Annual Trading Program, as specified in 40 CFR Part 97, Subpart AAAAA, and identified in Appendix 10-2. **(40 CFR Part 97, Subpart AAAAA)**
6. The permittee shall comply with the provisions of the Cross-State Air Pollution Rule NO_x Ozone Season Group 3 Trading program, as specified in 40 CFR Part 97, Subpart GGGGG, and identified in Appendix 10-2. **(40 CFR Part 97, Subpart GGGGG)**
7. The permittee shall comply with the provisions of the Cross-State Air Pollution Rule SO₂ Group 1 Trading Program, as specified in 40 CFR Part 97, Subpart CCCCC, and identified in Appendix 10-2. **(40 CFR Part 97, Subpart CCCCC)**

Footnotes:

¹ This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

² This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

E. NON-APPLICABLE REQUIREMENTS

At the time of the ROP issuance, the AQD has determined that no non-applicable requirements have been identified for incorporation into the permit shield provision set forth in the General Conditions in Part A pursuant to Rule 213(6)(a)(ii).

APPENDICES

Appendix 1-2. Acronyms and Abbreviations

Common Acronyms		Pollutant / Measurement Abbreviations	
AQD	Air Quality Division	acfm	Actual cubic feet per minute
BACT	Best Available Control Technology	BTU	British Thermal Unit
CAA	Clean Air Act	°C	Degrees Celsius
CAM	Compliance Assurance Monitoring	CO	Carbon Monoxide
CEM	Continuous Emission Monitoring	CO ₂ e	Carbon Dioxide Equivalent
CEMS	Continuous Emission Monitoring System	dscf	Dry standard cubic foot
CFR	Code of Federal Regulations	dscm	Dry standard cubic meter
COM	Continuous Opacity Monitoring	°F	Degrees Fahrenheit
Department/ department	Michigan Department of Environment, Great Lakes, and Energy	gr	Grains
EGLE	Michigan Department of Environment, Great Lakes, and Energy	HAP	Hazardous Air Pollutant
EU	Emission Unit	Hg	Mercury
FG	Flexible Group	hr	Hour
GACS	Gallons of Applied Coating Solids	HP	Horsepower
GC	General Condition	H ₂ S	Hydrogen Sulfide
GHGs	Greenhouse Gases	kW	Kilowatt
HVLP	High Volume Low Pressure*	lb	Pound
ID	Identification	m	Meter
IRSL	Initial Risk Screening Level	mg	Milligram
ITSL	Initial Threshold Screening Level	mm	Millimeter
LAER	Lowest Achievable Emission Rate	MM	Million
MACT	Maximum Achievable Control Technology	MW	Megawatts
MAERS	Michigan Air Emissions Reporting System	NMOC	Non-methane Organic Compounds
MAP	Malfunction Abatement Plan	NO _x	Oxides of Nitrogen
MSDS	Material Safety Data Sheet	ng	Nanogram
NA	Not Applicable	PM	Particulate Matter
NAAQS	National Ambient Air Quality Standards	PM10	Particulate Matter equal to or less than 10 microns in diameter
NESHAP	National Emission Standard for Hazardous Air Pollutants	PM2.5	Particulate Matter equal to or less than 2.5 microns in diameter
NSPS	New Source Performance Standards	pph	Pounds per hour
NSR	New Source Review	ppm	Parts per million
PS	Performance Specification	ppmv	Parts per million by volume
PSD	Prevention of Significant Deterioration	ppmw	Parts per million by weight
PTE	Permanent Total Enclosure	%	Percent
PTI	Permit to Install	psia	Pounds per square inch absolute
RACT	Reasonable Available Control Technology	psig	Pounds per square inch gauge
ROP	Renewable Operating Permit	scf	Standard cubic feet
SC	Special Condition	sec	Seconds
SCR	Selective Catalytic Reduction	SO ₂	Sulfur Dioxide
SDS	Safety Data Sheet	TAC	Toxic Air Contaminant
SNCR	Selective Non-Catalytic Reduction	Temp	Temperature
SRN	State Registration Number	THC	Total Hydrocarbons
TEQ	Toxicity Equivalence Quotient	tpy	Tons per year
USEPA/EPA	United States Environmental Protection Agency	µg	Microgram
VE	Visible Emissions	µm	Micrometer or Micron
		VOC	Volatile Organic Compounds
		yr	Year

*For HVLP applicators, the pressure measured at the gun air cap shall not exceed 10 psig.

Appendix 2-2. Schedule of Compliance

The permittee certified in the ROP application that this stationary source is in compliance with all applicable requirements and the permittee shall continue to comply with all terms and conditions of this ROP. A Schedule of Compliance is not required. (R 336.1213(4)(a), R 336.1119(a)(ii))

Appendix 3-2. Monitoring Requirements

Specific monitoring requirement procedures, methods or specifications are detailed in Part A or the appropriate Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Therefore, this appendix is not applicable.

Appendix 4-2. Recordkeeping

Specific recordkeeping requirement formats and procedures are detailed in Part A or the appropriate Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Therefore, this appendix is not applicable.

Appendix 5-2. Testing Procedures

Specific testing requirement plans, procedures, and averaging times are detailed in the appropriate Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Therefore, this appendix is not applicable.

Appendix 6-2. Permits to Install

The following table lists any PTIs issued or ROP revision applications received since the effective date of the previously issued ROP No. MI-ROP-B6145-2018. Those ROP revision applications that are being issued concurrently with this ROP renewal are identified by an asterisk (*). Those revision applications not listed with an asterisk were processed prior to this renewal.

Source-Wide PTI No MI-PTI-B6145-2018 is being reissued as Source-Wide PTI No. MI-PTI-B6145-2024.

Permit to Install Number	ROP Revision Application Number	Description of Equipment or Change	Corresponding Emission Unit(s) or Flexible Group(s)
NA	NA	NA	NA

Appendix 7-2. Emission Calculations

The permittee shall use the following calculations in conjunction with monitoring, testing or recordkeeping data to determine compliance with the applicable requirements referenced in FGCTGS and as described in the “Continuous Compliance Protocol” for Greenwood the CTG Units (Rev. July 12, 1999).

Natural gas usage is monitored continuously but recorded once per hour and tracked on a monthly basis.

The NOx and CO, calendar day ppmv limits are assured by the latest stack testing results. The worst case concentration data (in ppmv) from the tested operating loads are compared to permit limits.

Section 2 – Combustion Turbine Generators

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

From stack testing, emission factors for CO, PM10 and formaldehyde are developed in lbs. pollutant/million cubic feet of natural gas for each corresponding load specified in stack test protocol. Emission factors for each pollutant are calculated using the emissions recorded during the last representative stack test on a pollutant-specific basis. The emission factors, along with the fuel monitoring requirement, shall be applied to each hour to ensure compliance with PM10 calendar day average and CO, PM10 and formaldehyde rolling 12-month period emission limits.

From stack testing at the four load points, correlation curves are developed from NOx emissions (lb/MMBTU) and heat input (MMBTU/hr) for each CTG. Consistent with Part 75, Appendix E, a NOx emission rate (lb/MMBTU) is applied to each operating hour. Each QA-QC validated hour either has the NOx emission rate from the correlation curve applied or the appropriate substitute NOx emission rate applied if the hour is outside operational and control equipment parameters, per Appendix E, section 2.5.2. The product of the hourly NOx emission rates and heat inputs are aggregated monthly to report the tons of NOx on a rolling 12-month basis.

Appendix 8-2. Reporting

A. Annual, Semiannual, and Deviation Certification Reporting

The permittee shall use EGLE, AQD, Report Certification form (EQP 5736) and EGLE, AQD, Deviation Report form (EQP 5737) for the annual, semiannual and deviation certification reporting referenced in the Reporting Section of the Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Alternative formats must meet the provisions of Rule 213(4)(c) and Rule 213(3)(c)(i), respectively, and be approved by the AQD District Supervisor.

B. Other Reporting

Specific reporting requirement formats and procedures are detailed in Part A or the appropriate Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Therefore, Part B of this appendix is not applicable.

Appendix 9-2. Acid Rain Permit

**PHASE II ACID RAIN PERMIT
Permit No. MI-AR-6035-2024**

Permittee	Greenwood Energy Center
Address	7000 Kilgore Road, Avoca, MI
SRN	B6145
Plant Code	6035
Issue Date	June 30, 2024
Effective	Issuance date of this facility’s Renewable Operating Permit at the facility in accordance with 40 CFR 72.73.
Expiration	This permit shall expire when the facility’s Renewable Operating Permit expires, in accordance with 40 CFR 72.73.
ROP No.	MI-ROP-B6145-2024

The Acid Rain Permit Contents

1. A statement of basis prepared by the Air Quality Division (AQD) containing:

References to statutory and regulatory authorities, and with comments, notes, and justification that apply to the source in general.
2. Terms and conditions including:

A table of sulfur dioxide allowances to be allocated during the term of the permit, if applicable, authorized by this permit during Phase II. Unless they are subject to Sections 405(g)(2) or (3) of the federal Clean Air Act, new units are not allocated allowances in 40 CFR Part 73 and must obtain allowances by other means (Section 403(e) of the federal Clean Air Act);

Comments, notes and justifications regarding permit decisions and changes made to the permit application forms during the review process, and any additional requirements; and,

Any applicable nitrogen oxides compliance plan. Unless they are coal fired utility units regulated pursuant to Sections 404, 405, or 409 of the federal Clean Air Act, new units are not subject to the acid rain nitrogen oxides requirements (40 CFR 76.1(a)).
3. The permit application that this source submitted, as corrected by the AQD. The owners and operators of the source must comply with the standard requirements and special provisions set forth in the application.

Statement of Basis

Statutory and Regulatory Authorities.

In accordance with the Natural Resources and Environmental Protection Act, 1994 PA 451 and Titles IV and V of the federal Clean Air Act, the Michigan Department of Environment, Great Lakes, and Energy, Air Quality Division (AQD), issues this permit pursuant to the provisions of R 336.1210 to R 336.1218, and R 336.1902(1)(q).

For further information contact:

Mr. Brian Carley
Environmental Quality Specialist
Michigan Department of Environment, Great Lakes, and Energy
Air Quality Division, Jackson District Office
State Office Building, 4th Floor
301 East Louis B. Glick Highway
Jackson, Michigan 49201-1556

Telephone: 517-416-4631

Facsimile: 517-780-7855

There are no comments, notes and/or justification that apply to the source in general for this section.

Section 2 – Combustion Turbine Generators

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

Terms and Conditions:

Phase II Sulfur Dioxide Allowance Allocation and Nitrogen Oxides Requirements for each affected unit.

		2024	2025	2026	2027	2028
Unit 1	SO ₂ allowances	541	541	541	541	541

		2024	2025	2026	2027	2028
Unit CTG 11-1	SO ₂ allowances	This affected unit shall hold allowances, as of the allowance transfer deadline, in the source's compliance account (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the affected units at the source; and comply with the applicable Acid Rain emissions limitation for sulfur dioxide in accordance with 40 CFR 72.9 (c).				

		2024	2025	2026	2027	2028
Unit CTG 11-2	SO ₂ allowances	This affected unit shall hold allowances, as of the allowance transfer deadline, in the source's compliance account (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the affected units at the source; and comply with the applicable Acid Rain emissions limitation for sulfur dioxide in accordance with 40 CFR 72.9 (c).				

		2024	2025	2026	2027	2028
Unit CTG 12-1	SO ₂ allowances	This affected unit shall hold allowances, as of the allowance transfer deadline, in the source's compliance account (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the affected units at the source; and comply with the applicable Acid Rain emissions limitation for sulfur dioxide in accordance with 40 CFR 72.9 (c).				

Comments, notes and justifications regarding permit decisions, and changes made to the permit application forms during the review process:

Permit Application: (attached)

Acid Rain Permit Application submitted August 23, 2022

Section 2 – Combustion Turbine Generators

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024



United States
Environmental Protection Agency
Acid Rain Program

OMB No. 2060-0258
Approval Expires 12/31/2021

Acid Rain Permit Application

For more information, see Instructions and 40 CFR 72.30 and 72.31

This submission is: new revised for ARP permit renewal

STEP 1

Identify the facility name, State, and plant (ORIS) code.

DTE Electric – Greenwood Energy Center	MI	6035
Facility (Source) Name		

STEP 2

Enter the unit ID# for every affected unit at the affected source in column "a."

a	b
Unit ID#	Unit Will Hold Allowances in Accordance with 40 CFR 72.9(e)(1)
1	Yes
CTG 11-1	Yes
CTG 11-2	Yes
CTG 12-1	Yes

STEP 3

Read the standard requirements.

Permit Requirements

- (1) The designated representative of each affected source and each affected unit at the source shall:
 - (i) Submit a complete Acid Rain permit application (including a compliance plan) under 40 CFR part 72 in accordance with the deadlines specified in 40 CFR 72.30; and
 - (ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary in order to review an Acid Rain permit application and issue or deny an Acid Rain permit;
- (2) The owners and operators of each affected source and each affected unit at the source shall:
 - (i) Operate the unit in compliance with a complete Acid Rain permit application or a superseding Acid Rain permit issued by the permitting authority; and
 - (ii) Have an Acid Rain Permit.

Monitoring Requirements

- (1) The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the source or unit, as appropriate, with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

Sulfur Dioxide Requirements

- (1) The owners and operators of each source and each affected unit at the source shall:
 - (i) Hold allowances, as of the allowance transfer deadline, in the source's compliance account (after deductions under 40 CFR 73.34(c)), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the affected units at the source; and
 - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An affected unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
 - (i) Starting January 1, 2000, an affected unit under 40 CFR 72.6(a)(2); or

Section 2 – Combustion Turbine Generators

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

DTE Electric – Greenwood Energy Center Facility (Source) Name (from STEP 1)	Acid Rain Permit – Page 2 of 3
---------------------------------------------------------------------------------------	--------------------------------

- (ii) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements

The owners and operators of the source and each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements

- (1) The designated representative of an affected source that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77.
- (2) The owners and operators of an affected source that has excess emissions in any calendar year shall:
 - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR part 77; and
 - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77.

Recordkeeping and Reporting Requirements

- (1) Unless otherwise provided, the owners and operators of the source and each affected unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the Administrator or permitting authority:
 - (i) The certificate of representation for the designated representative for the source and each affected unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
 - (ii) All emissions monitoring information, in accordance with 40 CFR part 75, provided that to the extent that 40 CFR part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply.
 - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,
 - (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.
- (2) The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR part 72 subpart I and 40 CFR part 75.

Liability

- (1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
- (2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
- (3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
- (4) Each affected source and each affected unit shall meet the requirements of the Acid Rain Program.

Section 2 – Combustion Turbine Generators

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

DTE Electric – Greenwood Energy Center
Facility (Source) Name (from STEP 1)

Acid Rain Permit – Page 3 of 3

- (5) Any provision of the Acid Rain Program that applies to an affected source (including a provision applicable to the designated representative of an affected source) shall also apply to the owners and operators of such source and of the affected units at the source.
- (6) Any provision of the Acid Rain Program that applies to an affected unit (including a provision applicable to the designated representative of an affected unit) shall also apply to the owners and operators of such unit.
- (7) Each violation of a provision of 40 CFR parts 72, 73, 74, 75, 76, 77, and 78 by an affected source or affected unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities

No provision of the Acid Rain Program, an Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 shall be construed as:

- (1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an affected source or affected unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;
- (2) Limiting the number of allowances a source can hold; provided, that the number of allowances held by the source shall not affect the source's obligation to comply with any other provisions of the Act;
- (3) Requiring a change of any kind in any State law regulating electric utility rates and charges, affecting any State law regarding such State regulation, or limiting such State regulation, including any prudence review requirements under such State law;
- (4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
- (5) Interfering with or impairing any program for competitive bidding for power supply in a State in which such program is established.

STEP 4

Read the certification statement, sign, and date.

Certification

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name: Mr. Benjamin F. Felton, Senior VP – Energy Supply

Signature:



Date:

7/27/2022

Appendix 10-2. Cross-State Air Pollution Rule (CSAPR) Trading Program Title V Requirements

Description of CSAPR Monitoring Provisions

The CSAPR subject units, and the unit-specific monitoring provisions, at this source are identified in the following tables. These units are subject to the requirements for the CSAPR NO_x Annual Trading Program, CSAPR NO_x Ozone Season Group 3 Trading Program, and CSAPR SO₂ Group 1 Trading Program, which are included below as Sections I, II, and III, respectively.

Each unit will use one of the following as the monitoring methodology for each parameter as provided below and shall comply with the general monitoring, recordkeeping, reporting and other requirements in conditions 1 through 5 below and in paragraph (b) of Sections I, II, and III:

- Continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR Part 75, Subpart B (for SO₂ monitoring) or 40 CFR Part 75, Subpart H (for NO_x monitoring)
- Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR Part 75, Appendix D
- Excepted monitoring system requirements for gas- and oil-fired peaking units pursuant to 40 CFR Part 75, Appendix E
- Low Mass Emissions excepted monitoring (LME) requirements for gas- and oil-fired units pursuant to 40 CFR 75.19
- EPA-approved alternative monitoring system requirements pursuant to 40 CFR Part 75, Subpart E

Unit ID: Unit 1 {EUBOILER1}	
Parameter	Monitoring Methodology
SO ₂	CEMS requirements pursuant to 40 CFR Part 75, Subpart B
NO _x	CEMS requirements pursuant to 40 CFR Part 75, Subpart H
Heat Input	CEMS requirements pursuant to 40 CFR Part 75, Subpart B and 40 CFR Part 75, Subpart H

Unit ID: CTG 11-1 {EUCTG11-1}	
Parameter	Monitoring Methodology
SO ₂	Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR Part 75, Appendix D
NO _x	Excepted monitoring system requirements for gas- and oil-fired peaking units pursuant to 40 CFR Part 75, Appendix E
Heat Input	Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR Part 75, Appendix D

Unit ID: CTG 11-2 {EUCTG11-2}	
Parameter	Monitoring Methodology
SO ₂	Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR Part 75, Appendix D
NO _x	Excepted monitoring system requirements for gas- and oil-fired peaking units pursuant to 40 CFR Part 75, Appendix E
Heat Input	Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR Part 75, Appendix D

Unit ID: CTG 12-1 {EUCTG12-1}	
Parameter	Monitoring Methodology
SO ₂	Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR Part 75, Appendix D
NO _x	Excepted monitoring system requirements for gas- and oil-fired peaking units pursuant to 40 CFR Part 75, Appendix E
Heat Input	Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR Part 75, Appendix D

Section 2 – Combustion Turbine Generators

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

1. The above description of the monitoring used by a unit does not change, create an exemption from, or otherwise affect the monitoring, recordkeeping, and reporting requirements applicable to the unit under 40 CFR 97.430 through 97.435 (CSAPR NO_x Annual Trading Program), 97.1030 through 97.1035 (CSAPR NO_x Ozone Season Group 3 Trading Program), and 97.630 through 97.635 (CSAPR SO₂ Group 1 Trading Program). The monitoring, recordkeeping and reporting requirements applicable to each unit are included below in the standard conditions for the applicable CSAPR trading programs.
2. Owners and operators must submit to the Administrator a monitoring plan for each unit in accordance with 40 CFR 75.53, 75.62 and 75.73, as applicable. The monitoring plan for each unit is available at the EPA's website at <https://www.epa.gov/airmarkets/monitoring-plans-part-75-sources>.
3. Owners and operators that want to use an alternative monitoring system must submit to the Administrator a petition requesting approval of the alternative monitoring system in accordance with 40 CFR Part 75, Subpart E and 40 CFR 75.66 and 97.435 (CSAPR NO_x Annual Trading Program), 97.1035 (CSAPR NO_x Ozone Season Group 3 Trading Program), and/or 97.635 (CSAPR SO₂ Group 1 Trading Program). The Administrator's response approving or disapproving any petition for an alternative monitoring system is available on the EPA's website at <https://www.epa.gov/airmarkets/part-75-petition-responses>.
4. Owners and operators that want to use an alternative to any monitoring, recordkeeping, or reporting requirement under 40 CFR 97.430 through 97.434 (CSAPR NO_x Annual Trading Program), 97.1030 through 97.1034 (CSAPR NO_x Ozone Season Group 3 Trading Program), and/or 97.630 through 97.634 (CSAPR SO₂ Group 1 Trading Program) must submit to the Administrator a petition requesting approval of the alternative in accordance with 40 CFR 75.66 and 97.435 (CSAPR NO_x Annual Trading Program), 97.1035 (CSAPR NO_x Ozone Season Group 3 Trading Program), and/or 97.635 (CSAPR SO₂ Group 1 Trading Program). The Administrator's response approving or disapproving any petition for an alternative to a monitoring, recordkeeping, or reporting requirement is available on the EPA's website at <https://www.epa.gov/airmarkets/part-75-petition-responses>.
5. The descriptions of monitoring applicable to the unit included above meet the requirement of 40 CFR 97.430 through 97.434 (CSAPR NO_x Annual Trading Program), 97.1030 through 97.1034 (CSAPR NO_x Ozone Season Group 3 Trading Program), and 97.630 through 97.634 (CSAPR SO₂ Group 1 Trading Program), and therefore minor permit modification procedures, in accordance with 40 CFR 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B), may be used to add or change this unit's monitoring system description.

SECTION I: CSAPR NO_x Annual Trading Program requirements (40 CFR 97.406)

(a) Designated representative requirements.

The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.413 through 97.418.

(b) Emissions monitoring, reporting, and recordkeeping requirements.

- (3) The owners and operators, and the designated representative, of each CSAPR NO_x Annual source and each CSAPR NO_x Annual unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.430 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.431 (initial monitoring system certification and recertification procedures), 97.432 (monitoring system out-of-control periods), 97.433 (notifications concerning monitoring), 97.434 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.435 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).

- (1) The emissions data determined in accordance with 40 CFR 97.430 through 97.435 shall be used to calculate allocations of CSAPR NO_x Annual allowances under 40 CFR 97.411(a)(2) and (b) and 97.412 and to determine compliance with the CSAPR NO_x Annual emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.430 through 97.435 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

(c) NO_x emissions requirements.

- (1) CSAPR NO_x Annual emissions limitation.
 - (i). As of the allowance transfer deadline for a control period in a given year, the owners and operators of each CSAPR NO_x Annual source and each CSAPR NO_x Annual unit at the source shall hold, in the source's compliance account, CSAPR NO_x Annual allowances available for deduction for such control period under 40 CFR 97.424(a) in an amount not less than the tons of total NO_x emissions for such control period from all CSAPR NO_x Annual units at the source.
 - (ii). If total NO_x emissions during a control period in a given year from the CSAPR NO_x Annual units at a CSAPR NO_x Annual source are in excess of the CSAPR NO_x Annual emissions limitation set forth in paragraph (c)(1)(i) above, then:
 - (A). The owners and operators of the source and each CSAPR NO_x Annual unit at the source shall hold the CSAPR NO_x Annual allowances required for deduction under 40 CFR 97.424(d); and
 - (B). The owners and operators of the source and each CSAPR NO_x Annual unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart AAAAA and the Clean Air Act.
- (2) CSAPR NO_x Annual assurance provisions.
 - (i). If total NO_x emissions during a control period in a given year from all CSAPR NO_x Annual units at CSAPR NO_x Annual sources in the state and Indian country within the borders of such State exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such NO_x emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) CSAPR NO_x Annual allowances available for deduction for such control period under 40 CFR 97.425(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.425(b), of multiplying— (A) The quotient of the amount by which the common designated representative's share of such NO_x emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state and Indian country within the borders of such state for such control period, by which each common designated representative's share of such NO_x emissions exceeds the respective common designated representative's assurance level; and (B) The amount by which total NO_x emissions from all CSAPR NO_x Annual units at CSAPR NO_x Annual sources in the state and Indian country within the borders of such state for such control period exceed the state assurance level.
 - (ii). The owners and operators shall hold the CSAPR NO_x Annual allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.

Section 2 – Combustion Turbine Generators

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

- (iii). Total NO_x emissions from all CSAPR NO_x Annual units at CSAPR NO_x Annual sources in the State and Indian country within the borders of such state during a control period in a given year exceed the state assurance level if such total NO_x emissions exceed the sum, for such control period, of the state NO_x Annual trading budget under 40 CFR 97.410(a) and the state's variability limit under 40 CFR 97.410(b).
- (iv). It shall not be a violation of 40 CFR Part 97, Subpart AAAAA or of the Clean Air Act if total NO_x emissions from all CSAPR NO_x Annual units at CSAPR NO_x Annual sources in the State and Indian country within the borders of such State during a control period exceed the state assurance level or if a common designated representative's share of total NO_x emissions from the CSAPR NO_x Annual units at CSAPR NO_x Annual sources in the state and Indian country within the borders of such state during a control period exceeds the common designated representative's assurance level.
- (v). To the extent the owners and operators fail to hold CSAPR NO_x Annual allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,
 - (A). The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and
 - (B). Each CSAPR NO_x Annual allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart AAAAA and the Clean Air Act.
- (3) Compliance periods.
 - (i). A CSAPR NO_x Annual unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of January 1, 2015, or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.430(b) and for each control period thereafter.
 - (ii). A CSAPR NO_x Annual unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting on the later of January 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.430(b) and for each control period thereafter.
- (4) Vintage of allowances held for compliance.
 - (i). A CSAPR NO_x Annual allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a CSAPR NO_x Annual allowance that was allocated for such control period or a control period in a prior year.
 - (ii). A CSAPR NO_x Annual allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a CSAPR NO_x Annual allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.
- (5) Allowance Management System requirements. Each CSAPR NO_x Annual allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR Part 97, Subpart AAAAA.
- (6) Limited authorization. A CSAPR NO_x Annual allowance is a limited authorization to emit one ton of NO_x during the control period in one year. Such authorization is limited in its use and duration as follows:
 - (i). Such authorization shall only be used in accordance with the CSAPR NO_x Annual Trading Program; and
 - (ii). Notwithstanding any other provision of 40 CFR Part 97, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.
- (7) Property right. A CSAPR NO_x Annual allowance does not constitute a property right.

(d) Title V permit revision requirements.

- (1) No title V permit revision shall be required for any allocation, holding, deduction, or transfer of CSAPR NO_x Annual allowances in accordance with 40 CFR Part 97, Subpart AAAAA.

- (2) This permit incorporates the CSAPR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.430 through 97.435, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR Part 75, Subparts B and H), an excepted monitoring system (pursuant to 40 CFR Part 75, Appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR 75.19), and an alternative monitoring system (pursuant to 40 CFR Part 75, Subpart E). Therefore, the Description of CSAPR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.406(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).

(e) Additional recordkeeping and reporting requirements.

- (1) Unless otherwise provided, the owners and operators of each CSAPR NO_x Annual source and each CSAPR NO_x Annual unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
- (i). The certificate of representation under 40 CFR 97.416 for the designated representative for the source and each CSAPR NO_x Annual unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.416 changing the designated representative.
 - (ii). All emissions monitoring information, in accordance with 40 CFR Part 97, Subpart AAAAA.
 - (iii). Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the CSAPR NO_x Annual Trading Program.
- (2) The designated representative of a CSAPR NO_x Annual source and each CSAPR NO_x Annual unit at the source shall make all submissions required under the CSAPR NO_x Annual Trading Program, except as provided in 40 CFR 97.418. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR Parts 70 and 71.

(f) Liability.

- (1) Any provision of the CSAPR NO_x Annual Trading Program that applies to a CSAPR NO_x Annual source or the designated representative of a CSAPR NO_x Annual source shall also apply to the owners and operators of such source and of the CSAPR NO_x Annual units at the source.
- (2) Any provision of the CSAPR NO_x Annual Trading Program that applies to a CSAPR NO_x Annual unit or the designated representative of a CSAPR NO_x Annual unit shall also apply to the owners and operators of such unit.

(g) Effect on other authorities.

No provision of the CSAPR NO_x Annual Trading Program or exemption under 40 CFR 97.405 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a CSAPR NO_x Annual source or CSAPR NO_x Annual unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

(h) Effect on units in Indian country.

Notwithstanding the provisions of paragraphs (a) through (g) above, paragraphs (a) through (g) shall be deemed not to impose any requirements on any source or unit, or any owner, operator, or designated representative with regard to any source or unit, in Indian country within the borders of the state.

SECTION II: CSAPR NO_x Ozone Season Group 3 Trading Program Requirements (40 CFR 97.1006)**(a) Designated representative requirements.**

The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.813 through 97.818.

(b) Emissions monitoring, reporting, and recordkeeping requirements.

- (1) The owners and operators, and the designated representative, of each CSAPR NO_x Ozone Season Group 3 source and each CSAPR NO_x Ozone Season Group 3 unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.830 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.831 (initial monitoring system certification and recertification procedures), 97.832 (monitoring system out-of-control periods), 97.833 (notifications concerning monitoring), 97.834 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.835 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).
- (2) The emissions data determined in accordance with 40 CFR 97.830 through 97.835 shall be used to calculate allocations of CSAPR NO_x Ozone Season Group 3 allowances under 40 CFR 97.811(a)(2) and (b) and 97.812 and to determine compliance with the CSAPR NO_x Ozone Season Group 3 emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.830 through 97.835 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

(c) NO_x emissions requirements.

- (1) CSAPR NO_x Ozone Season Group 3 emissions limitation.
 - (i). As of the allowance transfer deadline for a control period in a given year, the owners and operators of each CSAPR NO_x Ozone Season Group 3 source and each CSAPR NO_x Ozone Season Group 3 unit at the source shall hold, in the source's compliance account, CSAPR NO_x Ozone Season Group 3 allowances available for deduction for such control period under 40 CFR 97.824(a) in an amount not less than the tons of total NO_x emissions for such control period from all CSAPR NO_x Ozone Season Group 3 units at the source.
 - (ii). If total NO_x emissions during a control period in a given year from the CSAPR NO_x Ozone Season Group 3 units at a CSAPR NO_x Ozone Season Group 3 source are in excess of the CSAPR NO_x Ozone Season Group 3 emissions limitation set forth in paragraph (c)(1)(i) above, then:
 - (A). The owners and operators of the source and each CSAPR NO_x Ozone Season Group 3 unit at the source shall hold the CSAPR NO_x Ozone Season Group 3 allowances required for deduction under 40 CFR 97.824(d); and
 - (B). The owners and operators of the source and each CSAPR NO_x Ozone Season Group 3 unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart GGGGG and the Clean Air Act.
- (2) CSAPR NO_x Ozone Season Group 3 assurance provisions.
 - (i). If total NO_x emissions during a control period in a given year from all CSAPR NO_x Ozone Season Group 3 units at CSAPR NO_x Ozone Season Group 3 sources in the state and Indian country within the borders of such state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such

Section 2 – Combustion Turbine Generators

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

NO_x emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) CSAPR NO_x Ozone Season Group 3 allowances available for deduction for such control period under 40 CFR 97.825(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.825(b), of multiplying—

- (A). The quotient of the amount by which the common designated representative's share of such NO_x emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state and Indian country within the borders of such state for such control period, by which each common designated representative's share of such NO_x emissions exceeds the respective common designated representative's assurance level; and
 - (B). The amount by which total NO_x emissions from all CSAPR NO_x Ozone Season Group 3 units at CSAPR NO_x Ozone Season Group 3 sources in the state and Indian country within the borders of such state for such control period exceed the state assurance level.
- (ii). The owners and operators shall hold the CSAPR NO_x Ozone Season Group 3 allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.
 - (iii). Total NO_x emissions from all CSAPR NO_x Ozone Season Group 3 units at CSAPR NO_x Ozone Season Group 3 sources in the state and Indian country within the borders of such state during a control period in a given year exceed the state assurance level if such total NO_x emissions exceed the sum, for such control period, of the State NO_x Ozone Season Group 3 trading budget under 40 CFR 97.810(a) and the state's variability limit under 40 CFR 97.810(b).
 - (iv). It shall not be a violation of 40 CFR Part 97, Subpart GGGGG or of the Clean Air Act if total NO_x emissions from all CSAPR NO_x Ozone Season Group 3 units at CSAPR NO_x Ozone Season Group 3 sources in the state and Indian country within the borders of such state during a control period exceed the state assurance level or if a common designated representative's share of total NO_x emissions from the CSAPR NO_x Ozone Season Group 3 units at CSAPR NO_x Ozone Season Group 3 sources in the state and Indian country within the borders of such state during a control period exceeds the common designated representative's assurance level.
 - (v). To the extent the owners and operators fail to hold CSAPR NO_x Ozone Season Group 3 allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,
 - (A). The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and
 - (B). Each CSAPR NO_x Ozone Season Group 3 allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart GGGGG and the Clean Air Act.
- (3) Compliance periods.
- (i). A CSAPR NO_x Ozone Season Group 3 unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of May 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.830(b) and for each control period thereafter.
 - (ii). A CSAPR NO_x Ozone Season Group 3 unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting on the later of May 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.830(b) and for each control period thereafter.

- (4) Vintage of allowances held for compliance.
 - (i). A CSAPR NO_x Ozone Season Group 3 allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a CSAPR NO_x Ozone Season Group 3 allowance that was allocated for such control period or a control period in a prior year.
 - (ii). A CSAPR NO_x Ozone Season Group 3 allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a CSAPR NO_x Ozone Season Group 3 allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.
- (5) Allowance Management System requirements. Each CSAPR NO_x Ozone Season Group 3 allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR Part 97, Subpart GGGGG.
- (6) Limited authorization. A CSAPR NO_x Ozone Season Group 3 allowance is a limited authorization to emit one ton of NO_x during the control period in one year. Such authorization is limited in its use and duration as follows:
 - (i). Such authorization shall only be used in accordance with the CSAPR NO_x Ozone Season Group 3 Trading Program; and
 - (ii). Notwithstanding any other provision of 40 CFR Part 97, Subpart GGGGG, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.
- (7) Property right. A CSAPR NO_x Ozone Season Group 3 allowance does not constitute a property right.

(d) Title V permit revision requirements.

- (1) No title V permit revision shall be required for any allocation, holding, deduction, or transfer of CSAPR NO_x Ozone Season Group 3 allowances in accordance with 40 CFR Part 97, Subpart GGGGG.
- (2) This permit incorporates the CSAPR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.830 through 97.835, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR Part 75, Subparts B and H), an excepted monitoring system (pursuant to 40 CFR Part 75, Appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR 75.19), and an alternative monitoring system (pursuant to 40 CFR Part 75, Subpart E). Therefore, the Description of CSAPR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.806(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).

(e) Additional recordkeeping and reporting requirements.

- (1) Unless otherwise provided, the owners and operators of each CSAPR NO_x Ozone Season Group 3 source and each CSAPR NO_x Ozone Season Group 3 unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
 - (i). The certificate of representation under 40 CFR 97.816 for the designated representative for the source and each CSAPR NO_x Ozone Season Group 3 unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.816 changing the designated representative.
 - (ii). All emissions monitoring information, in accordance with 40 CFR Part 97, Subpart GGGGG.
 - (iii). Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the CSAPR NO_x Ozone Season Group 3 Trading Program.

- (2) The designated representative of a CSAPR NO_x Ozone Season Group 3 source and each CSAPR NO_x Ozone Season Group 3 unit at the source shall make all submissions required under the CSAPR NO_x Ozone Season Group 3 Trading Program, except as provided in 40 CFR 97.818. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR Parts 70 and 71.

(f) Liability.

- (1) Any provision of the CSAPR NO_x Ozone Season Group 3 Trading Program that applies to a CSAPR NO_x Ozone Season Group 3 source or the designated representative of a CSAPR NO_x Ozone Season Group 3 source shall also apply to the owners and operators of such source and of the CSAPR NO_x Ozone Season Group 3 units at the source.
- (2) Any provision of the CSAPR NO_x Ozone Season Group 3 Trading Program that applies to a CSAPR NO_x Ozone Season Group 3 unit or the designated representative of a CSAPR NO_x Ozone Season Group 3 unit shall also apply to the owners and operators of such unit.

(g) Effect on other authorities.

No provision of the CSAPR NO_x Ozone Season Group 3 Trading Program or exemption under 40 CFR 97.805 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a CSAPR NO_x Ozone Season Group 3 source or CSAPR NO_x Ozone Season Group 3 unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

(h) Effect on units in Indian country.

Notwithstanding the provisions of paragraphs (a) through (g) above, paragraphs (a) through (g) shall be deemed not to impose any requirements on any source or unit, or any owner, operator, or designated representative with regard to any source or unit, in Indian country within the borders of the state.

SECTION III: CSAPR SO₂ Group 1 Trading Program requirements (40 CFR 97.606)

(a) Designated representative requirements.

The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.613 through 97.618.

(b) Emissions monitoring, reporting, and recordkeeping requirements.

- (1) The owners and operators, and the designated representative, of each CSAPR SO₂ Group 1 source and each CSAPR SO₂ Group 1 unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.630 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.631 (initial monitoring system certification and recertification procedures), 97.632 (monitoring system out-of-control periods), 97.633 (notifications concerning monitoring), 97.634 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.635 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).
- (2) The emissions data determined in accordance with 40 CFR 97.630 through 97.635 shall be used to calculate allocations of CSAPR SO₂ Group 1 allowances under 40 CFR 97.611(a)(2) and (b) and 97.612 and to determine compliance with the CSAPR SO₂ Group 1 emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.630 through 97.635 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

(c) SO₂ emissions requirements.**(1) CSAPR SO₂ Group 1 emissions limitation.**

- (i). As of the allowance transfer deadline for a control period in a given year, the owners and operators of each CSAPR SO₂ Group 1 source and each CSAPR SO₂ Group 1 unit at the source shall hold, in the source's compliance account, CSAPR SO₂ Group 1 allowances available for deduction for such control period under 40 CFR 97.624(a) in an amount not less than the tons of total SO₂ emissions for such control period from all CSAPR SO₂ Group 1 units at the source.
- (ii). If total SO₂ emissions during a control period in a given year from the CSAPR SO₂ Group 1 units at a CSAPR SO₂ Group 1 source are in excess of the CSAPR SO₂ Group 1 emissions limitation set forth in paragraph (c)(1)(i) above, then:
 - (A). The owners and operators of the source and each CSAPR SO₂ Group 1 unit at the source shall hold the CSAPR SO₂ Group 1 allowances required for deduction under 40 CFR 97.624(d); and
 - (B). The owners and operators of the source and each CSAPR SO₂ Group 1 unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation 40 CFR Part 97, Subpart CCCCC and the Clean Air Act.

(2) CSAPR SO₂ Group 1 assurance provisions.

- (i). If total SO₂ emissions during a control period in a given year from all CSAPR SO₂ Group 1 units at CSAPR SO₂ Group 1 sources in the state and Indian country within the borders of such state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such SO₂ emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) CSAPR SO₂ Group 1 allowances available for deduction for such control period under 40 CFR 97.625(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.625(b), of multiplying—
 - (A). The quotient of the amount by which the common designated representative's share of such SO₂ emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state and Indian country within the borders of such state for such control period, by which each common designated representative's share of such SO₂ emissions exceeds the respective common designated representative's assurance level; and
 - (B). The amount by which total SO₂ emissions from all CSAPR SO₂ Group 1 units at CSAPR SO₂ Group 1 sources in the state and Indian country within the borders of such state for such control period exceed the state assurance level.
- (ii). The owners and operators shall hold the CSAPR SO₂ Group 1 allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.
- (iii). Total SO₂ emissions from all CSAPR SO₂ Group 1 units at CSAPR SO₂ Group 1 sources in the state and Indian country within the borders of such state during a control period in a given year exceed the state assurance level if such total SO₂ emissions exceed the sum, for such control period, of the state SO₂ Group 1 trading budget under 40 CFR 97.610(a) and the state's variability limit under 40 CFR 97.610(b).
- (iv). It shall not be a violation of 40 CFR Part 97, Subpart CCCCC or of the Clean Air Act if total SO₂ emissions from all CSAPR SO₂ Group 1 units at CSAPR SO₂ Group 1 sources in the state and Indian country within the borders of such state during a control period exceed the state assurance level or if

Section 2 – Combustion Turbine Generators

ROP No: MI-ROP-B6145-2024

Expiration Date: June 30, 2029

PTI No: MI-PTI-B6145-2024

a common designated representative's share of total SO₂ emissions from the CSAPR SO₂ Group 1 units at CSAPR SO₂ Group 1 sources in the state and Indian country within the borders of such state during a control period exceeds the common designated representative's assurance level.

- (v). To the extent the owners and operators fail to hold CSAPR SO₂ Group 1 allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,
 - (A). The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and
 - (B). Each CSAPR SO₂ Group 1 allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart CCCCC and the Clean Air Act.
- (3) Compliance periods.
 - (i). A CSAPR SO₂ Group 1 unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of January 1, 2015 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.630(b) and for each control period thereafter.
 - (ii). A CSAPR SO₂ Group 1 unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting on the later of January 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.630(b) and for each control period thereafter.
- (4) Vintage of allowances held for compliance.
 - (i). A CSAPR SO₂ Group 1 allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a CSAPR SO₂ Group 1 allowance that was allocated for such control period or a control period in a prior year.
 - (ii). A CSAPR SO₂ Group 1 allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a CSAPR SO₂ Group 1 allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.
- (5) Allowance Management System requirements. Each CSAPR SO₂ Group 1 allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR Part 97, Subpart CCCCC.
- (6) Limited authorization. A CSAPR SO₂ Group 1 allowance is a limited authorization to emit one ton of SO₂ during the control period in one year. Such authorization is limited in its use and duration as follows:
 - (i). Such authorization shall only be used in accordance with the CSAPR SO₂ Group 1 Trading Program; and
 - (ii). Notwithstanding any other provision of 40 CFR Part 97, Subpart CCCCC, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.
- (7) Property right. A CSAPR SO₂ Group 1 allowance does not constitute a property right.

(d) Title V permit revision requirements.

- (1) No title V permit revision shall be required for any allocation, holding, deduction, or transfer of CSAPR SO₂ Group 1 allowances in accordance with 40 CFR Part 97, Subpart CCCCC.
- (2) This permit incorporates the CSAPR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.630 through 97.635, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR Part 75, Subparts B and H), an excepted monitoring system (pursuant to 40 CFR Part 75, Appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR 75.19), and an alternative monitoring system (pursuant to 40 CFR Part 75, Subpart E). Therefore, the Description of CSAPR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.606(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).

(e) Additional recordkeeping and reporting requirements.

- (1) Unless otherwise provided, the owners and operators of each CSAPR SO₂ Group 1 source and each CSAPR SO₂ Group 1 unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
 - (i). The certificate of representation under 40 CFR 97.616 for the designated representative for the source and each CSAPR SO₂ Group 1 unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.616 changing the designated representative.
 - (ii). All emissions monitoring information, in accordance with 40 CFR Part 97, Subpart CCCCC.
 - (iii). Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the CSAPR SO₂ Group 1 Trading Program.
- (2) The designated representative of a CSAPR SO₂ Group 1 source and each CSAPR SO₂ Group 1 unit at the source shall make all submissions required under the CSAPR SO₂ Group 1 Trading Program, except as provided in 40 CFR 97.618. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR Parts 70 and 71.

(f) Liability.

- (1) Any provision of the CSAPR SO₂ Group 1 Trading Program that applies to a CSAPR SO₂ Group 1 source or the designated representative of a CSAPR SO₂ Group 1 source shall also apply to the owners and operators of such source and of the CSAPR SO₂ Group 1 units at the source.
- (2) Any provision of the CSAPR SO₂ Group 1 Trading Program that applies to a CSAPR SO₂ Group 1 unit or the designated representative of a CSAPR SO₂ Group 1 unit shall also apply to the owners and operators of such unit.

(g) Effect on other authorities.

No provision of the CSAPR SO₂ Group 1 Trading Program or exemption under 40 CFR 97.605 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a CSAPR SO₂ Group 1 source or CSAPR SO₂ Group 1 unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

(h) Effect on units in Indian country.

Notwithstanding the provisions of paragraphs (a) through (g) above, paragraphs (a) through (g) shall be deemed not to impose any requirements on any source or unit, or any owner, operator, or designated representative with regard to any source or unit, in Indian country within the borders of the state.