

**MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY  
AIR QUALITY DIVISION**

EFFECTIVE DATE: March 9, 2020  
REVISION DATE: February 7, 2022

ISSUED TO

**National Energy of Lincoln LLC**

State Registration Number (SRN): N0890

LOCATED AT

509 West State Street, Lincoln, Alcona County, Michigan 48742

**RENEWABLE OPERATING PERMIT**

Permit Number: MI-ROP-N0890-2020a

Expiration Date: March 9, 2025

Administratively Complete ROP Renewal Application Due Between  
September 9, 2023 and September 9, 2024

This Renewable Operating Permit (ROP) is issued in accordance with and subject to Section 5506(3) of Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451). Pursuant to Rule 210(1) of the administrative rules promulgated under Act 451, this ROP constitutes the permittee's authority to operate the stationary source identified above in accordance with the general conditions, special conditions and attachments contained herein. Operation of the stationary source and all emission units listed in the permit are subject to all applicable future or amended rules and regulations pursuant to Act 451 and the federal Clean Air Act.

**SOURCE-WIDE PERMIT TO INSTALL**

Permit Number: MI-PTI-N0890-2020a

This Permit to Install (PTI) is issued in accordance with and subject to Section 5505(1) of Act 451. Pursuant to Rule 214a of the administrative rules promulgated under Act 451, the terms and conditions herein, identified by the underlying applicable requirement citation of Rule 201(1)(a), constitute a federally enforceable PTI. The PTI terms and conditions do not expire and remain in effect unless the criteria of Rule 201(6) are met. Operation of all emission units identified in the PTI is subject to all applicable future or amended rules and regulations pursuant to Act 451 and the federal Clean Air Act.

Michigan Department of Environment, Great Lakes, and Energy

---

Shane Nixon, Cadillac District Supervisor

# TABLE OF CONTENTS

- AUTHORITY AND ENFORCEABILITY ..... 3**
  
- A. GENERAL CONDITIONS..... 4**
  - Permit Enforceability ..... 4
  - General Provisions..... 4
  - Equipment & Design ..... 5
  - Emission Limits ..... 5
  - Testing/Sampling ..... 5
  - Monitoring/Recordkeeping ..... 6
  - Certification & Reporting ..... 6
  - Permit Shield ..... 7
  - Revisions ..... 8
  - Reopenings..... 8
  - Renewals..... 9
  - Stratospheric Ozone Protection ..... 9
  - Risk Management Plan ..... 9
  - Emission Trading ..... 9
  - Permit to Install (PTI) ..... 10
  
- B. SOURCE-WIDE CONDITIONS ..... 11**
  
- C. EMISSION UNIT SPECIAL CONDITIONS ..... 14**
  - EMISSION UNIT SUMMARY TABLE..... 14
  - EURMHANDLING..... 15
  - EUBOILER..... 17
  - EUASHHANDLING ..... 31
  - EUGENERATOR ..... 33
  
- D. FLEXIBLE GROUP SPECIAL CONDITIONS..... 35**
  - FLEXIBLE GROUP SUMMARY TABLE ..... 35
  - FGCOLDCLEANERS..... 36
  
- E. NON-APPLICABLE REQUIREMENTS ..... 39**
  
- APPENDICES ..... 40**
  - Appendix 1. Acronyms and Abbreviations..... 40
  - Appendix 2. Schedule of Compliance..... 41
  - Appendix 3. Monitoring Requirements ..... 41
  - Appendix 4. Recordkeeping ..... 41
  - Appendix 5. Testing Procedures ..... 41
  - Appendix 6. Permits to Install..... 41
  - Appendix 7. Emission Calculations ..... 41
  - Appendix 8. Reporting ..... 42

## AUTHORITY AND ENFORCEABILITY

For the purpose of this permit, the **permittee** is defined as any person who owns or operates an emission unit at a stationary source for which this permit has been issued. The **department** is defined in Rule 104(d) as the Director of the Michigan Department of Environment, Great Lakes, and Energy (EGLE) or his or her designee.

The permittee shall comply with all specific details in the permit terms and conditions and the cited underlying applicable requirements. All terms and conditions in this ROP are both federally enforceable and state enforceable unless otherwise footnoted. Certain terms and conditions are applicable to most stationary sources for which an ROP has been issued. These general conditions are included in Part A of this ROP. Other terms and conditions may apply to a specific emission unit, several emission units which are represented as a flexible group, or the entire stationary source which is represented as a Source-Wide group. Special conditions are identified in Parts B, C, D and/or the appendices.

In accordance with Rule 213(2)(a), all underlying applicable requirements are identified for each ROP term or condition. All terms and conditions that are included in a PTI are streamlined, subsumed and/or is state-only enforceable will be noted as such.

In accordance with Section 5507 of Act 451, the permittee has included in the ROP application a compliance certification, a schedule of compliance, and a compliance plan. For applicable requirements with which the source is in compliance, the source will continue to comply with these requirements. For applicable requirements with which the source is not in compliance, the source will comply with the detailed schedule of compliance requirements that are incorporated as an appendix in this ROP. Furthermore, for any applicable requirements effective after the date of issuance of this ROP, the stationary source will meet the requirements on a timely basis, unless the underlying applicable requirement requires a more detailed schedule of compliance.

Issuance of this permit does not obviate the necessity of obtaining such permits or approvals from other units of government as required by law.

## A. GENERAL CONDITIONS

### Permit Enforceability

- All conditions in this permit are both federally enforceable and state enforceable unless otherwise noted. **(R 336.1213(5))**
- Those conditions that are hereby incorporated in a state-only enforceable Source-Wide PTI pursuant to Rule 201(2)(d) are designated by footnote one. **(R 336.1213(5)(a), R 336.1214a(5))**
- Those conditions that are hereby incorporated in a federally enforceable Source-Wide PTI pursuant to Rule 201(2)(c) are designated by footnote two. **(R 336.1213(5)(b), R 336.1214a(3))**

### General Provisions

1. The permittee shall comply with all conditions of this ROP. Any ROP noncompliance constitutes a violation of Act 451, and is grounds for enforcement action, for ROP revocation or revision, or for denial of the renewal of the ROP. All terms and conditions of this ROP that are designated as federally enforceable are enforceable by the Administrator of the United States Environmental Protection Agency (USEPA) and by citizens under the provisions of the federal Clean Air Act (CAA). Any terms and conditions based on applicable requirements which are designated as "state-only" are not enforceable by the USEPA or citizens pursuant to the CAA. **(R 336.1213(1)(a))**
2. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this ROP. **(R 336.1213(1)(b))**
3. This ROP may be modified, revised, or revoked for cause. The filing of a request by the permittee for a permit modification, revision, or termination, or a notification of planned changes or anticipated noncompliance does not stay any ROP term or condition. This does not supersede or affect the ability of the permittee to make changes, at the permittee's own risk, pursuant to Rule 215 and Rule 216. **(R 336.1213(1)(c))**
4. The permittee shall allow the department, or an authorized representative of the department, upon presentation of credentials and other documents as may be required by law and upon stating the authority for and purpose of the investigation, to perform any of the following activities: **(R 336.1213(1)(d))**
  - a. Enter, at reasonable times, a stationary source or other premises where emissions-related activity is conducted or where records must be kept under the conditions of the ROP.
  - b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the ROP.
  - c. Inspect, at reasonable times, any of the following:
    - i. Any stationary source.
    - ii. Any emission unit.
    - iii. Any equipment, including monitoring and air pollution control equipment.
    - iv. Any work practices or operations regulated or required under the ROP.
  - d. As authorized by Section 5526 of Act 451, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the ROP or applicable requirements.
5. The permittee shall furnish to the department, within a reasonable time, any information the department may request, in writing, to determine whether cause exists for modifying, revising, or revoking the ROP or to determine compliance with this ROP. Upon request, the permittee shall also furnish to the department copies of any records that are required to be kept as a term or condition of this ROP. For information which is claimed by the permittee to be confidential, consistent with the requirements of the 1976 PA 442, MCL §15.231 et seq., and known as the Freedom of Information Act, the person may also be required to furnish the records directly to the USEPA together with a claim of confidentiality. **(R 336.1213(1)(e))**

6. A challenge by any person, the Administrator of the USEPA, or the department to a particular condition or a part of this ROP shall not set aside, delay, stay, or in any way affect the applicability or enforceability of any other condition or part of this ROP. **(R 336.1213(1)(f))**
7. The permittee shall pay fees consistent with the fee schedule and requirements pursuant to Section 5522 of Act 451. **(R 336.1213(1)(g))**
8. This ROP does not convey any property rights or any exclusive privilege. **(R 336.1213(1)(h))**

### Equipment & Design

9. Any collected air contaminants shall be removed as necessary to maintain the equipment at the required operating efficiency. The collection and disposal of air contaminants shall be performed in a manner so as to minimize the introduction of contaminants to the outer air. Transport of collected air contaminants in Priority I and II areas requires the use of material handling methods specified in Rule 370(2).<sup>2</sup> **(R 336.1370)**
10. Any air cleaning device shall be installed, maintained, and operated in a satisfactory manner and in accordance with the Michigan Air Pollution Control rules and existing law. **(R 336.1910)**

### Emission Limits

11. Unless otherwise specified in this ROP, the permittee shall comply with Rule 301, which states, in part, "Except as provided in Subrules 2, 3, and 4 of this rule, a person shall not cause or permit to be discharged into the outer air from a process or process equipment a visible emission of a density greater than the most stringent of the following:"<sup>2</sup> **(R 336.1301(1))**
  - a. A 6-minute average of 20% opacity, except for one 6-minute average per hour of not more than 27% opacity.
  - b. A limit specified by an applicable federal new source performance standard.

The grading of visible emissions shall be determined in accordance with Rule 303.

12. The permittee shall not cause or permit the emission of an air contaminant or water vapor in quantities that cause, alone or in reaction with other air contaminants, either of the following:
  - a. Injurious effects to human health or safety, animal life, plant life of significant economic value, or property.<sup>1</sup> **(R 336.1901(a))**
  - b. Unreasonable interference with the comfortable enjoyment of life and property.<sup>1</sup> **(R 336.1901(b))**

### Testing/Sampling

13. The department may require the owner or operator of any source of an air contaminant to conduct acceptable performance tests, at the owner's or operator's expense, in accordance with Rule 1001 and Rule 1003, under any of the conditions listed in Rule 1001(1).<sup>2</sup> **(R 336.2001)**
14. Any required performance testing shall be conducted in accordance with Rule 1001(2), Rule 1001(3) and Rule 1003. **(R 336.2001(2), R 336.2001(3), R 336.2003(1))**
15. Any required test results shall be submitted to the Air Quality Division (AQD) in the format prescribed by the applicable reference test method within 60 days following the last date of the test. **(R 336.2001(5))**

## Monitoring/Recordkeeping

16. Records of any periodic emission or parametric monitoring required in this ROP shall include the following information specified in Rule 213(3)(b)(i), where appropriate. **(R 336.1213(3)(b))**
  - a. The date, location, time, and method of sampling or measurements.
  - b. The dates the analyses of the samples were performed.
  - c. The company or entity that performed the analyses of the samples.
  - d. The analytical techniques or methods used.
  - e. The results of the analyses.
  - f. The related process operating conditions or parameters that existed at the time of sampling or measurement.
17. All required monitoring data, support information and all reports, including reports of all instances of deviation from permit requirements, shall be kept and furnished to the department upon request for a period of not less than 5 years from the date of the monitoring sample, measurement, report or application. Support information includes all calibration and maintenance records and all original strip-chart recordings, or other original data records, for continuous monitoring instrumentation and copies of all reports required by the ROP. **(R 336.1213(1)(e), R 336.1213(3)(b)(ii))**

## Certification & Reporting

18. Except for the alternate certification schedule provided in Rule 213(3)(c)(iii)(B), any document required to be submitted to the department as a term or condition of this ROP shall contain an original certification by a Responsible Official which state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. **(R 336.1213(3)(c))**
19. A Responsible Official shall certify to the appropriate AQD District Office and to the USEPA that the stationary source is and has been in compliance with all terms and conditions contained in the ROP except for deviations that have been or are being reported to the appropriate AQD District Office pursuant to Rule 213(3)(c). This certification shall include all the information specified in Rule 213(4)(c)(i) through (v) and shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the certification are true, accurate, and complete. The USEPA address is: USEPA, Air Compliance Data - Michigan, Air and Radiation Division, 77 West Jackson Boulevard, Chicago, Illinois 60604-3507. **(R 336.1213(4)(c))**
20. The certification of compliance shall be submitted annually for the term of this ROP as detailed in the special conditions, or more frequently if specified in an applicable requirement or in this ROP. **(R 336.1213(4)(c))**
21. The permittee shall promptly report any deviations from ROP requirements and certify the reports. The prompt reporting of deviations from ROP requirements is defined in Rule 213(3)(c)(ii) as follows, unless otherwise described in this ROP. **(R 336.1213(3)(c))**
  - a. For deviations that exceed the emissions allowed under the ROP, prompt reporting means reporting consistent with the requirements of Rule 912 as detailed in Condition 25. All reports submitted pursuant to this paragraph shall be promptly certified as specified in Rule 213(3)(c)(iii).
  - b. For deviations which exceed the emissions allowed under the ROP and which are not reported pursuant to Rule 912 due to the duration of the deviation, prompt reporting means the reporting of all deviations in the semiannual reports required by Rule 213(3)(c)(i). The report shall describe reasons for each deviation and the actions taken to minimize or correct each deviation.
  - c. For deviations that do not exceed the emissions allowed under the ROP, prompt reporting means the reporting of all deviations in the semiannual reports required by Rule 213(3)(c)(i). The report shall describe the reasons for each deviation and the actions taken to minimize or correct each deviation.

22. For reports required pursuant to Rule 213(3)(c)(ii), prompt certification of the reports is described in Rule 213(3)(c)(iii) as either of the following: **(R 336.1213(3)(c))**
  - a. Submitting a certification by a Responsible Official with each report which states that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.
  - b. Submitting, within 30 days following the end of a calendar month during which one or more prompt reports of deviations from the emissions allowed under the ROP were submitted to the department pursuant to Rule 213(3)(c)(ii), a certification by a Responsible Official which states that; “based on information and belief formed after reasonable inquiry, the statements and information contained in each of the reports submitted during the previous month were true, accurate, and complete.” The certification shall include a listing of the reports that are being certified. Any report submitted pursuant to Rule 213(3)(c)(ii) that will be certified on a monthly basis pursuant to this paragraph shall include a statement that certification of the report will be provided within 30 days following the end of the calendar month.
23. Semiannually for the term of the ROP as detailed in the special conditions, or more frequently if specified, the permittee shall submit certified reports of any required monitoring to the appropriate AQD District Office. All instances of deviations from ROP requirements during the reporting period shall be clearly identified in the reports. **(R 336.1213(3)(c)(i))**
24. On an annual basis, the permittee shall report the actual emissions, or the information necessary to determine the actual emissions, of each regulated air pollutant as defined in Rule 212(6) for each emission unit utilizing the emissions inventory forms provided by the department. **(R 336.1212(6))**
25. The permittee shall provide notice of an abnormal condition, start-up, shutdown, or malfunction that results in emissions of a hazardous or toxic air pollutant which continue for more than one hour in excess of any applicable standard or limitation, or emissions of any air contaminant continuing for more than two hours in excess of an applicable standard or limitation, as required in Rule 912, to the appropriate AQD District Office. The notice shall be provided not later than two business days after the start-up, shutdown, or discovery of the abnormal conditions or malfunction. Notice shall be by any reasonable means, including electronic, telephonic, or oral communication. Written reports, if required under Rule 912, must be submitted to the appropriate AQD District Supervisor within 10 days after the start-up or shutdown occurred, within 10 days after the abnormal conditions or malfunction has been corrected, or within 30 days of discovery of the abnormal conditions or malfunction, whichever is first. The written reports shall include all of the information required in Rule 912(5) and shall be certified by a Responsible Official in a manner consistent with the CAA.<sup>2</sup> **(R 336.1912)**

## Permit Shield

26. Compliance with the conditions of the ROP shall be considered compliance with any applicable requirements as of the date of ROP issuance if either of the following provisions is satisfied. **(R 336.1213(6)(a)(i), R 336.1213(6)(a)(ii))**
  - a. The applicable requirements are included and are specifically identified in the ROP.
  - b. The permit includes a determination or concise summary of the determination by the department that other specifically identified requirements are not applicable to the stationary source.

Any requirements identified in Part E of this ROP have been identified as non-applicable to this ROP and are included in the permit shield.

27. Nothing in this ROP shall alter or affect any of the following:
  - a. The provisions of Section 303 of the CAA, emergency orders, including the authority of the USEPA under Section 303 of the CAA. **(R 336.1213(6)(b)(i))**
  - b. The liability of the owner or operator of this source for any violation of applicable requirements prior to or at the time of this ROP issuance. **(R 336.1213(6)(b)(ii))**
  - c. The applicable requirements of the acid rain program, consistent with Section 408(a) of the CAA. **(R 336.1213(6)(b)(iii))**

- d. The ability of the USEPA to obtain information from a source pursuant to Section 114 of the CAA. **(R 336.1213(6)(b)(iv))**
28. The permit shield shall not apply to provisions incorporated into this ROP through procedures for any of the following:
  - a. Operational flexibility changes made pursuant to Rule 215. **(R 336.1215(5))**
  - b. Administrative Amendments made pursuant to Rule 216(1)(a)(i)-(iv). **(R 336.1216(1)(b)(iii))**
  - c. Administrative Amendments made pursuant to Rule 216(1)(a)(v) until the amendment has been approved by the department. **(R 336.1216(1)(c)(iii))**
  - d. Minor Permit Modifications made pursuant to Rule 216(2). **(R 336.1216(2)(f))**
  - e. State-Only Modifications made pursuant to Rule 216(4) until the changes have been approved by the department. **(R 336.1216(4)(e))**
29. Expiration of this ROP results in the loss of the permit shield. If a timely and administratively complete application for renewal is submitted not more than 18 months, but not less than 6 months, before the expiration date of the ROP, but the department fails to take final action before the end of the ROP term, the existing ROP does not expire until the renewal is issued or denied, and the permit shield shall extend beyond the original ROP term until the department takes final action. **(R 336.1217(1)(c), R 336.1217(1)(a))**

## Revisions

30. For changes to any process or process equipment covered by this ROP that do not require a revision of the ROP pursuant to Rule 216, the permittee must comply with Rule 215. **(R 336.1215, R 336.1216)**
31. A change in ownership or operational control of a stationary source covered by this ROP shall be made pursuant to Rule 216(1). **(R 336.1219(2))**
32. For revisions to this ROP, an administratively complete application shall be considered timely if it is received by the department in accordance with the time frames specified in Rule 216. **(R 336.1210(10))**
33. Pursuant to Rule 216(1)(b)(iii), Rule 216(2)(d) and Rule 216(4)(d), after a change has been made, and until the department takes final action, the permittee shall comply with both the applicable requirements governing the change and the ROP terms and conditions proposed in the application for the modification. During this time period, the permittee may choose to not comply with the existing ROP terms and conditions that the application seeks to change. However, if the permittee fails to comply with the ROP terms and conditions proposed in the application during this time period, the terms and conditions in the ROP are enforceable. **(R 336.1216(1)(c)(iii), R 336.1216(2)(d), R 336.1216(4)(d))**

## Reopenings

34. A ROP shall be reopened by the department prior to the expiration date and revised by the department under any of the following circumstances:
  - a. If additional requirements become applicable to this stationary source with three or more years remaining in the term of the ROP, but not if the effective date of the new applicable requirement is later than the ROP expiration date. **(R 336.1217(2)(a)(i))**
  - b. If additional requirements pursuant to Title IV of the CAA become applicable to this stationary source. **(R 336.1217(2)(a)(ii))**
  - c. If the department determines that the ROP contains a material mistake, information required by any applicable requirement was omitted, or inaccurate statements were made in establishing emission limits or the terms or conditions of the ROP. **(R 336.1217(2)(a)(iii))**
  - d. If the department determines that the ROP must be revised to ensure compliance with the applicable requirements. **(R 336.1217(2)(a)(iv))**

## Renewals

35. For renewal of this ROP, an administratively complete application shall be considered timely if it is received by the department not more than 18 months, but not less than 6 months, before the expiration date of the ROP. **(R 336.1210(9))**

## Stratospheric Ozone Protection

36. If the permittee is subject to Title 40 of the Code of Federal Regulations (CFR), Part 82 and services, maintains, or repairs appliances except for motor vehicle air conditioners (MVAC), or disposes of appliances containing refrigerant, including MVAC and small appliances, or if the permittee is a refrigerant reclaimer, appliance owner or a manufacturer of appliances or recycling and recovery equipment, the permittee shall comply with all applicable standards for recycling and emissions reduction pursuant to 40 CFR Part 82, Subpart F.
37. If the permittee is subject to 40 CFR Part 82 and performs a service on motor (fleet) vehicles when this service involves refrigerant in the MVAC, the permittee is subject to all the applicable requirements as specified in 40 CFR Part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners. The term "motor vehicle" as used in Subpart B does not include a vehicle in which final assembly of the vehicle has not been completed by the original equipment manufacturer. The term MVAC as used in Subpart B does not include the air-tight sealed refrigeration system used for refrigerated cargo or an air conditioning system on passenger buses using Hydrochlorofluorocarbon-22 refrigerant.

## Risk Management Plan

38. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall register and submit to the USEPA the required data related to the risk management plan for reducing the probability of accidental releases of any regulated substances listed pursuant to Section 112(r)(3) of the CAA as amended in 40 CFR 68.130. The list of substances, threshold quantities, and accident prevention regulations promulgated under 40 CFR Part 68, do not limit in any way the general duty provisions under Section 112(r)(1).
39. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall comply with the requirements of 40 CFR Part 68, no later than the latest of the following dates as provided in 40 CFR 68.10(a):
- June 21, 1999,
  - Three years after the date on which a regulated substance is first listed under 40 CFR 68.130, or
  - The date on which a regulated substance is first present above a threshold quantity in a process.
40. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall submit any additional relevant information requested by any regulatory agency necessary to ensure compliance with the requirements of 40 CFR Part 68.
41. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall annually certify compliance with all applicable requirements of Section 112(r) as detailed in Rule 213(4)(c)). **(40 CFR Part 68)**

## Emission Trading

42. Emission averaging and emission reduction credit trading are allowed pursuant to any applicable interstate or regional emission trading program that has been approved by the Administrator of the USEPA as a part of Michigan's State Implementation Plan. Such activities must comply with Rule 215 and Rule 216. **(R 336.1213(12))**

### **Permit to Install (PTI)**

43. The process or process equipment included in this permit shall not be reconstructed, relocated, or modified unless a PTI authorizing such action is issued by the department, except to the extent such action is exempt from the PTI requirements by any applicable rule.<sup>2</sup> **(R 336.1201(1))**
44. The department may, after notice and opportunity for a hearing, revoke PTI terms or conditions if evidence indicates the process or process equipment is not performing in accordance with the terms and conditions of the PTI or is violating the department's rules or the CAA.<sup>2</sup> **(R 336.1201(8), Section 5510 of Act 451)**
45. The terms and conditions of a PTI shall apply to any person or legal entity that now or hereafter owns or operates the process or process equipment at the location authorized by the PTI. If a new owner or operator submits a written request to the department pursuant to Rule 219 and the department approves the request, this PTI will be amended to reflect the change of ownership or operational control. The request must include all of the information required by Subrules (1)(a), (b) and (c) of Rule 219. The written request shall be sent to the appropriate AQD District Supervisor, EGLE.<sup>2</sup> **(R 336.1219)**
46. If the installation, reconstruction, relocation, or modification of the equipment for which PTI terms and conditions have been approved has not commenced within 18 months of the original PTI issuance date, or has been interrupted for 18 months, the applicable terms and conditions from that PTI, as incorporated into the ROP, shall become void unless otherwise authorized by the department. Furthermore, the person to whom that PTI was issued, or the designated authorized agent, shall notify the department via the Supervisor, Permit Section, EGLE, AQD, P. O. Box 30260, Lansing, Michigan 48909, if it is decided not to pursue the installation, reconstruction, relocation, or modification of the equipment allowed by the terms and conditions from that PTI.<sup>2</sup> **(R 336.1201(4))**

#### **Footnotes:**

<sup>1</sup>This condition is state-only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup>This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

## **B. SOURCE-WIDE CONDITIONS**

Part B outlines the Source-Wide Terms and Conditions that apply to this stationary source. The permittee is subject to these special conditions for the stationary source in addition to the general conditions in Part A and any other terms and conditions contained in this ROP.

The permittee shall comply with all specific details in the special conditions and the underlying applicable requirements cited. If a specific condition type does not apply to this source, NA (not applicable) has been used in the table. If there are no Source-Wide Conditions, this section will be left blank.

## SOURCE-WIDE CONDITIONS

### DESCRIPTION

Electrical generating facility which burns wood chips, wood products, and tire-derived fuel; fuel storage piles; yards, driveways, fuel and ash handling procedures

### POLLUTION CONTROL EQUIPMENT

NA

#### I. EMISSION LIMIT(S)

NA

#### II. MATERIAL LIMIT(S)

Material	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. Particle Board and Plywood	6935 tpy received <sup>2</sup>	12-month rolling time period as determined at the end of each calendar month	EUBOILER	SC VI.2	R 336.1205(1) R 336.1224 R 336.1225 40 CFR 52.21
2. Creosote Treated Wood	60,200 tpy received <sup>2</sup>	12-month rolling time period as determined at the end of each calendar month	EUBOILER	SC VI.2	R 336.1205(1) R 336.1224 R 336.1225 40 CFR 52.21 (c) and (d)
3. Pentachlorophenol Treated Wood	14,308 tpy received <sup>2</sup>	12-month rolling time period as determined at the end of each calendar month	EUBOILER	SC VI.2	R 336.1205(1) R 336.1224 R 336.1225 40 CFR 52.21
4. TDF	16,060 tpy received <sup>2</sup>	12-month rolling time period as determined at the end of each calendar month	EUBOILER	SC VI.2	R 336.1205(1) R 336.1224 R 336.1225 40 CFR 52.21 (c) and (d)

#### III. PROCESS/OPERATIONAL RESTRICTION(S)

1. The permittee shall not operate EUBOILER unless a program for continuous fugitive emissions control for all plant roadways, the plant yard, all material storage piles, and all material handling operations as approved by the District Supervisor has been implemented and maintained.<sup>2</sup> (R 336.1205(1), R 336.1301, 40 CFR 52.21(c) and (d))
2. The permittee shall implement and maintain a Malfunction Abatement Plan (MAP), as approved by the AQD district supervisor, for the facility. (R 336.1911, R 336.1213(3))
3. If the MAP fails to address or inadequately addresses an event that meets the characteristics of a malfunction, the owner or operator shall revise the MAP within 45 days after such an event occurs and submit the revised plan for approval to the AQD District Supervisor. Should the AQD determine the MAP to be inadequate, the District Supervisor may request modification of the plan to address those inadequacies. (R 336.1213(3), R 336.1910, R 336.1911)

**IV. DESIGN/EQUIPMENT PARAMETER(S)**

NA

**V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. (R 336.1213(3)(b)(ii))

NA

**VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. (R 336.1213(3)(b)(ii))

1. The permittee shall maintain records of activities associated with the Fugitive Emissions Control Plan. (R 336.1301(1), R 336.1213(3))
2. By the fifth calendar day of each month, the permittee shall calculate the total fuel received for the previous month and a 12-calendar month time period for the creosote treated wood fuel; for particle board/plywood fuel; for pentachlorophenol-treated wood; and for TDF. Permittee shall monitor and record the quantity of each of the fuels other than natural gas received during each calendar day in a manner acceptable to the AQD. All such records, including the 12-month time period total fuel received calculation, shall be made available to the AQD upon request. These records may be stored electronically.<sup>2</sup> (R 336.1205(1), R 336.1224, R 336.1225, 40 CFR 52.21(c) and (d))

**VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. (R 336.1213(3)(c)(ii))
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. (R 336.1213(3)(c)(i))
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. (R 336.1213(4)(c))

See Appendix 8

**VIII. STACK/VENT RESTRICTION(S)**

NA

**IX. OTHER REQUIREMENT(S)**

NA

**Footnotes:**

<sup>1</sup>This condition is state-only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup>This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

### C. EMISSION UNIT SPECIAL CONDITIONS

Part C outlines terms and conditions that are specific to individual emission units listed in the Emission Unit Summary Table. The permittee is subject to the special conditions for each emission unit in addition to the General Conditions in Part A and any other terms and conditions contained in this ROP.

The permittee shall comply with all specific details in the special conditions and the underlying applicable requirements cited. If a specific condition type does not apply, NA (not applicable) has been used in the table. If there are no conditions specific to individual emission units, this section will be left blank.

#### EMISSION UNIT SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Emission Unit ID	Emission Unit Description (Including Process Equipment & Control Device(s))	Installation Date/ Modification Date	Flexible Group ID
EURMHANDLING	Raw material handling equipment, including primary and secondary screens, a radial stacker, raw material piles, two hoppers to chip the raw material, and several conveyors. The raw materials are conveyed to the feed hopper of the boiler.	08-01-1986	NA
EUBOILER	230 million BTU per hour boiler equipped with two air pollution control devices: A multiple cyclone collector (pre-cleaner) and an electrostatic precipitator. The boiler is a two drum, open pass, traveling grate spreader-stoker type. Used to produce steam that operates an electrical generator with a nameplate capacity of 18 megawatts. The boiler burns wood, tire-derived fuel (TDF), creosote treated wood, pentachlorophenol-treated wood, particle board, and plywood. Natural gas is fired during startup of the boiler.	08-01-1986	NA
EUASHHANDLING	Ash handling equipment. Fly ash and bottom ash are conveyed to a wet rotary unloader where water is added to control fugitive emissions. The ash is then transported to an enclosed building where it is stored until it is trucked offsite for disposal.	08-01-1986	NA
EUGENERATOR	Standby emergency generator powered by Detroit Diesel diesel-fueled 415 HP engine.	08-01-1986	NA
EUCLDCLNR	Any cold cleaner that is exempt from NSR permitting by R 336.1281(h) or R 336.1285 (r)(iv).	Various	FGCOLDCLEANER

**EURMHANDLING  
EMISSION UNIT CONDITIONS**

**DESCRIPTION**

Raw material handling equipment, including primary and secondary screens, a radial stacker, a raw material pile, two hoppers to chip the raw material, and several conveyors. The raw material is conveyed to the feed hopper of the boiler.

Flexible Group ID: NA

**POLLUTION CONTROL EQUIPMENT**

NA

**I. EMISSION LIMIT(S)**

Pollutant	Limit	Time Period/Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. Visible emissions	5% opacity <sup>2</sup>	6-minute average	EURMHANDLING	SC V.1	<b>R 336.1301 (1)(c)</b>

**II. MATERIAL LIMIT(S)**

NA

**III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. If visible emissions from EURMHANDLING, observed according to SC V.1 of this table, exceed the 5% opacity limit of SC I.1, the permittee shall, within 24 hours, either shut down the process or conduct any maintenance needed to return opacity to within the 5% limit. **(R 336.1301, R 336.1213(3))**
2. If the inspections of equipment in EURMHANDLING, performed according to SC V.2 of this table, reveal any leaks or damage, the permittee shall repair the leaks or damage as soon as practical. **(R 336.1213(3))**

**IV. DESIGN/EQUIPMENT PARAMETER(S)**

NA

**V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall observe and record visible emissions from EURMHANDLING once per calendar day. If any visible emissions are present, the observations shall be performed by a certified observer, using USEPA Method 9, and must be conducted for a minimum of 15 minutes; otherwise, the observations may be informal. **(R 336.1301(1), R 336.1213(3))**

**VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. Records of daily visible emission observations, and those repairs and remedial actions performed in response to the daily visible emission observations, shall be made available to the AQD upon request. **(R 336.1213(3), R 336.1301(1))**

2. Records of weekly inspections of drop chutes, conveyor covers, and other enclosures, and those repairs and remedial actions performed in response to these inspections, shall be made available to the AQD upon request. **(R 336.1213(3), R 336.1301(1))**

## **VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**

See Appendix 8

## **VIII. STACK/VENT RESTRICTION(S)**

NA

## **IX. OTHER REQUIREMENT(S)**

1. The permittee shall perform weekly inspections of drop chutes, conveyor covers, and other enclosures designed to reduce dust from all equipment in EURMHANDLING. **(R 336.1213(3))**

### **Footnotes:**

<sup>1</sup>This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup>This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

**EUBOILER  
 EMISSION UNIT CONDITIONS**

**DESCRIPTION**

The 230 million BTU per hour spreader-stoker boiler. It burns wood, tire derived fuel (TDF), and alternate fuels to generate steam to power an electrical generator of 18 MW nameplate capacity. Alternative fuels include creosote-treated wood, pentachlorophenol-treated wood, particle board, and plywood. Natural gas is also fired during start-up of the boiler. Subject to 40 CFR Part 63, Subpart JJJJJJ in the boiler subcategory defined in 40 CFR 63.11237.

**Flexible Group ID: NA**

**POLLUTION CONTROL EQUIPMENT**

Multiple Cyclonic Collector, Electrostatic Precipitator

**I. EMISSION LIMIT(S)**

Pollutant	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. CO	0.25 lb/MMBtu heat input <sup>2</sup>	24-hour rolling average	EUBOILER	SC VI.9	R 336.1205(1) 40 CFR 52.21 (c) and (d)
2. CO	57.5 pph <sup>2</sup>	24-hour rolling average	EUBOILER	SC VI.9	R 336.1205(1) 40 CFR 52.21 (c) and (d)
3. CO	247.2 tpy <sup>2</sup>	12-month rolling time period as determined at the end of each calendar month	EUBOILER	SC VI.13	R 336.1205(1) 40 CFR 52.21 (c) and (d)
4. NOx	0.25 lb/MMBtu heat input <sup>2</sup>	30-day rolling average	EUBOILER	SC VI.9	R 336.1205(1) 40 CFR 52.21 (c) and (d)
5. NOx	57.5 pph <sup>2</sup>	30-day rolling average	EUBOILER	SC VI.9	R 336.1205(1) 40 CFR 52.21 (c) and (d)
6. NOx	247.2 tpy <sup>2</sup>	12-month rolling time period as determined at the end of each calendar month	EUBOILER	SC VI.13	R 336.1205(1) 40 CFR 52.21 (c) and (d)
7. SO <sub>2</sub>	0.25 lb/MMBtu heat input <sup>2</sup>	30-day rolling average	EUBOILER	SC VI.9	R 336.1205(1) 40 CFR 52.21 (c) and (d)
8. SO <sub>2</sub>	57.5 pph <sup>2</sup>	30-day rolling average	EUBOILER	SC VI.9	R 336.1205(1) 40 CFR 52.21 (c) and (d)
9. SO <sub>2</sub>	247.2 tpy <sup>2</sup>	12-month rolling time period as determined at the end of each calendar month	EUBOILER	SC VI. 13	R 336.1205(1) 40 CFR 52.21 (c) and (d)

<b>Pollutant</b>	<b>Limit</b>	<b>Time Period/ Operating Scenario</b>	<b>Equipment</b>	<b>Monitoring/ Testing Method</b>	<b>Underlying Applicable Requirements</b>
10. PM	0.10 lb/MMBtu heat input	Hourly, except during periods of startup, shutdown, or malfunction.	EUBOILER	SC VI.10	<b>40 CFR 60.43b (c)(1)</b> <b>40 CFR 60.46b (a)</b>
11. PM-10	0.10 lb/MMBtu heat input <sup>2</sup>	Hourly	EUBOILER	SC VI.10	<b>R 336.1205(1)</b> <b>40 CFR 52.21 (c) and (d)</b>
12. PM-10	23.0 pph <sup>2</sup>	Hourly	EUBOILER	SC VI.11	<b>R 336.1205(1)</b> <b>40 CFR 52.21 (c) and (d)</b>
13. PM-10	98.9 tpy <sup>2</sup>	12-month rolling time period as determined at the end of each calendar month	EUBOILER	SC VI.13	<b>R 336.1205(1)</b> <b>40 CFR 52.21 (c) and (d)</b>
14. VOC	0.020 lb/MMBtu heat input	Hourly	EUBOILER	SC VI.10	<b>R 336.1702(c)</b>
15. VOC	4.6 pph <sup>2</sup>	Hourly	EUBOILER	SC VI.11	<b>R 336.1702(c)</b>
16. VOC	19.1 tpy <sup>2</sup>	12-month rolling time period as determined at the end of each calendar month	EUBOILER	SC VI.13	<b>R 336.1702(c)</b>
17. Arsenic	28.7 microgram per dry standard cubic meter @ 7 percent oxygen <sup>1</sup>	Hourly	EUBOILER	SC VI.12	<b>R 336.1225</b>
18. Arsenic	0.0053 pph <sup>1</sup>	Hourly	EUBOILER	SC VI.11	<b>R 336.1225</b>
19. Arsenic	0.0233 tpy <sup>2</sup>	12-month rolling time period as determined at the end of each calendar month	EUBOILER	SC VI.13	<b>R 336.1225</b>
20. Benzo(a) pyrene	0.008 microgram per dry standard cubic meter @ 7 percent oxygen <sup>1</sup>	Hourly	EUBOILER	SC VI.12	<b>R 336.1225</b>
21. Benzo(a) pyrene	0.0000015 pph <sup>1</sup>	Hourly	EUBOILER	SC VI.11	<b>R 336.1225</b>
22. Benzo(a) pyrene	0.0000065 tpy <sup>1</sup>	12-month rolling time period as determined at the end of each calendar month	EUBOILER	SC VI.13	<b>R 336.1225</b>
23. Hydrogen Chloride	23,000 microgram per dry standard cubic meter @ 7 percent oxygen <sup>1</sup>	Hourly	EUBOILER	SC VI.12	<b>R 336.1224</b> <b>R 336.1225</b>
24. Hydrogen Chloride	2.07 pph <sup>1</sup>	Hourly	EUBOILER	SC VI.11	<b>R 336.1224</b> <b>R 336.1225(1)</b>

<b>Pollutant</b>	<b>Limit</b>	<b>Time Period/ Operating Scenario</b>	<b>Equipment</b>	<b>Monitoring/ Testing Method</b>	<b>Underlying Applicable Requirements</b>
25. Hydrogen Chloride	8.9 tpy <sup>1</sup>	12-month rolling time period as determined at the end of each calendar month	EUBOILER	SC VI.13	<b>R 336.1224</b>
26. Hexavalent Chromium	8.8 microgram per dry standard cubic meter @ 7 percent oxygen <sup>1</sup>	Hourly	EUBOILER	SC VI.12	<b>R 336.1225(1)</b>
27. Hexavalent Chromium	0.0016 pph <sup>1</sup>	Hourly	EUBOILER	SC VI.11	<b>R 336.1225(1)</b>
28. Hexavalent Chromium	0.0071 tpy <sup>1</sup>	12-month rolling time period as determined at the end of each calendar month	EUBOILER	SC VI.13	<b>R 336.1225(1)</b>
29. Total Chromium	23.0 microgram per dry standard cubic meter @ 7 percent oxygen <sup>1</sup>	Hourly	EUBOILER	SC VI.12	<b>R 336.1225(1)</b>
30. Total Chromium	0.0043 pph <sup>1</sup>	Hourly	EUBOILER	SC VI.11	<b>R 336.1225(1)</b>
31. Total Chromium	0.0186 tpy <sup>1</sup>	12-month rolling time period as determined at the end of each calendar month	EUBOILER	SC VI.13	<b>R 336.1225(1)</b>
32. Lead	0.00003 lb/MMBtu heat input <sup>2</sup>	Hourly	EUBOILER	SC VI.10	<b>R 336.1205(1) 40 CFR 52.21 (c) and (d)</b>
33. Lead	0.0069 pph <sup>2</sup>	Hourly	EUBOILER	SC VI.11	<b>R 336.1205(1) 40 CFR 52.21 (c) and (d)</b>
34. Lead	0.03 tpy <sup>2</sup>	12-month rolling time period as determined at the end of each calendar month	EUBOILER	SC VI.13	<b>R 336.1205(1) 40 CFR 52.21 (c) and (d)</b>
35. Mercury Compounds	0.8 microgram per dry standard cubic meter @7 percent oxygen <sup>1</sup>	Hourly	EUBOILER	SC VI.12	<b>R 336.1224 R 336.1225</b>
36. Mercury Compounds	0.00015 pph <sup>1</sup>	Hourly	EUBOILER	SC VI.11	<b>R 336.1224 R 336.1225(1)</b>
37. Mercury Compounds	0.0006 tpy <sup>1</sup>	12-month rolling time period as determined at the end of each calendar month	EUBOILER	SC VI.13	<b>R 336.1224 R 336.1225</b>
38. Sulfuric Acid (H <sub>2</sub> SO <sub>4</sub> )	0.0157 lb/MM BTU heat input <sup>1</sup>	Hourly	EUBOILER	SC VI.10	<b>R 336.1224 R 336.1225</b>
39. H <sub>2</sub> SO <sub>4</sub>	5.5 pph <sup>1</sup>	Hourly	EUBOILER	SC VI.11	<b>R 336.1224 R 336.1225</b>

Pollutant	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
40. H <sub>2</sub> SO <sub>4</sub>	23.7 tpy <sup>1</sup>	12-month rolling time period as determined at the end of each calendar month	EUBOILER	SC VI.13	R 336.1224 R 336.1225(1)
41. 2,3,7,8 – tetrachlorodib enzo-p-dioxin (TCDD Toxic Equivalent) (dioxins and furans)	0.000029 microgram per dry standard cubic meter @ 7 percent oxygen <sup>1</sup>	Hourly	EUBOILER	SC VI.12	R 336.1224 R336.1225 (6)(a)
42. TCDD Toxic Equivalent (dioxins and furans)	5.4 x 10 <sup>-9</sup> pph <sup>1</sup>	Hourly	EUBOILER	SC VI.11	R 336.1224 R 336.1225 (6)(a)
43. TCDD Toxic Equivalent (dioxins and furans)	2.3 x 10 <sup>-8</sup> tpy <sup>1</sup>	12-month rolling time period as determined at the end of each calendar month	EUBOILER	SC VI.13	R 336.1224

**II. MATERIAL LIMIT(S)**

Material	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. Natural Gas	490,200,000 cubic feet/year <sup>2</sup>	12-month rolling time period as determined at the end of each calendar month	EUBOILER	SC VI.17	R 336.1205(1) 40 CFR 52.21 (c) and (d) 40 CFR 60.44b (d)
2. Particle Board and Plywood	19 tons burned <sup>2</sup>	24-hour time period	EUBOILER	SC VI.19	R 336.1205(1) R 336.1224 R 336.1225 40 CFR 52.21 (c) and (d)
3. Creosote Treated Wood	168 tons burned <sup>2</sup>	24-hour time period	EUBOILER	SC VI.19	R 336.1205(1) R 336.1224 R 336.1225 40 CFR 52.21 (c) and (d)
4. Pentachlorophenol Treated Wood	39.2 tons burned <sup>2</sup>	24-hour time period	EUBOILER	SC VI.19	R 336.1205(1) R 336.1224 R 336.1225 40 CFR 52.21 (c) and (d)
5. TDF	44 tons burned <sup>2</sup>	24-hour time period	EUBOILER	SC VI.19	R 336.1205(1) R 336.1224 R 336.1225 40 CFR 52.21 (c) and (d)

6. The permittee shall not exceed 0.8 percent, by weight, of chlorine, nor 5 parts per million, by weight, of hexavalent chromium, nor 0.5 parts per million, by weight of mercury in any of the fuels burned in EUBOILER. These concentrations are on a fuel's dry basis.<sup>1</sup> **(R 336.1224, R 336.1225)**

### **III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. The permittee shall not burn TDF and pentachlorophenol-treated wood in the EU BOILER simultaneously.<sup>1</sup> **(R 336.1224, R 336.1225)**
2. The permittee may burn TDF and particle board and/or plywood simultaneously if stack tests, approved by the AQD, demonstrate that these fuels can be co-fired without exceeding any emission limit specified in this permit.<sup>2</sup> **(R 336.1205(1), R 336.1224, R 336.1225, 40 CFR 52.21(c) and (d))**
3. The permittee shall begin firing EU BOILER from a cold start using natural gas only.<sup>2</sup> **(R 336.1912)**
4. The permittee shall not operate EUBOILER unless the multiple cyclone collector and electrostatic precipitator are operating properly.<sup>2</sup> **(R 336.1910, R 336.1205(1) 40 CFR 52.21(c) and (d))**
5. The permittee shall not operate EUBOILER for more than 8,600 hours per 12-month rolling time period, as determined at the end of each calendar month.<sup>2</sup> **(R 336.1205(1)(a), 40 CFR 52.21(c) and (d))**
6. The permittee shall properly maintain the monitoring system including keeping necessary parts for routine repair of the monitoring equipment. **(40 CFR 64.7(b))**
7. Except as specified in paragraph (c) of Section 63.11223, stated in SC III.8, the permittee must conduct a tune-up of the boiler biennially to demonstrate continuous compliance as specified in paragraphs (b)(1) through (7) of Section 63.11223, as listed below. The permittee must conduct the tune-up while burning the type of fuel (or fuels, in the case of boilers that routinely burn multiple types of fuel at the same time) that provided the majority of the heat input to the boiler over the 12 months prior to the tune-up. Each biennial tune-up must be conducted no more than 25 months after the previous tune-up. **(40 CFR 63.11223(a) and (b))**
  - a. As applicable, inspect the burner, and clean or replace any components of the burner as necessary (the permittee may delay the burner inspection until the next scheduled unit shutdown, not to exceed 36 months from the previous inspection). Units that produce electricity for sale may delay the burner inspection until the first outage, not to exceed 36 months from the previous inspection. **(40 CFR 63.11223(b)(1))**
  - b. Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern. The adjustment should be consistent with the manufacturer's specifications, if available. **(40 CFR 63.11223(b)(2))**
  - c. Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure that it is correctly calibrated and functioning properly (the permittee may delay the inspection until the next scheduled unit shutdown, not to exceed 36 months from the previous inspection). Units that produce electricity for sale may delay the inspection until the first outage, not to exceed 36 months from the previous inspection. **(40 CFR 63.11223(b)(3))**
  - d. Optimize total emissions of CO. This optimization should be consistent with the manufacturer's specifications, if available, and with any nitrogen oxide requirement to which the unit is subject. **(40 CFR 63.11223(b)(4))**
  - e. Measure the concentrations in the effluent stream of CO in parts per million, by volume, and oxygen in volume percent, before and after the adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made). Measurements may be taken using a portable CO analyzer. **(40 CFR 63.11223(b)(5))**
  - f. Maintain on-site and submit, if requested by the Administrator, a report containing the information in paragraphs (b)(6)(i) through (iii) of Section 63.11223, as listed below. **(40 CFR 63.11223(b)(6))**
    - i. The concentrations of CO in the effluent stream in parts per million, by volume, and oxygen in volume percent, measured at high fire or typical operating load, before and after the tune-up of the boiler. **(40 CFR 63.11223(b)(6)(i))**

- ii. A description of any corrective actions taken as a part of the tune-up of the boiler. **(40 CFR 63.11223(b)(6)(ii))**
  - iii. The type and amount of fuel used over the 12 months prior to the tune-up of the boiler, but only if the unit was physically and legally capable of using more than one type of fuel during that period. Units sharing a fuel meter may estimate the fuel use by each unit. **(40 CFR 63.11223(b)(6)(iii))**
  - g. If the unit is not operating on the required date for a tune-up, the tune-up must be conducted within 30 days of startup. **(40 CFR 63.11223(b)(7))**
8. Boilers with an oxygen trim system that maintains an optimum air-to-fuel ratio that would otherwise be subject to a biennial tune-up must conduct a tune-up of the boiler every 5 years as specified in paragraphs (b)(1) through (7) of Section 63.11223, stated in SC III.7. Each 5-year tune-up must be conducted no more than 61 months after the previous tune-up. The permittee may delay the burner inspection specified in paragraph (b)(1) of Section 63.11223 and inspection of the system controlling the air-to-fuel ratio specified in paragraph (b)(3) of Section 63.11223 until the next scheduled unit shutdown, but the permittee must inspect each burner and system controlling the air-to-fuel ratio at least once every 72 months. **(40 CFR 63.11223(c))**
  9. The boiler shall comply with the definition of the biomass subcategory: the boiler burns any biomass and is not in the coal subcategory. Where biomass means any biomass-based solid fuel that is not a solid waste. This may include wood waste derived fuels if they are substantially similar to virgin wood. **(40 CFR 63.11200(b), 40 CFR 63.11237)**
  10. The permittee shall not burn the alternative wood fuels and tire derived fuel unless the Fuel Procurement and Handling Plan as approved by the District Supervisor has been implemented and maintained.<sup>1</sup> **(R 336.1224, R 336.1225)**

#### **IV. DESIGN/EQUIPMENT PARAMETER(S)**

1. The permittee shall install, calibrate, maintain and operate in a satisfactory manner, a device to monitor and record the NO<sub>x</sub> and SO<sub>2</sub> concentrations from EUBOILER on a continuous basis (CEMS).<sup>2</sup> **(40 CFR 60.13, 40 CFR 60.48b(b), R 336.2150)**
2. The permittee shall install, calibrate, maintain and operate in a satisfactory manner, a device to monitor and record the CO concentration from EUBOILER on a continuous basis (CEMS).<sup>2</sup> **(40 CFR 60.13, 40, R 336.2150, R 336.1205)**
3. The permittee shall install, calibrate, maintain and operate in a satisfactory manner, a device to monitor and record the O<sub>2</sub> concentration from EUBOILER on a continuous basis (CEMS).<sup>2</sup> **(40 CFR 60.13, R 336.2150)**
4. The permittee shall install, calibrate, maintain and operate in a satisfactory manner, a device to monitor and record visible emissions from EUBOILER on a continuous basis (COMS).<sup>2</sup> **(40 CFR 60.13, 40 CFR 60.48b(a), R 336.2150, 40 CFR 64.6(c)(1)(i) and (ii))**
5. The procedures under 40 CFR 60.13 and 40 CFR Part 60, Appendix B, Performance Specification 1 shall be followed for installation, initial evaluation, and operation of the COMS.<sup>2</sup> **(40 CFR 60.13, 40 CFR 60.48b(a), R 336.2150, 40 CFR 64.6(c)(1)(i) and (ii))**
6. The procedures under 40 CFR 60.13 and Performance Specification 2 of Appendix B to 40 CFR Part 60 shall be followed for installation, initial evaluation, and operation of the NO<sub>x</sub> and SO<sub>2</sub> CEMS.<sup>2</sup> **(40 CFR 60.13, 40 CFR 60.48b(b), R 336.2150)**
7. The procedures under 40 CFR 60.13 and 40 CFR Part 60, Appendix B, Performance Specification 3 shall be followed for installation, initial evaluation, and operation of the O<sub>2</sub> CEMS.<sup>2</sup> **(40 CFR 60.13, R 336.2150)**
8. The procedures under 40 CFR 60.13 and 40 CFR Part 60, Appendix B, Performance Specification 4 shall be followed for installation, initial evaluation, and operation of the CO CEMS.<sup>2</sup> **(40 CFR 60.13, 40, R 336.2150, R 336.1205)**

9. The span value for the NO<sub>x</sub>, SO<sub>2</sub>, CO, and O<sub>2</sub> CEMS shall be 2.0 times the lowest emission standard or as specified in the federal regulations.<sup>2</sup> **(40 CFR 60.13, R 336.2154)**
  
10. Span value for the COMS shall be between 60 and 80 percent. **(40 CFR 60.48(b)(e)(1)), 40 CFR 64.6(c)(1)(iii)**
  
11. The permittee shall calibrate and standardize the COMS in accordance with procedures set forth in Appendix F of 40 CFR Part 60, including daily system checks, quarterly performance audits, and an annual zero path alignment. **(40 CFR Part 60, Appendix F, Procedure 3, 40 CFR 64.6(c)(1)(iii), R 336.1213)**
  
12. The permittee shall equip the boiler with and properly maintain an oxygen trim system that maintains an optimum air-to-fuel ratio. **(40 CFR 63.11200(f))**

**V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall sample all solid fuels burned in EUBOILER on an annual basis and have the samples tested for chromium and mercury content in ppm dry weight.<sup>1</sup> **(R 336.1225)**
  
2. The permittee shall sample all solid fuels burned in EUBOILER on an annual basis and have the samples tested for chlorine content in percent by dry weight.<sup>1</sup> **(R 336.1225)**
  
3. The permittee shall verify PM-10, arsenic, benzo(a)pyrene, hydrogen chloride, hexavalent chromium, total chromium, lead, mercury compounds, Sulfuric Acid, TCDD Toxic Equivalent, and VOC expressed as propane emission rates from EUBOILER by testing at owner's expense, in accordance with the Department requirements. The hourly emission rate shall be determined by the average of three test runs, per the method requirements. Testing shall be performed using an approved USEPA Method listed in:

<b>Pollutant</b>	<b>Test Method Reference</b>
PM-10	40 CFR Part 51, Appendix M
Arsenic	40 CFR Part 60, Appendix A, 40 CFR Part 61, Appendix B, 40 CFR Part 63, Appendix A
Benzo(a)pyrene	40 CFR Part 60, Appendix A
Hydrogen Chloride	40 CFR Part 60, Appendix A
Hexavalent Chromium	40 CFR Part 60, Appendix A
Total Chromium	40 CFR Part 60, Appendix A
Lead	40 CFR Part 60, Appendix A 40 CFR Part 61, Appendix B, 40 CFR Part 63, Appendix A
Mercury Compounds	40 CFR Part 60, Appendix A, 40 CFR Part 61, Appendix B, 40 CFR Part 63, Appendix A
Sulfuric Acid	40 CFR Part 60, Appendix A
TCDD Toxic Equivalent	40 CFR Part 60, Appendix A
VOC	40 CFR Part 60, Appendix A

An alternate method, or a modification to the approved USEPA Method, may be specified in an AQD-approved Test Protocol. No less than 30 days prior to testing, the permittee shall submit a complete test plan to the AQD Technical Programs Unit and District Office. The AQD must approve the final plan prior to testing, including any modifications to the method in the test protocol that are proposed after initial submittal. The permittee must submit a complete report of the test results to the AQD Technical Programs Unit and District Office within 60 days following the last date of the test.<sup>2</sup> **(R 336.1213(3), R 336.2001, R 336.2003, R 336.2004)**

4. The permittee shall verify the PM10, arsenic, benzo(a)pyrene, hydrogen chloride, hexavalent chromium, total chromium, lead, mercury compounds, H<sub>2</sub>SO<sub>4</sub>, TCDD Toxic Equivalent, and VOC emission rates from EUBOILER, at a minimum, every five years from the date of the last test.<sup>2</sup> **(R 336.1213(3), R 336.2001, R 336.2003, R 336.2004)**
5. The permittee shall verify PM emission rates from EUBOILER by testing at owner's expense, in accordance with the Department requirements. The hourly emission rate shall be determined by the average of three test runs, per the method requirements. Testing shall be performed using an approved USEPA Method listed in:

<b>Pollutant</b>	<b>Test Method Reference</b>
PM	40 CFR Part 60, Appendix A; Part 10 of the Michigan Air Pollution Control Rules

An alternate method, or a modification to the approved USEPA Method, may be specified in an AQD-approved Test Protocol. No less than 30 days prior to testing, the permittee shall submit a complete test plan to the AQD Technical Programs Unit and District Office. The AQD must approve the final plan prior to testing, including any modifications to the method in the test protocol that are proposed after initial submittal. The permittee must submit a complete report of the test results to the AQD Technical Programs Unit and District Office within 60 days following the last date of the test. **(R 336.1213(3), R 336.2001, R 336.2003, R 336.2004)**

6. The permittee shall verify the PM emission rate from EUBOILER, at a minimum, every five years from the date of the last test. **(R 336.1213(3), R 336.2001, R 336.2003, R 336.2004)**
7. The permittee shall perform exhaust gas flow rate testing for EUBOILER to determine the average flow rate which shall be used, in conjunction with CEM data, to calculate NO<sub>x</sub>, SO<sub>2</sub>, and CO pound per hour emission rates.<sup>2</sup> **(R 336.2001, R 336.2003, R 336.2004)**
8. Annual flow rate testing shall be performed using an approved method listed in 40 CFR Part 60, Appendix A. An alternate method, or a modification to the approved USEPA Method, may be specified in an AQD-approved Test Protocol. No less than 30 days prior to testing, the permittee shall submit a complete test plan to the AQD Technical Programs Unit and District Office. The AQD must approve the final plan prior to testing, including any modifications to the method in the test protocol that are proposed after initial submittal. The permittee must submit a complete report of the test results to the AQD Technical Programs Unit and District Office within 60 days following the last date of the test. **(R 336.1213(3), R 336.2001, R 336.2003, R 336.2004)**
9. The permittee shall verify the exhaust gas flow rate from EUBOILER, at a minimum, one calendar year from the date of the last test. **(R 336.1213(3), R 336.2001, R 336.2003, R 336.2004)**
10. The permittee shall notify the AQD Technical Programs Unit Supervisor and the District Supervisor not less than 7 days of the time and place before performance tests are conducted. **(R 336.1213(3), R 336.2001)**

## **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall use the COMS to assure compliance with the PM limit. An excursion for PM shall be two consecutive 1-hour block average opacity values greater than 15 percent opacity. This condition does not affect compliance with R 336.1301. **(40 CFR 64.6(c)(2))**
2. The permittee shall monitor and record the visible emissions from EUBOILER on a continuous basis in a manner and with instrumentation acceptable to the AQD. Six minute averages shall be based on 36 or more equally spaced instantaneous opacity measurements per six minute period.<sup>2</sup> **(40 CFR 60.48b(a), 40 CFR 60.49b(f), 40 CFR 60.13, 40 CFR 64.6(c)(1)(ii))**
3. The permittee shall use the COMS as an indicator of proper functioning of the electrostatic precipitator. The appropriate range of opacity defining proper function of the electrostatic precipitator is 0-15 percent opacity. **(40 CFR 64.6(c)(1)(i) and (ii))**

4. In the event of an excursion of more than 15 percent opacity, based on two consecutive 1-hour block averages, the permittee shall examine and correct the electrostatic precipitator primary and secondary voltage in accordance to the MAP. **(40 CFR 64.7(d))**
5. The permittee shall implement a quality improvement plan if the total duration of opacity excursions is greater than 5 percent of the total EU BOILER operating time during the reporting time, excluding startup and shutdown. **(40 CFR 64.8(a))**
6. The permittee shall operate the COMS during all required periods when EUBOILER is operating. Data recorded during monitoring malfunctions, repairs, and QA/QC operations shall not be used to demonstrate compliance with 40 CFR Part 64. **(40 CFR 64.6(c)(3), 40 CFR 64.7(c))**
7. The permittee shall monitor and record the CO, NO<sub>x</sub>, SO<sub>2</sub>, and O<sub>2</sub> emissions from EU BOILER on a continuous basis in a manner and with instrumentation acceptable to the AQD.<sup>2</sup> **(R 336.1205(1), R 336.1225)**
8. For all pollutants not monitored by CEMS, the permittee shall establish emission factors using the most recent stack testing data. These emission factors shall be applied to calculate emissions of each pollutant. in the same units across the same time periods as the emission limits in Section I of this table. <sup>2</sup> **(R 336.1224, R 336.1225(6)(a))**
9. The permittee shall calculate and maintain records of CO, NO<sub>x</sub>, and SO<sub>2</sub> in pounds per hour and pounds per million BTU heat input emission rates using hourly averages of continuous emission monitoring data, in parts per million, and the average flow rate established in the most recent flow data testing.<sup>2</sup> **(R 336.1205(1))**
10. The permittee shall calculate and maintain records of PM, PM-10, VOC, Lead, and Sulfuric Acid from EUBOILER in pounds per million BTU heat input, using emission factors based on the most recent emissions tests. **(R 336.1224, R 336.1225(6)(a))**
11. The permittee shall calculate and maintain records of PM-10, VOC, Arsenic, Benzo(a)pyrene, Hydrogen Chloride, Hexavalent Chromium, Total Chromium, Lead, Mercury Compounds, H<sub>2</sub>SO<sub>4</sub>, and TCDD Toxic Equivalent, in pounds per hour, from EUBOILER, using emission factors based on the most recent emissions tests. **(R 336.1224, R 336.1225(6)(a))**
12. The permittee shall calculate and maintain records of Arsenic, Benzo(a)pyrene, Hydrogen Chloride, Hexavalent Chromium, Total Chromium, Mercury Compounds, and TCDD Toxic Equivalent, as a concentration expressed in micrograms per dry standard cubic meter, from EUBOILER, using emission factors based on the most recent emissions tests. **(R 336.1224, R 336.1225(6)(a))**
13. The permittee shall keep, in a satisfactory manner, monthly and 12-month rolling time period emission calculation records of CO, NO<sub>x</sub>, SO<sub>2</sub>, PM-10, VOC, Hydrogen Chloride, Hexavalent Chromium, Total Chromium, Lead, Mercury Compounds, H<sub>2</sub>SO<sub>4</sub>, and TCDD Toxic Equivalent, in tons, from EUBOILER. The permittee shall use stack test results and the calculation in Appendix 7, or CEMS, to calculate pollutant emissions. The permittee shall keep all records on file at the facility and make them available to the Department upon request.<sup>2</sup> **(R 336.1205, R 336.1225)**
14. The permittee shall properly maintain the monitoring system including keeping necessary parts for routine repair of the monitoring equipment. **(40 CFR 64.7(b))**
15. The permittee shall operate the monitoring device during all periods that the emissions unit is operating. Data recorded during monitoring malfunctions, repair activities, and QA/QC operations shall not be used to determine 40 CFR Part 64 compliance. **(40 CFR 64.6(c)(3), 64.7(c))**
16. The permittee shall monitor and record the natural gas usage in EUBOILER on a continuous basis in a manner and with instrumentation acceptable to the AQD. **(R 336.1213(3))**

17. By the fifth calendar day of each month, the permittee shall calculate the total usage of natural gas for the previous month and a 12-month rolling time period. The calendar month natural gas usage rate records and the 12-month rolling time period calculations shall be made available to the AQD upon request. These records may be stored electronically.<sup>2</sup> **(R 336.1205(1), 40 CFR 52.21(c) and (d), 40 CFR 60.49b(d))**
18. The permittee shall record and maintain records of the amounts of each fuel combusted during each day and calculate the annual capacity factor individually for natural gas and wood for the reporting period. The annual capacity factor is determined on a 12-month rolling average basis with a new annual capacity factor calculated at the end of each calendar month. **(40 CFR 60.43b(e), 40 CFR 60.49b(d)(1))**
19. Each calendar day, the permittee shall calculate the total fuel burned for the previous 24 hours period for particle board/plywood fuel; creosote treated wood fuel; for pentachlorophenol treated wood; and for TDF in a manner acceptable to the AQD. All records of calculations shall be made available to the AQD upon request. These records may be stored electronically.<sup>2</sup> **(R 336.1205(1), R 336.1224, R 336.1225, 40 CFR 52.21(c) and (d))**
20. The permittee shall maintain a written log of the hours of operation of EUBOILER. These records may be stored electronically.<sup>2</sup> **(R 336.1205(1), R 336.1224, R 336.1225, 40 CFR 52.21(c) and (d))**
21. The permittee shall maintain records of the following information for each steam generating unit operating day: **(40 CFR 60.49b(g))**
  - a. Calendar date
  - b. The average hourly NO<sub>x</sub> emission rates (expressed as NO<sub>2</sub>) (in lb/MMBtu heat input) measured or predicted
  - c. The 30-day average NO<sub>x</sub> emission rates in lb/MMBtu heat input, calculated at the end of each steam generating unit operating day from the measured or predicted hourly nitrogen oxide emission rates for the preceding 30 steam generating unit operating days
  - d. Identification of the steam generating unit operating days when the calculated 30-day average NO<sub>x</sub> emission rates are in excess of the NO<sub>x</sub> emissions standards under 40 CFR 60.44b, with the reasons for such excess emissions as well as a description of corrective actions taken
  - e. Identification of the steam generating unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken
  - f. Identification of the times when emission data have been excluded from the calculation of average emission rates and the reasons for excluding data
  - g. Identification of "F" factor used for calculations, method of determination, and type of fuel combusted
  - h. Identification of the times when the pollutant concentration exceeded full span of the CEMS
  - i. Description of any modifications to the CEMS that could affect the ability of the CEMS to comply with Performance Specification 2 or 3; and
  - j. Results of daily CEMS drift tests and quarterly accuracy assessments as required under Appendix F, Procedure 1 of this part.
22. Upon detecting an excursion or exceedance, the owner or operator shall restore operation of EUBOILER (including the cyclone collector and ESP) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution practices for minimizing emissions. The response shall include minimizing the period of any startup, shutdown or malfunction and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion or exceedance (other than those caused by excused startup or shutdown conditions). In response to an excursion of more than 15% opacity based on 2 consecutive 1-hour block averages the permittee shall initiate an evaluation of electrostatic precipitator secondary voltage. **(40 CFR 64.7(d))**
23. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the owner or operator shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that EUBOILER is operating. Data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities shall not be used for purposes of Compliance Assurance

Monitoring, including data averages and calculations or fulfilling a minimum data availability requirement, if applicable. The owner or operator shall use all the data collected during all other periods in assessing the operation of the cyclone collector and ESP. A monitoring malfunction is any sudden, in frequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions." The permittee shall operate the COMS during all required periods when the boiler is operating. Data recorded during monitoring malfunctions, repair activities and QA/QC operations shall not be used for 40 CFR, Part 64 compliance. **(40 CFR 64.6(c)(3), (40 CFR 64.7(c))**

24. The permittee shall maintain written procedures for the opacity monitor quality assurance program, and shall make them available to Federal, State, and Local Air Quality representatives upon request. **(40 CFR Part 60, Appendix F, Procedure 3(9.1))**
25. The permittee must maintain the records specified in paragraphs (c)(1) through (7) of Section 63.11225, as listed below. **(40 CFR 63.11225(c))**
  - a. As required in Section 63.10(b)(2)(xiv), the permittee must keep a copy of each notification and report that the permittee submitted to comply with 40 CFR Part 63, Subpart JJJJJJ and all documentation supporting any Initial Notification or Notification of Compliance Status that the permittee submitted. **(40 CFR 63.11225(c)(1))**
  - b. The permittee must keep records to document conformance with the work practices, emission reduction measures, and management practices required by Sections 63.11214 and 63.11223 as specified in paragraphs (c)(2)(i) through (vi) of Section 63.11225, as listed below. **(40 CFR 63.11225(c)(2))**
    - i. Records must identify each boiler, the date of tune-up, the procedures followed for tune-up, and the manufacturer's specifications to which the boiler was tuned. **(40 CFR 63.11225(c)(2)(i))**
    - ii. For operating units that combust non-hazardous secondary materials that have been determined not to be solid waste pursuant to 40 CFR Section 241.3(b)(1), the permittee must keep a record which documents how the secondary material meets each of the legitimacy criteria under 40 CFR Section 241.3(d)(1). If the permittee combusts a fuel that has been processed from a discarded non-hazardous secondary material pursuant to 40 CFR Section 241.3(b)(4), the permittee must keep records as to how the operations that produced the fuel satisfies the definition of processing in 40 CFR Section 241.2 and each of the legitimacy criteria in 40 CFR Section 241.3(d)(1). If the fuel received a non-waste determination pursuant to the petition process submitted under 40 CFR Section 241.3(c), the permittee must keep a record that documents how the fuel satisfies the requirements of the petition process. For operating units that combust non-hazardous secondary materials as fuel per 40 CFR Section 241.4, the permittee must keep records documenting that the material is a listed non-waste under 40 CFR Section 241.4(a). **(40 CFR 63.11225(c)(2)(ii))**
    - iii. For each boiler required to conduct an energy assessment, the permittee must keep a copy of the energy assessment report. **(40 CFR 63.11225(c)(2)(iii))**
  - c. Records of the occurrence and duration of each malfunction of the boiler. **(40 CFR 63.11225(c)(4))**
  - d. Records of actions taken during periods of malfunction to minimize emissions in accordance with the general duty to minimize emissions in Section 63.11205(a), stated in SC IX.4, including corrective actions to restore the malfunctioning boiler to its normal or usual manner of operation. **(40 CFR 63.11225(c)(5))**
26. The permittee's records must be in a form suitable and readily available for expeditious review. The permittee must keep each record for 5 years following the date of each recorded action. The permittee must keep each record on-site or be accessible from a central location by computer or other means that instantly provide access at the site for at least 2 years after the date of each recorded action. The permittee may keep the records off site for the remaining 3 years. **(40 CFR 63.11225(d))**
27. The permittee shall maintain records of monitoring data, monitor performance data, corrective actions taken, any written quality improvement plan, and other information such as data used to document the adequacy of monitoring or records of monitoring maintenance or corrective actions. **(40 CFR 64.9(b)(1))**
28. The permittee shall monitor secondary voltage for the electrostatic precipitator. **(40 CFR 64.6(c)(1)(i), (ii))**

## **VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
1. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
4. Prior to installation or replacement of any CEMS or COMS, the permittee shall submit a monitoring plan to the District Supervisor for review and approval. The monitoring plan shall include drawings or specifications showing proposed locations and descriptions of all required monitor(s).<sup>2</sup> **(R 336.2155, 40 CFR 60.13)**
5. In accordance with 40 CFR 60.7(c) and (d) an excess emissions report (EER) and summary report shall be submitted in an acceptable format to the District Supervisor within 30 days following the end of each calendar quarter for all CEMS and COMS. The EER shall include each occurrence of all exceedances and the magnitudes of the excess emissions of the specified permit limit, the cause of the excess emissions, if known, periods of monitoring system downtime, any corrective action taken and the total operating time of the source(s). If no exceedances or monitoring system downtime occurred during the reporting period, the permittee shall report that fact.<sup>2</sup> **(R 336.2170, 40 CFR 60.7, 40 CFR 60.49b(h))**
6. Each semiannual report of monitoring and deviations shall include summary information on the number, duration and cause of excursions and/or exceedances and the corrective actions taken. If there were no excursions and/or exceedances in the reporting period, then this report shall include a statement that there were no excursions and/or exceedances. **(40 CFR 64.9(a)(2)(i))**
7. Each semiannual report of monitoring and deviations shall include summary information on monitoring downtime. If there were no periods of monitor downtime in the reporting period, then this report shall include a statement that there were no periods of monitor downtime. **(40 CFR 64.9(a)(2)(ii))**
8. The permittee shall report the results of the quality assurance procedures of the CEMS set forth in 40 CFR Part 60, Appendix F, Procedure 1 of to the AQD District Supervisor within the quarterly EER for the quarter in which the audit is conducted.<sup>2</sup> **(40 CFR Part 60, Appendix B, Procedure 1, R 336.1213(3))**
9. The permittee shall submit the results of the quality assurance procedures of the COMS set forth in 40 CFR Part 60, Appendix F, Procedure 3 to the AQD District Supervisor within the quarterly EER for the quarter in which the audit is conducted.<sup>2</sup> **(40 CFR Part 60, Appendix B, Procedure 3, R 336.1213(3))**
10. The permittee must prepare, by March 1 of each year, and submit to the delegated authority upon request, an annual compliance certification report for the previous calendar year containing the information specified in paragraphs (b)(1) through (4) of Section 63.11225. For boilers that are subject only to a requirement to conduct a 5-year tune-up according to Section 63.11223(a) and not subject to emission limits or operating limits, the permittee may prepare only a 5-year compliance report as specified in paragraphs (b)(1) and (2) of Section 63.11225, as listed below. **(40 CFR 63.11225(b))**
  - a. Company name and address. **(40 CFR 63.11225(b)(1))**
  - b. Statement by a responsible official, with the official's name, title, phone number, email address, and signature, certifying the truth, accuracy and completeness of the notification and a statement of whether the source has complied with all the relevant standards and other requirements of 40 CFR Part 63, Subpart JJJJJ. The permittee's notification must include the following certification(s) of compliance, as applicable, and signed by a responsible official: **(40 CFR 63.11225(b)(2))**
    - i. "This facility complies with the requirements in Section 63.11223 to conduct a biennial or 5-year tune-up, as applicable, of each boiler." **(40 CFR 63.11225(b)(2)(i))**

ii. For units that do not qualify for a statutory exemption as provided in Section 129(g)(1) of the Clean Air Act: "No secondary materials that are solid waste were combusted in any affected unit."  
**(40 CFR 63.11225(b)(2)(ii))**

11. If the permittee intends to commence or recommence combustion of solid waste, the permittee must provide 30 days prior notice of the date upon which the permittee will commence or recommence combustion of solid waste. The notification must identify: **(40 CFR 63.11225(f))**
  - a. The name of the owner or operator of the affected source, the location of the source, the boiler(s) that will commence burning solid waste, and the date of the notice. **(40 CFR 63.11225(f)(1))**
  - b. The currently applicable subcategory under 40 CFR Part 63, Subpart JJJJJJ. **(40 CFR 63.11225(f)(2))**
  - c. The date on which the permittee became subject to the currently applicable emission limits. **(40 CFR 63.11225(f)(3))**
  - d. The date upon which the permittee will commence combusting solid waste. **(40 CFR 63.11225(f)(4))**
  
12. If the permittee has switched fuels or made a physical change to the boiler and the fuel switch or change resulted in the applicability of a different subcategory within 40 CFR Part 63, Subpart JJJJJJ, in the boiler becoming subject to 40 CFR Part 63, Subpart JJJJJJ, or in the boiler switching out of 40 CFR Part 63, Subpart JJJJJJ due to a change to 100 percent natural gas, or the permittee has taken a permit limit that resulted in the permittee being subject to 40 CFR Part 63, Subpart JJJJJJ, the permittee must provide notice of the date upon which the permittee switched fuels, made the physical change, or took a permit limit within 30 days of the change. The notification must identify: **(40 CFR 63.11225(g))**
  - a. The name of the owner or operator of the affected source, the location of the source, the boiler(s) that have switched fuels, were physically changed, or took a permit limit, and the date of the notice. **(40 CFR 63.11225(g)(1))**
  - b. The date upon which the fuel switch, physical change, or permit limit occurred. **(40 CFR 63.11225(g)(2))**

See Appendix 8

**VIII. STACK/VENT RESTRICTION(S)**

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Diameter / Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SVBOILER	72 <sup>2</sup>	150 <sup>2</sup>	40 CFR 52.21 (c) and (d)

**IX. OTHER REQUIREMENT(S)**

1. The permittee shall promptly notify AQD for the need to modify the CAM Plan if the existing plan is found to be inadequate and shall submit a proposed modification to the ROP if necessary. **(40 CFR 64.7(e))**
2. The permittee shall perform the COMS quality assurance procedure set forth in 40 CFR Part 60, Appendix F, Procedure 3, or a method acceptable to the AQD. Within 30 days after completion of Procedure 3, the permittee shall submit the results to the AQD. **(R 336.1213(3), 40 CFR Part 60, Appendix F)**
3. The permittee shall perform the quarterly quality assurance procedures of the CEMS set forth in Appendix F of 40 CFR Part 60.<sup>2</sup> **(R 336.2170, 40 CFR Part 60, Appendix F)**
4. The permittee shall develop and implement a quality control plan and program for the opacity monitor, as specified in 40 CFR Part 60, Appendix F. **(40 CFR Part 60, Appendix F, Procedure 3(9.0))**

5. If the opacity monitor fails two consecutive annual audits, two consecutive quarterly audits, or five consecutive daily checks, the permittee shall either revise quality control procedures for the opacity monitor or determine whether the opacity monitor is malfunctioning and take Federally specified corrective actions. **(40 CFR Part 60, Appendix F, Procedure 3(9.2))**
6. The permittee shall comply with all applicable requirements of 40 CFR Part 64. **(40 CFR Part 64)**
7. At all times the permittee must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require the permittee to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator that may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source. **(40 CFR 63.11205(a))**
8. If the permittee owns or operates an industrial, commercial, or institutional boiler and would be subject to 40 CFR Part 63, Subpart JJJJJJ except for the exemption in Section 63.11195(b) for commercial and industrial solid waste incineration units covered by 40 CFR Part 60, Subpart CCCC or Subpart DDDD, and the permittee ceases combusting solid waste, the permittee must be in compliance with 40 CFR Part 63, Subpart JJJJJJ on the effective date of the waste to fuel switch as specified in Section 60.2145(a)(2) and (3) of Subpart CCCC or Section 60.2710(a)(2) and (3) of Subpart DDDD. **(40 CFR 63.11196(d))**
9. For affected boilers that ceased burning solid waste consistent with Section 63.11196(d) and for which the initial compliance date has passed, the permittee must demonstrate compliance within 60 days of the effective date of the waste-to-fuel switch as specified in Section 60.2145(a)(2) and (3) of Subpart CCCC or Section 60.2710(a)(2) and (3) of Subpart DDDD. If the permittee has not conducted their compliance demonstration for 40 CFR Part 63, Subpart JJJJJJ within the previous 12 months, the permittee must complete all compliance demonstrations for 40 CFR Part 63, Subpart JJJJJJ before commencing or recommencing combustion of solid waste. **(40 CFR 63.11210(g))**
10. For affected boilers that switch fuels or make a physical change to the boiler that results in the applicability of a different subcategory within 40 CFR Part 63, Subpart JJJJJJ or the boiler becoming subject to 40 CFR Part 63, Subpart JJJJJJ, the permittee must demonstrate compliance within 180 days of the effective date of the fuel switch or the physical change. Notification of such changes must be submitted according to Section 63.11225(g), stated in SC VIII.18. **(40 CFR 63.11210(h))**
11. Table 8 to 40 CFR Part 63, Subpart JJJJJJ, shows which parts of the General Provisions in Sections 63.1 through 63.15 apply to the permittee. **(40 CFR 63.11235)**
12. If the permittee identifies a failure to achieve compliance with an emission limitation or standard for which the approved monitoring did not provide an indication of an excursion or exceedance while providing valid data, or the results of compliance or performance testing document a need to modify the existing indicator ranges or designated conditions, the permittee shall promptly notify the AQD and if necessary, submit a proposed modification of the ROP and CAM Plan to address the necessary monitoring changes. Such a modification may include but is not limited to, reestablishing indicator ranges or designated conditions, modifying the frequency of conducting monitoring and collecting data, or the monitoring of additional parameters. **(40 CFR 64.7(e))**
13. The permittee shall comply with all provisions of 40 CFR Part 63, Subpart JJJJJJ, National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers, Area Sources. **(40 CFR Part 63, Subpart JJJJJJ)**

**Footnotes:**

<sup>1</sup> This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup> This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

**EUASHHANDLING  
 EMISSION UNIT CONDITIONS**

**DESCRIPTION**

Ash handling equipment. Fly ash and bottom ash is conveyed to a wet rotary unloader where water is added to control fugitive dust. The ash is then transported to an enclosed ash handling building where it is stored until it is trucked offsite.

**Flexible Group ID: NA**

**POLLUTION CONTROL EQUIPMENT**

Ash wetting system

**I. EMISSION LIMIT(S)**

Pollutant	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
2. Visible Emissions	5% opacity <sup>2</sup>	6-minute average	EUASHHANDLING	SC V.1	<b>R 336.1301 (1)(c)</b>

**II. MATERIAL LIMIT(S)**

NA

**III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. The permittee shall not operate EUASHHANDLING unless the wetting system is installed and operating properly.<sup>2</sup> **(R 336.1910, R 336.1205(1), 40 CFR 52.21(c) and (d))**
2. If visible emissions from EUASHHANDLING, observed according to SC V.1 of this table, exceed the 5% opacity limit of SC I.1, the permittee shall, within 24 hours, either shut down the process or conduct any maintenance needed to return opacity to within the 5% limit. **(R 336.1301, R 336.1213(3))**

**IV. DESIGN/EQUIPMENT PARAMETER(S)**

NA

**V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall observe and record visible emissions from EURMHANDLING once per calendar day. If any visible emissions are seen, the observations must be done by a certified observer, using USEPA Method 9, and must be conducted for a minimum of 15 minutes; otherwise, the observations may be informal. **(R 336.1301(1), R 336.1213(3))**

**VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. Records of daily visible emission observations, and those repairs and remedial actions performed in response to the daily visible emission observations, shall be made available to the AQD upon request. **(R 336.1301(1))**

## **VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**

See Appendix 8

## **VIII. STACK/VENT RESTRICTION(S)**

NA

## **IX. OTHER REQUIREMENT(S)**

NA

### **Footnotes:**

<sup>1</sup>This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup>This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

**EUGENERATOR  
 EMISSION UNIT CONDITIONS**

**DESCRIPTION**

Standby diesel-fired reciprocating Detroit Diesel 415hp emergency generator to provide electricity to the facility on an emergency basis. This engine is subject to 40 CFR Part 63, Subpart ZZZZ.

**Flexible Group ID: NA**

**POLLUTION CONTROL EQUIPMENT**

NA

**I. EMISSION LIMIT(S)**

Pollutant	Limit	Time Period/Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. SO <sub>2</sub>	0.56 pounds per million BTU heat input, equivalent to using fuel oil with a 0.5% sulfur content and a heat value of 18,000 BTUs per pound <sup>2</sup>	24-hour average	EUGENERATOR	SC VI.2	<b>40 CFR 52.21 (c) and (d)</b>

**II. MATERIAL LIMIT(S)**

NA

**III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. The permittee shall not operate the standby diesel generator for more than 100 hours per year.<sup>2</sup> **(R 336.1205(1), 40 CFR 52.21(c) and (d))**
2. The permittee shall operate and maintain the standby diesel generator in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require the permittee to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source. **(40 CFR 63.6605(b))**
3. The permittee may operate the standby diesel generator for any combination of the following purposes for a maximum of 100 hours per calendar year. Maintenance checks and readiness testing provided that the tests are recommended by federal, state, or local government, the engine manufacturer or vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the standby diesel generator. The owner or operator may petition the administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of the standby diesel generator beyond 100 hours per calendar year. **(40 CFR 63.6640(f)(2))**

4. The permittee may operate the standby diesel generator for up to 50 hours per engine per year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours of operation allowed under SC III.3. The 50 hours per year for non-emergency situations cannot be used for peak shaving or to generate income for a facility to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity. **(40 CFR 63.6640(f)(3))**

#### **IV. DESIGN/EQUIPMENT PARAMETER(S)**

1. The permittee shall equip the generator engine with a non-resettable hour meter. **(R 336.1213(3)), 40 CFR 63.6655(f)**

#### **V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

NA

#### **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. A written log of the hours of operation of EUGENERATOR shall be kept on file. The log shall be made available to the AQD upon request. These records may be stored electronically<sup>2</sup> **(R 336.1205(1), 40 CFR 52.21(c) and (d))**
2. The permittee shall obtain analytical results for each shipment of diesel fuel used in EUGENERATOR to include the sulfur content as a percent and the heating value of the fuel in BTU per gallon. The lb/MMBtu emission rate shall be calculated for each shipment of diesel fuel as outlined in Appendix 7. **(R 336.1213(3))**

#### **VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**

See Appendix 8

#### **VIII. STACK/VENT RESTRICTION(S)**

NA

#### **IX. OTHER REQUIREMENT(S)**

1. The permittee shall comply with the requirements of 40 CFR Part 63, Subpart ZZZZ (RICE Area MACT) as they apply to EUGENERATOR. **(40 CFR Part 63, Subparts A and ZZZZ)**

#### **Footnotes:**

<sup>1</sup> This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup> This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

## D. FLEXIBLE GROUP SPECIAL CONDITIONS

Part D outlines the terms and conditions that apply to more than one emission unit. The permittee is subject to the special conditions for each flexible group in addition to the General Conditions in Part A and any other terms and conditions contained in this ROP.

The permittee shall comply with all specific details in the special conditions and the underlying applicable requirements cited. If a specific condition type does not apply, NA (not applicable) has been used in the table. If there are no special conditions that apply to more than one emission unit, this section will be left blank.

### FLEXIBLE GROUP SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Flexible Group ID	Flexible Group Description	Associated Emission Unit IDs
FGCOLDCLEANERS	Any cold cleaner that is grandfathered or exempt from Rule 201 pursuant to Rule 278 and Rule 281(h) or Rule 285(r)(iv). Existing cold cleaners were placed into operation prior to July 1, 1979. New cold cleaners were placed into operation on or after July 1, 1979.	EUCLDCLNR

## **FGCOLDCLEANERS FLEXIBLE GROUP CONDITIONS**

### **DESCRIPTION**

Any cold cleaner that is grandfathered or exempt from Rule 201 pursuant to Rule 278, 278a and Rule 281(2)(h) or Rule 285(2)(r)(iv). Existing cold cleaners were placed into operation prior to July 1, 1979. New cold cleaners were placed into operation on or after July 1, 1979.

**Emission Unit:** EUCLDCLNR

### **POLLUTION CONTROL EQUIPMENT**

NA

### **I. EMISSION LIMIT(S)**

NA

### **II. MATERIAL LIMIT(S)**

1. The permittee shall not use cleaning solvents containing more than five percent by weight of the following halogenated compounds: methylene chloride, perchloroethylene, trichloroethylene, 1,1,1-trichloroethane, carbon tetrachloride, chloroform, or any combination thereof. **(R 336.1213(2))**

### **III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. Cleaned parts shall be drained for no less than 15 seconds or until dripping ceases. **(R 336.1611(2)(b), R 336.1707(3)(b))**
2. The permittee shall perform routine maintenance on each cold cleaner as recommended by the manufacturer. **(R 336.1213(3))**

### **IV. DESIGN/EQUIPMENT PARAMETER(S)**

1. The cold cleaner must meet one of the following design requirements:
  - a. The air/vapor interface of the cold cleaner is no more than ten square feet. **(R 336.1281(2)(h))**
  - b. The cold cleaner is used for cleaning metal parts and the emissions are released to the general in-plant environment. **(R 336.1285((2)r)(iv))**
2. The cold cleaner shall be equipped with a device for draining cleaned parts. **(R 336.1611(2)(b), R 336.1707(3)(b))**
3. All new and existing cold cleaners shall be equipped with a cover and the cover shall be closed whenever parts are not being handled in the cold cleaner. **(R 336.1611(2)(a), R 336.1707(3)(a))**
4. The cover of a new cold cleaner shall be mechanically assisted if the Reid vapor pressure of the solvent is more than 0.3 psia or if the solvent is agitated or heated. **(R 336.1707(3)(a))**
5. If the Reid vapor pressure of any solvent used in a new cold cleaner is greater than 0.6 psia; or, if any solvent used in a new cold cleaner is heated above 120 degrees Fahrenheit, then the cold cleaner must comply with at least one of the following provisions:
  - a. The cold cleaner must be designed such that the ratio of the freeboard height to the width of the cleaner is equal to or greater than 0.7. **(R 336.1707(2)(a))**

- b. The solvent bath must be covered with water if the solvent is insoluble and has a specific gravity of more than 1.0. **(R 336.1707(2)(b))**
- c. The cold cleaner must be controlled by a carbon adsorption system, condensation system, or other method of equivalent control approved by the AQD. **(R 336.1707(2)(c))**

## **V. TESTING/SAMPLING**

NA

## **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. For each new cold cleaner in which the solvent is heated, the solvent temperature shall be monitored and recorded at least once each calendar week during routine operating conditions. **(R 336.1213(3))**
2. The permittee shall maintain the following information on file for each cold cleaner: **(R 336.1213(3))**
  - a. A serial number, model number, or other unique identifier for each cold cleaner.
  - b. The date the unit was installed, manufactured or that it commenced operation.
  - c. The air/vapor interface area for any unit claimed to be exempt under Rule 281(2)(h).
  - d. The applicable Rule 201 exemption.
  - e. The Reid vapor pressure of each solvent used.
  - f. If applicable, the option chosen to comply with Rule 707(2).
3. The permittee shall maintain written operating procedures for each cold cleaner. These written procedures shall be posted in an accessible, conspicuous location near each cold cleaner. **(R 336.1611(3), R 336.1707(4))**
4. As noted in Rule 611(2)(c) and Rule 707(3)(c), if applicable, an initial demonstration that the waste solvent is a safety hazard shall be made prior to storage in non-closed containers. If the waste solvent is a safety hazard and is stored in non-closed containers, verification that the waste solvent is disposed of so that not more than 20 percent, by weight, is allowed to evaporate into the atmosphere shall be made on a monthly basis. **(R 336.1213(3), R 336.1611(2)(c), R 336.1707(3)(c))**

## **VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**

**See Appendix 8**

## **VIII. STACK/VENT RESTRICTION(S)**

NA

**IX. OTHER REQUIREMENT(S)**

NA

**Footnotes:**

<sup>1</sup> This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup> This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

## **E. NON-APPLICABLE REQUIREMENTS**

At the time of the ROP issuance, the AQD has determined that no non-applicable requirements have been identified for incorporation into the permit shield provision set forth in the General Conditions in Part A pursuant to Rule 213(6)(a)(ii).

## APPENDICES

### Appendix 1. Acronyms and Abbreviations

Common Acronyms		Pollutant / Measurement Abbreviations	
AQD	Air Quality Division	acfm	Actual cubic feet per minute
BACT	Best Available Control Technology	BTU	British Thermal Unit
CAA	Clean Air Act	°C	Degrees Celsius
CAM	Compliance Assurance Monitoring	CO	Carbon Monoxide
CEM	Continuous Emission Monitoring	CO <sub>2</sub> e	Carbon Dioxide Equivalent
CEMS	Continuous Emission Monitoring System	dscf	Dry standard cubic foot
CFR	Code of Federal Regulations	dscm	Dry standard cubic meter
COM	Continuous Opacity Monitoring	°F	Degrees Fahrenheit
Department/ department	Michigan Department of Environment, Great Lakes, and Energy	gr	Grains
EGLE	Michigan Department of Environment, Great Lakes, and Energy	HAP	Hazardous Air Pollutant
EU	Emission Unit	Hg	Mercury
FG	Flexible Group	hr	Hour
GACS	Gallons of Applied Coating Solids	HP	Horsepower
GC	General Condition	H <sub>2</sub> S	Hydrogen Sulfide
GHGs	Greenhouse Gases	kW	Kilowatt
HVLP	High Volume Low Pressure*	lb	Pound
ID	Identification	m	Meter
IRSL	Initial Risk Screening Level	mg	Milligram
ITSL	Initial Threshold Screening Level	mm	Millimeter
LAER	Lowest Achievable Emission Rate	MM	Million
MACT	Maximum Achievable Control Technology	MW	Megawatts
MAERS	Michigan Air Emissions Reporting System	NMOC	Non-methane Organic Compounds
MAP	Malfunction Abatement Plan	NO <sub>x</sub>	Oxides of Nitrogen
MSDS	Material Safety Data Sheet	ng	Nanogram
NA	Not Applicable	PM	Particulate Matter
NAAQS	National Ambient Air Quality Standards	PM10	Particulate Matter equal to or less than 10 microns in diameter
NESHAP	National Emission Standard for Hazardous Air Pollutants	PM2.5	Particulate Matter equal to or less than 2.5 microns in diameter
NSPS	New Source Performance Standards	pph	Pounds per hour
NSR	New Source Review	ppm	Parts per million
PS	Performance Specification	ppmv	Parts per million by volume
PSD	Prevention of Significant Deterioration	ppmw	Parts per million by weight
PTE	Permanent Total Enclosure	%	Percent
PTI	Permit to Install	psia	Pounds per square inch absolute
RACT	Reasonable Available Control Technology	psig	Pounds per square inch gauge
ROP	Renewable Operating Permit	scf	Standard cubic feet
SC	Special Condition	sec	Seconds
SCR	Selective Catalytic Reduction	SO <sub>2</sub>	Sulfur Dioxide
SNCR	Selective Non-Catalytic Reduction	TAC	Toxic Air Contaminant
SRN	State Registration Number	Temp	Temperature
TEQ	Toxicity Equivalence Quotient	THC	Total Hydrocarbons
USEPA/EPA	United States Environmental Protection Agency	tpy	Tons per year
VE	Visible Emissions	µg	Microgram
		µm	Micrometer or Micron
		VOC	Volatile Organic Compounds
		yr	Year

\*For HVLP applicators, the pressure measured at the gun air cap shall not exceed 10 psig.

**Appendix 2. Schedule of Compliance**

The permittee certified in the ROP application that this stationary source is in compliance with all applicable requirements and the permittee shall continue to comply with all terms and conditions of this ROP. A Schedule of Compliance is not required. (R 336.1213(4)(a), R 336.1119(a)(ii))

**Appendix 3. Monitoring Requirements**

Specific monitoring requirement procedures, methods or specifications are detailed in Part A or the appropriate Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Therefore, this appendix is not applicable.

**Appendix 4. Recordkeeping**

Specific recordkeeping requirement formats and procedures are detailed in Part A or the appropriate Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Therefore, this appendix is not applicable.

**Appendix 5. Testing Procedures**

Specific testing requirement plans, procedures, and averaging times are detailed in the appropriate Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Therefore, this appendix is not applicable.

**Appendix 6. Permits to Install**

The following table lists any PTIs issued or ROP revision applications received since the effective date of the previously issued ROP No. MI-ROP-N0890-2013. Those ROP revision applications that are being issued concurrently with this ROP renewal are identified by an asterisk (\*). Those revision applications not listed with an asterisk were processed prior to this renewal.

Source-Wide PTI No MI-PTI-N0890-2013a is being reissued as Source-Wide PTI No. MI-PTI-N0890-2020a.

Permit to Install Number	ROP Revision Application Number	Description of Equipment or Change	Corresponding Emission Unit(s) or Flexible Group(s)
NA	NA	NA	NA

**Appendix 7. Emission Calculations**

The permittee shall use the following calculations in conjunction with monitoring, testing or recordkeeping data to determine compliance with the applicable requirements referenced in EUBOILER.

For pollutants **not** monitored by CEMS, the following formula shall be used to calculate emissions:

$$Emissions(tpm) = \frac{tons}{hour} (feed\ calculated) \times \frac{pound}{hour} (emissions\ test) \times \frac{hour}{ton} (test\ feed) \times \frac{hours}{month} (operated) \times \frac{ton}{2000\ pound}$$

12 Month Rolling Time Period Emission = Emissions (tpm) for most recent month + Σ previous 11 months Emissions (tpm)

Where:

tpm – is tons per month

Feed calculated – is the feed rate in tons per hour of each specific fuel achieved during the reporting period in question.

Emissions test – is the final result of pollutant emissions in pounds per hour, as measured in the most recent valid stack test.

Feed test – is the feed rate in tons per hour of each specific fuel achieved during the most recent valid stack test.

Operated – is the hours EUBOILER operated in a given month.

The permittee shall use the following calculations in conjunction with monitoring, testing or recordkeeping data to determine compliance with the applicable requirements referenced in EUGENERATOR.

The permittee shall calculate the lb/MMBtu SO<sub>2</sub> emission rate from each shipment of oil if this is not provided with the laboratory analysis of the fuel oil. The lb/MMBtu SO<sub>2</sub> emissions shall be calculated as follows:

$$SO_2 Emissions = Sulfur Content \times Fuel Density \times \frac{1}{Heating Value} \times \frac{10^6 BTU}{MMBTU} \times \frac{1 lb - mole S}{32 lb S} \times \frac{1 lb - mole SO_2}{1 lb - mole S} \times \frac{64 lb SO_2}{1 lb - mole SO_2}$$

Where:

S- is Sulfur

SO<sub>2</sub> Emissions – is pound/MMBTU

Sulfur Content – is ppm

Fuel Density – is 7.0 pound / Gallon or other as approved by AQD

Heating Value – is BTU / Gallon Fuel

Feed (calculated) – is the feed rate of each specific fuel achieved during the reporting period in question. Where the emission limit is stated in pounds per hour, the reporting period shall not exceed 24 hours.

Emissions (test) – is the final result of pollutant emissions in the appropriate units (ie. pound/MMBTU, lb/hr, ppmv, etc) as measured in the most recent valid stack test.

Feed (test) – is the feed rate of each specific fuel achieved during the most recent valid stack test.

## Appendix 8. Reporting

### A. Annual, Semiannual, and Deviation Certification Reporting

The permittee shall use EGLE, AQD, Report Certification form (EQP 5736) and EGLE, AQD, Deviation Report form (EQP 5737) for the annual, semiannual and deviation certification reporting referenced in the Reporting Section of the Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Alternative formats must meet the provisions of Rule 213(4)(c) and Rule 213(3)(c)(i), respectively, and be approved by the AQD District Supervisor.

### B. Other Reporting

Specific reporting requirement formats and procedures are detailed in Part A or the appropriate Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Therefore, Part B of this appendix is not applicable.