

Great Lakes Gas Transmission – Rapid River Compressor Station No. 9 Preventive Maintenance / Malfunction Abatement Plan

Rev. January 2023

1.0 Introduction

The Rapid River Compressor Station No. 9 is located at 10888 T-65 Pipeline Road in Rapid River, Delta County, Michigan 49878. The primary function of this facility is to provide motive force for natural gas flowing through the pipeline. This plan provides preventative maintenance and malfunction abatement measures for one (1) stationary natural gas-fired turbine (EUUNIT901), which in turn drives a single natural gas compressor.

2.0 Contact Information

Any questions regarding this PM/MAP should be directed to:

Name: Chris McFarlane
Title: Analyst – US Natural Gas Environmental
Phone: (832) 320-5490
E-mail: chris_mcfarlane@tcenergy.com
Address: TC Energy
700 Louisiana
Houston, TX 77002

The following station personnel are responsible for the overall performance and maintenance of the prime movers at the Rapid River Compressor Station No. 9.

Name: Trent Meske
Title: Area Manager
Phone: (989) 588-5804
E-mail: trent_meske@tcenergy.com
Address: Great Lakes Gas Transmission
69720 Forest Road 241
Iron River, WI 54847

3.0 Natural Gas Compressors

Engine ID	Manufacturer	Model	Engine Type	Add-On Control
EU-UNIT901	Rolls Royce	Avon 76G	Natural Gas-Fired Turbine	None

3.1 Turbine Maintenance

The Rolls Royce Avon 76G Turbine (EU-UNIT901) is maintained in accordance with TC Energy Operating Procedures (TOP) governing natural-gas fired turbines. GLGT employs good combustion practices on well-maintained engines combined with the exclusive use of natural gas in order to minimize air emissions.

4.0 Malfunction Corrective Procedures

In the event of a malfunction or failure that has the potential to exceed applicable emission limitation or cause air pollution, the following corrective actions will be implemented.

- Shut the unit(s) down as soon as possible and consistent with safe operating procedures.
- Troubleshoot or research the cause of such malfunction or failure.
- Repair and/or replace components as required.
- Restart the unit(s) and confirm normal operation.

The above malfunction corrective procedures are consistent with good air pollution control practices and are developed with the intent to minimize the release of any air contaminant and restore normal operations as soon as practicable.

5.0 Major Parts Inventory and Replacement

Major Parts are ordered as needed through the vendors and not kept on site.

6.0 Responsible Person for Inspection, Maintenance and Repair of Add-On Equipment

N/A – no add-on equipment

7.0 Retention of Records

All Records shall be retained for 5 years.

8.0 Updates of PM/MAP

The PM/MAP will be reviewed annually, and any updates shall be submitted to the AQD District Supervisor for approval.