

RECEIVED

APR 23 2024

AIR QUALITY DIVISION

40 CFR 63, Subpart ZZZZ  
Reciprocating Internal Combustion Engines  
(RICE MACT)  
WWTP Diversion Diesel Pumps  
Engine A (D-200A)  
Engine B (D-200B)

Project number: 60724067

March 7, 2024

### Quality information

**Prepared by**

*Wayne W. Washburn*

Wayne Washburn, QSTI  
Air Quality Senior Scientist

**Checked by**

*Rob Sava*

Rob Sava, QSTI  
Environmental Engineer IV

**Approved by**

*James Edmister*

James Edmister  
Project Manager

### Revision History

Revision	Revision date	Details	Authorized	Name	Position

### Distribution List

# Hard Copies	PDF Required	Association / Company Name

Prepared for:

Becky Meyerholt  
Sr. Environmental Specialist  
Dow Chemical Company  
Office: 989-638-7824  
Cell: 989-325-6820  
E: [RMeyerholt@dow.com](mailto:RMeyerholt@dow.com)

Prepared by:

AECOM  
3700 James Savage Road  
Midland, MI 48642  
USA  
[www.aecom.com](http://www.aecom.com)

Managed by:

James Edmister  
Project Manager  
M: (585) 721-9128 (mobile)  
E: [James.Edmister@aecom.com](mailto:James.Edmister@aecom.com)

Copyright © 2024 by AECOM

All rights reserved. No part of this copyrighted work may be reproduced, distributed, or transmitted in any form or by any means without the prior written permission of AECOM.

## Table of Contents

1.	Introduction .....	1-1
1.1	Summary of Test Program .....	1-1
1.2	Key Personnel .....	1-2
2.	Plant and Sampling Location Description .....	2-1
2.1	Facility Description.....	2-1
2.2	Control Equipment.....	2-1
2.3	Flue Gas Sampling Locations.....	2-1
3.	Summary and Discussion of Test Results .....	3-1
3.1	Objectives and Test Matrix .....	3-1
3.2	Facility Operations .....	3-1
3.3	Comments / Exceptions.....	3-1
4.	Sampling and Analytical Procedures .....	4-1
4.1	Test Methods .....	4-1
4.2	Procedures .....	4-1
4.3	Source Test Equipment.....	4-2
5.	Calculation Examples .....	5-1
5.1	Calibration Error - Equation 7E-1 .....	5-1
5.2	System Bias - Equation 7E-2.....	5-2
5.3	System Drift - Equation 7E-4.....	5-3
5.4	Effluent Concentration - Equation 7E-5b.....	5-4
5.5	Effluent Concentration Corrected for Oxygen Concentration.....	5-5
5.6	CO Reduction / Destruction Efficiency .....	5-6
	Appendix A AECOM Reference Method Emissions Data	
	A.1 RM Summary Data and Calculated Results	
	A.2 RM Stratification Determination Printouts	
	A.3 RM Analyzers Bias Corrected Test Runs Data Printouts	
	A.4 RM DAS Data	
	Appendix B Dow Process Operations Data	
	B.1 Process Operating Data – Engine A	
	B.2 Process Operating Data – Engine B	
	Appendix C AECOM Reference Method Quality Assurance Data	
	C.1 RM Calibration Error, System Bias, and System Drift Checks – 02/20/2024	
	C.2 RM Calibration Error, System Bias, and System Drift Checks – 02/20/2024	
	C.3 RM System Response Time Tests	
	C.4 RM Gas Cylinder Certificates of Analysis	
	C.5 RM Instrumental Analyzer Operator Logs	
	Appendix D Test Protocol	

## Figures

Figure 2-1. Sampling Location Diagram of Engines A and B (Typical) ..... 2-1  
Figure 4-1. Sampling Train Used for CO & O2 (M10 & M3A) ..... 4-2

## Tables

Table 1-1. General Summary Information ..... 1-1  
Table 1-2. Test Program Personnel Summary ..... 1-2  
Table 3-1. Summary of Results ..... 3-1  
Table 3-2. Test Run Data ..... 3-1  
Table 3-3. Engine A Process Data ..... 3-2  
Table 3-4. Engine B Process Data ..... 3-2  
Table 4-1: Instrumental Analyzers ..... 4-2

# 1. Introduction

## 1.1 Summary of Test Program

The Dow Chemical Company (Dow) in Midland, Michigan, is a large complex with manufacturing and utility plants. Dow’s Michigan Operations (MiOps) is a major source of Hazardous Air Pollutants (HAPs).

AECOM was contracted to conduct an emissions compliance test of two 1,050 horsepower (hp) non-emergency diesel engines (designated as Engine A and Engine B) to demonstrate compliance with the RICE MACT regulations in 40CFR63, Subpart ZZZZ. The engines are operated to divert influent wastewater and storm water away from the on-site wastewater treatment plant (WWTP) to wastewater storage tanks for a variety of reasons. The testing was conducted to demonstrate compliance with emissions and operating limits found in 63.6600(d), Table 2c of the RICE MACT (40CFR63, Subpart ZZZZ).

The following table summarizes the pertinent data for this compliance test:

**Table 1-1. General Summary Information**

Responsible Groups	<ul style="list-style-type: none"> <li>• The Dow Chemical Company</li> <li>• Michigan Department of Energy, Great Lakes, and Environment. (EGLE)</li> <li>• U. S. Environmental Protection Agency (US EPA)</li> </ul>
Applicable Regulations	<ul style="list-style-type: none"> <li>• ROP-MI-A4033-2024</li> <li>• 40 CFR 63, Subpart ZZZZ (RICE MACT)</li> </ul>
Industry / Plant	<ul style="list-style-type: none"> <li>• Environmental Operations Plant (EVO)</li> </ul>
Plant Location	<ul style="list-style-type: none"> <li>• The Dow Chemical Company Midland, MI 48667</li> </ul>
Unit Installation Date	<ul style="list-style-type: none"> <li>• Engine A 6/2/2021</li> <li>• Engine B 3/17/2022</li> </ul>
Unit Initial Compliance Date	<ul style="list-style-type: none"> <li>• Engine A 11/18/2021</li> <li>• Engine B 8/03/2022</li> </ul>
Air Pollution Control Equipment	<ul style="list-style-type: none"> <li>• All engines are equipped with dual single stage catalytic reduction and closed crankcase filtration emissions control systems</li> </ul>
Emission Points	<ul style="list-style-type: none"> <li>• P200 Diesel Engine A</li> <li>• P200 Diesel Engine B</li> </ul>
Pollutants/Diluent Measured	<ul style="list-style-type: none"> <li>• Carbon Monoxide (CO)</li> <li>• Oxygen (O<sub>2</sub>)</li> </ul>
Test Dates	<ul style="list-style-type: none"> <li>• Feb 20, 2024 (Engine A)</li> <li>• Feb 21, 2024 (Engine B)</li> </ul>

## 1.2 Key Personnel

Names and affiliations of personnel, including their roles in the test program, are summarized in the following table.

**Table 1-2. Test Program Personnel Summary**

Role	Role Description	Name	Affiliation
Process Focal Point	<ul style="list-style-type: none"> <li>• Coordinate plant operation during the test.</li> <li>• Ensure the unit is operating at the agreed upon conditions in the test plan.</li> <li>• Collect any process data required.</li> <li>• Provide all technical support related to process operation.</li> </ul>	Morgan Raup	Dow Chemical
Environmental Focal Point	<ul style="list-style-type: none"> <li>• Ensure all regulatory requirements and citations are reviewed and considered for the testing.</li> </ul>	Becky Meyerholt	Dow Chemical
Technical Reviewer	<ul style="list-style-type: none"> <li>• Completes technical review of the test data.</li> </ul>	Wayne Washburn	AECOM
Field Team Leader	<ul style="list-style-type: none"> <li>• Ensures field sampling meets the quality assurance objectives of the plan.</li> </ul>	Peter Becker	AECOM
Sample Project Leader	<ul style="list-style-type: none"> <li>• Ensures data generated meets the quality assurance objectives of the plan.</li> </ul>	James Edmister	AECOM

## 2. Plant and Sampling Location Description

### 2.1 Facility Description

Dow operates a chemical manufacturing facility in Midland, Michigan. Environmental Operations (EVO) operates two 1,050 hp diesel engines used to divert influent wastewater and stormwater away from the on-site wastewater treatment plant (WWTP) to wastewater storage tanks for a variety of reasons.

The testing was conducted to demonstrate compliance with emissions and operating limits found in 63.6600(d), Table 2b of the RICE MACT, 40CFR63, Subpart ZZZZ.


### 2.2 Control Equipment

CO emissions are controlled by catalytic oxidation.

### 2.3 Flue Gas Sampling Locations

Sampling was conducted on the typical exhaust trains of Engine A and Engine B prior to and after the individual identical dual (in parallel) single stage catalytic reduction system serving each engine. Flue gas sample locations met the minimum guidelines for carbon monoxide (CO) and oxygen (O<sub>2</sub>) sampling using instrumental analyzers.

Figure 2-1. Sampling Location Diagram of Engines A and B (Typical)



### 3. Summary and Discussion of Test Results

#### 3.1 Objectives and Test Matrix

Under contract with Dow Midland Operations, AECOM, Inc. conducted compliance sampling on the engines located at the Environmental Operations Plant (EVO) at Dow’s Michigan Operations (MiOps) facility. These engines are operated in non-emergency situations to manage wastewater and stormwater at the MiOps WWTP. The testing was conducted to demonstrate compliance with emissions and operating limits found in 63.6600(d), Table 2c. The specific objectives of this test were to:

- Verify that the destruction efficiency (DE) for CO is greater than 70%.

#### 3.2 Facility Operations

For engines >500 HP, the facility must:

- Minimize idle time at startup to <30 minutes,
- Maintain the catalyst so that the pressure-drop across the catalyst does not change by more than 2 inches of water at 100 percent load ±10 percent from the pressure drop across the catalyst measured during the initial performance test, and
- Maintain the exhaust temperature such that 450°F ≥ catalyst inlet temperature ≤ 1350°F.

#### 3.3 Comments / Exceptions

- As allowed by 40 CFR, Part 60, Subpart ZZZZ, this Compliance Test consisted of three, one-hour test runs.

**Table 3-1. Summary of Results**

SAMPLE TYPE	TEST METHOD	ACTUAL EMISSION REDUCTION	REQUIRED EMISSION REDUCTION
CO Emissions (DE) Engine A	EPA Method 10	94.8 %	70 %
CO Emissions (DE) Engine B	EPA Method 10	96.2 %	70 %

**Table 3-2. Test Run Data**

<b>P200 Engine A Test Run Data</b>				
PARAMETER	RUN 1	RUN 2	RUN 3	AVERAGE
Sample Date	2/20/2024	2/20/2024	2/20/2024	--
Sample Times (start/end)	10:05-11:05	11:22-12:22	12:40-13:40	--
Outlet CO (ppmv @ 15% O <sub>2</sub> )	2.30	2.00	1.91	2.07
Inlet CO (ppmv @ 15% O <sub>2</sub> )	41.01	38.77	39.94	39.91
CO (DE %)	---	---	---	<b>94.8</b>
<b>P200 Engine B Test Run Data</b>				
PARAMETER	RUN 1	RUN 2	RUN 3	AVERAGE
Sample Date	2/21/2024	2/21/2024	2/21/2024	--
Sample Times (start/end)	09:00-10:00	10:15-11:15	11:35-12:35	--
Outlet CO (ppmv @ 15% O <sub>2</sub> )	1.78	1.68	1.65	1.70
Inlet CO (ppmv @ 15% O <sub>2</sub> )	45.88	44.94	42.61	44.48
CO (DE %)	---	---	---	<b>96.2</b>

**Table 3-3. Engine A Process Data**

PARAMETER	RUN 1	RUN 2	RUN 3	AVERAGE
Sample Date	2/20/2024	2/20/2024	2/20/2024	--
Sample Times (start-end)	10:05-11:05	11:22-12:22	12:40-13:40	--
Engine RPM (RPM)	1,847	1,846	1,846	1,846
Engine Load (%)	84	85	85	85
Fuel Consumed (Gallons)	49	44	51	48
<b>Catalyst 1</b>				
Catalyst Inlet Temp (Deg F)	704	712	716	710.7
Differential Pressure (IWC)	21.09	20.97	20.91	20.99
<b>Catalyst 2</b>				
Catalyst Inlet Temp (Deg F)	717	724	729	723.3
Differential Pressure (IWC)	21.35	21.22	21.18	21.25

\*1 gallon of distillate fuel with 15 ppm of sulfur or less produces 137,381 Btu.

**Table 3-4. Engine B Process Data**

PARAMETER	RUN 1	RUN 2	RUN 3	AVERAGE
Sample Date	2/21/2024	2/21/2024	2/21/2024	--
Sample Times (start-end)	09:00-10:00	10:15-11:15	11:35-12:35	--
Engine RPM (RPM)	1,847	1,848	1,848	1,848
Engine Load (%)	84	85	85	85
Fuel Consumed (Gallons)	47	43	49	46
<b>Catalyst 1</b>				
Catalyst Inlet Temp (Deg F)	715	717	722	718.0
Differential Pressure (IWC)	18.70	18.70	18.79	18.73
<b>Catalyst 2</b>				
Catalyst Inlet Temp (Deg F)	714	716	721	717.0
Differential Pressure (IWC)	18.92	18.91	18.99	18.94

\*1 gallon of distillate fuel with 15 ppm of sulfur or less produces 137,381 Btu.

## 4. Sampling and Analytical Procedures

### 4.1 Test Methods

All sampling and analytical procedures are EPA published methods or methods allowed by 63.6610. This compliance test utilized the following methods:

- EPA Method 3A for O<sub>2</sub> Concentration
- EPA Method 10 for CO Concentration

#### **EPA Method 3A (Flue Gas Composition and Molecular Weight)**

EPA Method 3A (Instrumental Analyzer Method) was utilized to determine the diluent gas concentrations during each run at both the inlet and outlet of the catalysts serving each engine exhaust train.

Each Method 3A analyzer measured O<sub>2</sub> concentrations based on the strong paramagnetic properties of O<sub>2</sub> relative to other compounds present in combustion gases. In the presence of a magnetic field, O<sub>2</sub> molecules become temporary magnets. The analyzer determines the sample gas O<sub>2</sub> concentration by detecting the displacement torque of the sample test body in the presence of a magnetic field.

#### **EPA Method 10 (CO Sampling and Analysis)**

EPA Method 10 was utilized to determine carbon monoxide concentrations during each run at both the inlet and outlet of the catalysts serving each engine exhaust train.

Each Method 10 analyzer measured CO based on its absorption of non-dispersive infrared (NDIR) radiation. The NDIR unit uses a single beam, single wavelength technique, with wavelength selection being achieved by a carefully specified narrow band optical filter making it highly selective for CO measurement in the presence of other infrared-absorbing gases. In addition, the Thermo Model 48 platform of analyzers employ gas filter correlation (GFC) techniques to eliminate bias from any other infrared-absorbing compounds besides CO.

### 4.2 Procedures

The above methods are performed using mobile continuous measurement instrumental analyzers. Gases are withdrawn from the gas stream and transported to monitors located at ground level. A stainless-steel probe is inserted into the gas stream and used to collect sample gas. A Teflon sample line heated to ≥250°F transports sample gas from the probe to the analyzers. The analyzers are kept at a constant temperature inside the mobile laboratory.

Sample gas is collected continuously from the gas stream for a period of one hour. A stratification test is performed during the first test run at three traverse points, which are 16.7%, 50.0%, and 83.3% of the measurement line that passes through the centroidal area of the stack or duct cross section. At the mobile laboratory, the stack gas is routed to a gas moisture condenser and then transported to the analyzers for dry-basis analysis.

The Destruction Efficiency (DE) tests are conducted by first measuring the Oxygen and Carbon Monoxide concentrations within the inlet and outlet gas streams of the catalyst system, with the CO concentrations then corrected to 15% excess oxygen prior to calculating DE as follows:

$$DE = (CO_{In} - CO_{Out}) / CO_{In} * 100\%$$

Destruction efficiency is determined for the 3-run average inlet and outlet CO (ppmvd @ 15% O<sub>2</sub>).

### 4.3 Source Test Equipment

Table 4-1: Instrumental Analyzers

Instrument	System	Output	Make	Model	Serial # or ID #
Method 3A (O <sub>2</sub> )	Inlet O <sub>2</sub>	0-25%	Servomex	1440	OXC-1601
Method 10 (CO)	Inlet CO	0-200 ppm	Thermo	48i	CO-A1601
Method 3A (O <sub>2</sub> )	Outlet O <sub>2</sub>	0-25%	Servomex	1440	OXC-1602
Method 10 (CO)	Outlet CO	0-60 ppm	Thermo	48C	CO-A1604

Figure 4-1. Sampling Train Used for CO & O<sub>2</sub> (M10 & M3A)

