

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

**FCE Summary Report**

<b>Facility :</b> GRAND RAPIDS WASTEWATER TREATMENT PLANT	<b>SRN :</b> B1729
<b>Location :</b> 1300 MARKET AVE SW	<b>District :</b> Grand Rapids
	<b>County :</b> KENT
<b>City :</b> GRAND RAPIDS <b>State:</b> MI <b>Zip Code :</b> 49503	<b>Compliance Status :</b> Compliance
<b>Source Class :</b> SM OPT OUT	<b>Staff :</b> Eric Grinstern
<b>FCE Begin Date :</b> 7/26/2023	<b>FCE Completion Date :</b> 7/26/2024
<b>Comments :</b> FY 24 FCE	

**List of Partial Compliance Evaluations :**

Activity Date	Activity Type	Compliance Status	Comments
07/02/2024	On-site Inspection	Compliance	Scheduled compliance inspection
05/28/2024	Annual Emissions Report (or MAERS)	Compliance	Submittal appears to account for applicable emission units and emissions. Submittal includes supporting documentation. Emission changes appear to correlate with changes in material throughput relative to the previous year's submittal. The original submittal did not utilize stack test data to calculate emissions for EUCHP1 and EUCHP3. The submittal was returned for modification by the facility. The facility corrected the emissions and resubmitted with supporting data.
11/27/2023	Stack Test	Compliance	Retesting demonstrated compliance with all pollutants: NOx, CO NMOC, CHO2
09/29/2023	Stack Test Observation	Non Compliance	On-site stack test observation Testing conducted to demonstrate compliance with PTI No. 37-19B and Subpart JJJJ.
09/19/2023	Stack Test	Non Compliance	Facility stopped testing after on run due to results showing the exceedance of the CHO2 limit on EUCHP3. Testing showed and emission rate of 0.076 pph vs. a limit of 0.056 pph. VN issued.

Name: Eric Grinstern Date: 07/26/2024

Supervisor: HH