

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : ANR Pipeline - Reed City Compressor Station	SRN : B3721
Location : 7677 230th Ave.	District : Cadillac
	County : OSCEOLA
City : REED CITY State: MI Zip Code : 49677	Compliance Status : Compliance
Source Class : MAJOR	Staff : Caryn Owens
FCE Begin Date : 7/29/2018	FCE Completion Date : 7/29/2019
Comments :	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
06/26/2019	Scheduled Inspection	Compliance	Scheduled Inspection and Records Review
04/05/2019	MACT (Part 63)	Compliance	Missing Cert Form., rcvd Cert Form on 3/22/19. Boiler MACT- Annual Compliance rpt. Identifies two preheaters & EURC016 and EURC017, due for annual tune-up in 2018, but not operating. Tune-up done on 2/10/19.
04/05/2019	MACT (Part 63)	Compliance	Certification form to certify MACT DDDDD Annual Certification Report received March 15, 2019.
03/06/2019	MAERS	Compliance	See MAERS Report for Further Info. - Made sure SCC codes made sense, compared calculated and reported emission with permitted limits. All permitted equipment was covered.
02/15/2019	MACT (Part 63)	Compliance	Rice MACT - Gaseous & Opacity excess emissions & CMS performance Summary Report, Compliance Report, and Certification Form. No excess emissions or CMS downtime reported, and no malfunctions or deviations reported. Mis-placed, reviewed when found.
02/15/2019	ROP Annual Cert	Compliance	MI-ROP-B3721-2014 Annual Report for 2018. No deviations during the reporting period.

Activity Date	Activity Type	Compliance Status	Comments
02/15/2019	MACT (Part 63)	Compliance	HHH - MACT Periodic Report to show Compliance with Subpart HHH - LoReed Dehy Unit and RC RAY Dehy unit had no leaks above 500ppmv. Operated total 338.4 hrs this report period. No excursions, leaks, defects occurred.
02/15/2019	ROP SEMI 2 CERT	Compliance	MI-ROP-B3721-2014 2nd Semi Annual Report for 2018. No deviations during the reporting period.
09/14/2018	MACT (Part 63)	Compliance	HHH - MACT Periodic Report to show Compliance with Subpart HHH - LoReed Dehy Unit and RC RAY Dehy unit had no leaks above 500ppmv. BTEX emissions were controlled by thermal oxidizer. Operated total 3201.0 hrs this report period. No excess emissions or monitor downtime.
09/14/2018	ROP Semi 1 Cert	Compliance	MI-ROP-B3721-2014a 1st Semi-Annual Report. No deviations during the reporting period.
09/14/2018	MACT (Part 63)	Compliance	Rice MACT - Gaseous & Opacity excess emissions & CMS performance Summary Report, Compliance Report, and Certification Form. No excess emissions or CMS downtime reported, and no malfunctions or deviations reported.

Name:

Camp Owens

Date:

7/29/19

Supervisor:

SN