


RECEIVED
DEC 20 2017
AIR QUALITY DIVISION

**Mercury and Air Toxics
Standard Particulate
Matter and Hydrogen
Chloride Emissions
Test Report**

We Energies
Presque Isle Power Plant
Flue 6 Stack
Marquette, Michigan
Project No. M174801B
November 8, 2017

 **platt**
mostardi



**Mercury and Air Toxics Standard Particulate Matter and
Hydrogen Chloride Emissions Test Report**

**We Energies
Presque Isle Power Plant
Flue 6 Stack
Marquette, Michigan
November 8, 2017**

**Report Submittal Date
December 8, 2017**

© Copyright 2017
All rights reserved in
Mostardi Platt

Project No. M174801B

1.0 EXECUTIVE SUMMARY

MOSTARDI PLATT conducted a Mercury and Air Toxics Standards (MATS) filterable particulate matter and Hydrogen Chloride emissions test program for the We Energies at the Presque Isle Power Plant on the Flue 6 Stack in Marquette, Michigan on November 8, 2017. This report summarizes the results of the test program and test methods used.

The test location, test date, and test parameters are summarized below.

TEST INFORMATION		
Test Location	Test Date	Test Parameters
Flue 6 Stack	November 8, 2017	Filterable Particulate Matter (FPM) and Hydrogen Chloride (HCl)

The purpose of the test program was to document FPM and HCl emissions to qualify for the LEE designation as required by 40 CFR Part 63, Subpart UUUUU. Selected results of the test program are summarized below. A complete summary of emission test results follows the narrative portion of this report.

TEST RESULTS			
Test Location	Test Parameter	Emission Limits	Emission Rates
Flue 6 Stack	FPM	≤0.030 lb/mmBtu	0.0009 lb/mmBtu
	HCl	≤0.002 lb/mmBtu	0.0002 lb/mmBtu

Emissions on lb/mmBtu basis were determined using a standard F_d -Factor of 9,820 dscf/mmBtu for sub-bituminous coal. Plant operating data as provided by We Energies is included in Appendix A.

The Stationary Source Audit Sample Program audit sample was obtained from ERA and analyzed by Mostardi Platt. The results of the audit sample were compared to the assigned value by ERA and found to be acceptable. The audit sample result and evaluation are appended to this report.

The identifications of individuals associated with the test program are summarized below.

TEST PERSONNEL INFORMATION		
Location	Address	Contact
Test Coordinator	We Energies 333 West Everett Street Environmental Department A231 Milwaukee, Wisconsin 53203	Mr. Rob Bregger (414) 221-2772 (phone) rob.bregger@we-energies.com
Test Facility	We Energies Presque Isle Power Plant 2701 Lakeshore Boulevard, North Marquette, Michigan 49885	Ms. Cindy Brandt, P.E. (920) 433-1830 (phone) chbrandt@integrysgroup.com
Testing Company Representative	Mostardi Platt 888 Industrial Drive Elmhurst, Illinois 60126	Mr. Stuart Sands Project Manager (630) 993-2100 (phone) ssands@mp-mail.com

The test crew consisted of Messrs. C. Menet, E. Charatz, J. Rogers, T. Schmidt, and S. Sands of Mostardi Platt.

2.0 TEST METHODOLOGY

Emissions testing was conducted following the methods specified in 40CFR60, Appendix A. A schematic of the test section diagram is found in Appendix B and schematics of the sampling trains used are included in Appendix C. Calculation nomenclature and sample calculations are included in Appendix D. Laboratory analysis data are found in Appendix E. Copies of analyzer print-outs for each test run are included in Appendix F and field data sheets are found in Appendix G.

The following methodologies were used during the test program:

Method 1 Traverse Point Determination

Test measurement points were selected in accordance with Method 1. The characteristics of the measurement location are summarized below.

TEST POINT INFORMATION				
Location	Upstream Diameters	Downstream Diameters	Test Parameter	Number of Sampling Points
Flue 6 Stack	>2.0	>8.0	FPM, HCl	12

Method 2 Volumetric Flowrate Determination

Gas velocity was measured following Method 2, for purposes of calculating stack gas volumetric flow rate. An S-type pitot tube, differential pressure gauge, thermocouple and temperature readout were used to determine gas velocity at each sample point. All of the equipment used was calibrated in accordance with the specifications of the Method. Calibration data are presented in Appendix H.

Method 3A Oxygen (O₂)/Carbon Dioxide (CO₂) Determination

Stack gas molecular weight was determined in accordance with Method 3A. An ECOM analyzer was used to determine stack gas oxygen and carbon dioxide content and, by difference, nitrogen content. All of the equipment used was calibrated in accordance with the specifications of the Method. Calibration data are presented in Appendix H and copies of the gas cylinder certifications are found in Appendix I.

Method 5 Filterable Particulate Matter (FPM) Determination

Stack gas filterable particulate concentrations and emission rates were determined in accordance with Method 5 with filter and probe temperatures between 248 and 273 degrees Fahrenheit in accordance with the USEPA letter which is appended. An Environmental Supply Company, Inc. sampling train was used to sample stack gas at an isokinetic rate, as specified in the Method utilizing Pallflex TX40HI45 filters. Particulate matter in the sample probe was recovered using an acetone wash. The probe wash and filter catch were analyzed by Mostardi Platt personnel. Laboratory analysis data are found in Appendix E. Calibration data are presented in Appendix H.

Method 26A Hydrogen Chloride (HCl) Determination

Stack gas HCl concentrations and emission rates were determined in accordance with Method 26A, 40CFR60, Appendix A in conjunction with the USEPA Method 5 sampling. An Environmental Supply Company sampling train was used to sample stack gas, in the manner specified in the Method utilizing Pallflex TX40HI45 filters. Analyses of the samples collected were conducted by Mostardi Platt in the Elmhurst laboratory. Sample analysis data are found in Appendix E. All of the equipment used was calibrated in accordance with the specifications of the Method. Calibration data are presented in Appendix H.

RECEIVED

DEC 20 2017

AIR QUALITY DIVISION

3.0 TEST RESULT SUMMARIES

Client: We Energies
 Facility: Presque Isle Power Plant
 Test Location: Flue 6
 Test Method: 5/26A

	Source Condition	Normal	Normal	Normal	
	Date	11/8/17	11/8/17	11/8/17	
	Start Time	7:00	9:35	12:10	
	End Time	9:10	11:46	14:20	
		Run 1	Run 2	Run 3	Average
Stack Conditions					
Average Gas Temperature, °F		325.0	325.0	325.0	325.0
Flue Gas Moisture, percent by volume		10.7%	11.4%	10.7%	10.9%
Average Flue Pressure, in. Hg		29.08	29.08	29.08	29.08
Gas Sample Volume, dscf		100.734	100.872	101.708	101.105
Average Gas Velocity, ft/sec		74.171	74.315	74.738	74.408
Gas Volumetric Flow Rate, acfm		283,113	283,661	285,276	284,017
Gas Volumetric Flow Rate, dscfm		165,305	164,252	166,539	165,365
Gas Volumetric Flow Rate, scfm		185,076	185,435	186,491	185,667
Average %CO ₂ by volume, dry basis		13.4	13.3	13.3	13.3
Average %O ₂ by volume, dry basis		6.2	6.3	6.3	6.3
Isokinetic Variance		101.2	102.0	101.4	101.5
Standard Fuel Factor Fd, dscf/mmBtu		9,820.0	9,820.0	9,820.0	9,820.0
Filterable Particulate Matter (Method 5)					
grams collected		0.00466	0.00194	0.00188	0.00283
mg/dscm		1.634	0.679	0.653	0.9885
grains/acf		0.0004	0.0002	0.0002	0.0003
grains/dscf		0.0007	0.0003	0.0003	0.0004
lb/hr		1.011	0.418	0.407	0.612
lb/mmBtu (Standard Fd Factor)		0.0014	0.0006	0.0006	0.0009

Client: We Energies
 Facility: Presque Isle Power Plant
 Test Location: Flue 6
 Test Method: 5/26A

	Source Condition	Normal	Normal	Normal	
	Date	11/8/17	11/8/17	11/8/17	
	Start Time	7:00	9:35	12:10	
	End Time	9:10	11:46	14:20	
	Run 1	Run 2	Run 3	Average	
Stack Conditions					
Average Gas Temperature, °F		325.0	325.0	325.0	325.0
Flue Gas Moisture, percent by volume		10.7%	11.4%	10.7%	10.9%
Average Flue Pressure, in. Hg		29.08	29.08	29.08	29.08
Gas Sample Volume, dscf		100.734	100.872	101.708	101.105
Average Gas Velocity, ft/sec		74.171	74.315	74.738	74.408
Gas Volumetric Flow Rate, acfm		283,113	283,661	285,276	284,017
Gas Volumetric Flow Rate, dscfm		165,305	164,252	166,539	165,365
Gas Volumetric Flow Rate, scfm		185,076	185,435	186,491	185,667
Average %CO ₂ by volume, dry basis		13.4	13.3	13.3	13.3
Average %O ₂ by volume, dry basis		6.2	6.3	6.3	6.3
Isokinetic Variance		101.2	102.0	101.4	101.5
Standard Fuel Factor Fd, dscf/mmBtu		9,820.0	9,820.0	9,820.0	9,820.0
Hydrogen Chloride (HCl) Emissions					
ug of sample collected		714.57	716.89	818.80	750.09
ppm		0.17	0.17	0.19	0.17
mg/dscm		0.25	0.25	0.28	0.26
lb/hr		0.155	0.154	0.177	0.162
lb/mmBtu (Standard Fd Factor)		0.0002	0.0002	0.0002	0.0002

4.0 CERTIFICATION

MOSTARDI PLATT is pleased to have been of service to We Energies. If you have any questions regarding this test report, please do not hesitate to contact us at 630-993-2100.

CERTIFICATION

As project manager, I hereby certify that this test report represents a true and accurate summary of emissions test results and the methodologies employed to obtain those results, and the test program was performed in accordance with the methods specified in this test report.

MOSTARDI PLATT



Stuart Sands

Program Manager



Scott W. Banach

Quality Assurance