



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
WARREN DISTRICT OFFICE



LIESL EICHLER CLARK
DIRECTOR

September 19, 2019

Mr. Charles Kelly, Station Supervisor
Consumers Energy - Ray Compressor Station
69333 Omo Road
Armada MI 48005-4510

SRN: B6636, Macomb County

Dear Mr. Kelly:

VIOLATION NOTICE

On September 12, 2019, the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD), received a Renewable Operating Permit (ROP) deviation report for Consumers Energy - Ray Compressor Station located at 69333 Omo Road, Armada, Michigan. The purpose of this ROP deviation report is to report deviations from all general conditions and special conditions in the ROP for which deviations required to be reported by R 336.1213(3)(c) have occurred.

Per the ROP deviation report received by the AQD on September 12, 2019, staff observed the following:

Process Description	Rule/Permit Condition Violated	Comments
EUGLYCDEHYD01	MI-ROP-B6636-2015a, III.4.b, III.5 and VI.9.	Permittee failed to maintain compliance with the daily average of temperature monitoring parameter for eleven (11) days from 1/12/2019, through 1/31/2019.
EUGLYCDEHYD01	MI-ROP-B6636-2015a, III.4.b, III.5 and VI.9.	Permittee failed to maintain compliance with the daily average of temperature monitoring parameter for three (3) days from 2/16/2019, through 2/18/2019.

Per Consumers Energy's ROP deviation report, the permittee failed to maintain compliance with the daily average of the temperature monitoring parameter for eleven (11) days from 1/12/2019, through 1/31/2019, and for three (3) days from 2/16/2019, through 2/18/2019.

Mr. Charles Kelly
Consumers Energy
Page 2
September 19, 2019

Please initiate actions necessary to correct the cited violations and submit a written response to this Violation Notice by October 10, 2019. The written response should include: the dates the violations occurred; an explanation of the causes and duration of the violations; a summary of the actions that have been taken and are proposed to be taken to correct the violations and the dates by which these actions will take place; and what steps are being taken to prevent another reoccurrence.

Please submit the written response to EGLE, AQD, Warren District, at 27700 Donald Court, Warren, Michigan 48092-2793 and submit a copy to Ms. Jenine Camilleri, Enforcement Unit Supervisor at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760.

If Consumers Energy - Ray Compressor Station believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violations cited above. If you have any questions regarding the violations or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Robert Elmouchi
Environmental Quality Analyst
Air Quality Division
586-753-3736

cc: Ms. Mary Ann Dolehanty, EGLE
Dr. Eduardo Olaguer, EGLE
Ms. Jenine Camilleri, EGLE
Mr. Christopher Ethridge, EGLE
Ms. Joyce Zhu, EGLE
Ms. Amy Kapuga, Consumers Energy