

5440 Alder Drive
Houston, TX 77081

Phone: 800-836-7333

Fax: 713-664-6444

E-mail: emissions@ceconet.com

EMISSION TEST REPORT

REGULATION(S): 40 CFR 60 SUBPART JJJJ AND MDEQ PERMIT

POLLUTANT(S): CO, NOX, AND VOCS

ANR TRANSCANADA PIPELINE COMPANY BLUE LAKE STORAGE COMPANY KALKASKA COUNTY, MI

PERMIT NUMBER: MI-ROP-B7198-2014A

FRS# /EPA REGISTRY ID: 110013860526

SOURCE CLASSIFICATION CODE (SCC): 20200254

EMISSION SOURCE: SPARK-IGNITED ENGINE

4-STROKE/2-STROKE: 4-STROKE

RICH/LEAN BURN: LEAN BURN

MAKE & MODEL: CATERPILLAR G3516

UNIT NUMBER: BLGEN-A

SERIAL NUMBER: 3RC00646

RECEIVED

DEC 04 2017

AIR QUALITY DIVISION

TEST DATE: OCTOBER 4, 2017

Pollutant	Permitted Limits				PASS/FAIL
	pounds / hour		g/BHP-hr		
	Permitted	Emitted	Permitted	Emitted	
CO	1.6	0.01	1.4	0.01	PASS
NOx	5.7	1.94	2	1.4	PASS
VOCs	0.9	< 0.10	0.55	<0.100	PASS

Limits obtained from Permit MI-ROP-B7198-2014a.

The contents of this document relate only to the items tested. I certify under penalty of law that I believe the information provided in this document is true, accurate and complete. I am aware that there are significant civil and criminal penalties, including the possibility of fine or imprisonment or both, for submitting false, inaccurate or incomplete information.

CECO TEST LEADER:

HUY NGUYEN

SENIOR EMISSIONS TEST SPECIALIST

CECO TRAINING & TECHNICAL SERVICES

724-961-3583

This report may not be reproduced in full, or in part, without the written approval of ANR TransCanada Pipeline Company.

Revision History

Version	Revision Date	Comments
0	<i>original</i>	Original Version of Document.

Project Information

CECO Project No: 20171004-051-1

Contact Information

Facility Information

Facility ANR TransCanada Pipeline Company
Blue Lake Storage Company
Kalkaska County, MI

Contact

Roy Cannon
700 Louisiana Street
Houston, TX 7702
832-320-5465
roy_cannon@transcanada.com

Testing Group Information

Contact

Huy Nguyen
CECO Training & Technical Services
5440 Alder Drive
Houston, TX 77081
724-961-3583
huy.nguyen@ceconet.com

Introduction

CECO Training & Technical Services, a division of Compressor Engineering Corporation, conducted source emission testing at ANR TransCanada Pipeline Company, Blue Lake Storage Company to fulfill the requirements of 40 CFR 60 Subpart JJJJ and MDEQ Permit No. MI-ROP-B7198-2014A. This report details the test purpose, objectives, testing procedures, sampling and analysis methodology, and results of the source testing conducted on October 4, 2017.

Process Description

The following source was tested:

- Unit Number (BLGEN-A) SN 3RC00646 – one (1) Caterpillar G3516 natural gas-fired, 4-Stroke, Lean Burn internal combustion engine, rated to 1125 brake horsepower (BHP) at 1200 revolutions per minute (RPM). This source is equipped with Oxidation Catalyst w/AFR for emission control and drive a generator.

Test Purpose and Objectives

The purpose of this test was to fulfill the requirements of 40 CFR 60 Subpart JJJJ and MDEQ Permit No. The objective of this test was to conduct the required three (3) 60-minute test runs to measure the applicable emission species at the maximum achievable load.

Results

	Test Run			Average	
	1st	2nd	3rd		
Fuel					
HHV (BTU/SCF)	1012				
LHV (BTU/SCF)	915				
F-factor (DSCF/MMBTU)	8613				
Test Date & Time					
Date	10/4/2017	10/4/2017	10/4/2017		
Start Time	2:51 PM	4:13 PM	5:26 PM		
End Time	3:51 PM	5:13 PM	6:26 PM		
Interval (minutes)	60	60	60	60	
Measured Concentrations (bias-corrected where applicable)					
O ₂ (%vd)	8.27	8.02	8.27	8.19	
CO (ppmvd)	2.9	0.1	0.8	1.3	
NO _x (ppmvd)	214.7	212.6	159.0	195.4	
VOCs (ppmvd)	-37.6	-49.1	-43.9	-43.5	
THC (ppmvd)	412.8	403.0	419.4	411.7	
Operating Conditions					
Engine Horsepower (BHP)	656	621	666	647	
Torque Load (%)	58.3	55.2	59.2	57.6	
Engine Speed (RPM)	1200	1200	1200	1200	
Fuel Flow Rate (SCFH)	5610	5593	6373	5859	
BSFC (BTU/BHP-hr), LHV	7835	8244	8763	8281	
Fuel BTU Consumption (MMBTU/hr)	5.68	5.66	6.45	5.93	
Exhaust Flow Rate (SCFH)	80930	79123	91942	83998	
Exhaust Flow Rate (SCFM)	1348.8	1318.7	1532.4	1400.0	
Calculated Emissions					
CO	(lb/hr)	0.0171	0.0006	0.0053	0.0077
	(ton/year)	0.0747	0.0025	0.0234	0.0335
	(g/BHP-hr)	0.0118	0.0004	0.0036	0.0053
	(ppmvd at 15% O ₂)	1.3547	0.0458	0.3737	0.5914
NO _x	(lb/hr)	2.0736	2.0075	1.7446	1.9419
	(ton/year)	9.0824	8.7928	7.6414	8.5055
	(g/BHP-hr)	1.4348	1.4661	1.1885	1.3631
	(ppmvd at 15% O ₂)	100.2953	97.3866	74.2755	90.6525
VOCs	(lb/hr)	< 0.1000	< 0.1000	< 0.1000	< 0.1000
	(ton/year)	< 1.0000	< 1.0000	< 1.0000	< 1.0000
	(g/BHP-hr)	< 0.1000	< 0.1000	< 0.1000	< 0.1000
	(ppmvd at 15% O ₂)	< 1.0000	< 1.0000	< 1.0000	< 1.0000
THC	(lb/hr)	3.8215	3.6475	4.4109	3.9600
	(ton/year)	16.7382	15.9761	19.3198	17.3447
	(g/BHP-hr)	2.6442	2.6638	3.0050	2.7710
	(ppmvd at 15% O ₂)	192.8361	184.6040	195.9192	191.1198

Methodology and Sampling Procedures

Methodology

Parameter	Sampling Method
Oxygen (O ₂)	40 CFR 60, Appendix A, Method 3A
Oxides of Nitrogen (NO _x)	40 CFR 60, Appendix A, Method 7E
Carbon Monoxide (CO)	40 CFR 60, Appendix A, Method 10
Volumetric Exhaust Flow Rate	40 CFR 60, Appendix A, Method 19
Gas Dilution System	40 CFR 60, Appendix A, Method 205
Methane (CH ₄) & Ethane (C ₂ H ₆)	ASTM D6348
Total Hydrocarbons (THC)	40 CFR 60, Appendix A, Method 25A
Volatile Organic Compounds (VOCs)	40 CFR 60, Appendix A, Method 25A & ASTM F6348 Subtraction

VOCs via Method 25A

The following gasses were individually quantified on the Fourier Transfer Infrared Spectroscopy (FTIR) analyzer and summed on a propane basis to calculate total hydrocarbons (THC). Methane response factors (based on carbon number) are listed after each compound. Methane and Ethane were subtracted from the total hydrocarbons to calculate Non-methane/Non-ethane (NM/NE) VOCs, reported as propane. Formaldehyde was specifically excluded per 60.4244 (f).

Methane (RF 1)	Ethylene (RF 2)	Propane (RF 3)	Butane (RF 4)	Acetaldehyde (RF 2)
Ethane (RF 2)	Acetylene (RF 2)	Propylene (RF 3)	Methanol (RF 1)	Formic Acid (RF 1)

Horsepower and Fuel Flow Determination

For this test, horsepower was obtained from automation display and fuel flow was obtained from automation display. The Engine Torque Load averaged 57.6% for the test. This was the highest achievable load based on the operating parameters during the test, which are included in Appendix A.

Sampling System

Compressor Engineering Corporation designed and assembled a versatile, emission testing unit (ETU), which houses all analyzers, computers and auxiliary equipment. Effluent stack gas enters the ETU through a heated Teflon sample line. A heated head pump with a Teflon diaphragm pulls the sample into the trailer, through a heated filter, and sends the wet gas directly to the inlet of the FTIR. The heated pump, sample lines, and filter have their temperatures maintained at approximately 191 °C. The FTIR analyzer gas cell and gas inlet temperatures are also maintained at approximately 191 °C. The sample is routed from the exit of the FTIR through a heated Teflon line to a gas conditioner for moisture removal. The dry gas exiting the gas conditioner is routed to a gas distribution panel which sends a portion of the gas to the paramagnetic oxygen analyzer.

The MKS Instruments MultiGas 2030 FTIR analyzer is used to determine the CO, NO_x, and VOCs emission concentrations. The FTIR serves as the instrument for Methods 7E and 10, and meets the requirements of Section 13 of Method 7E. All measured concentrations are corrected to a dry basis via the MKS MG2000 operating software. The FTIR analyzer is configured with

a fixed optical pathlength of 5.11 meters. The measured concentrations are collected at a 0.5 cm^{-1} resolution. Each spectrum is derived from the co-addition of 60 scans. Data is collected continuously during each test run. A new data point is generated every 60 seconds.

A software package (CECOTest) is used to collect and processes data. CECOTest continually logs data every 10 seconds from the oxygen analyzer and the FTIR during the 60 minute runs.

Refer to **FIGURE 1** for a schematic of the sampling system.




Figure 1: Sampling System Schematic

Instrument Specifications

Description: Oxygen Analyzer
 Manufacturer: Servomex
 Model: 1440C
 Serial Number: 2593
 Technology Type: Paramagnetic
 Range: 0-25%
 Repeatability: +/- 0.1% O2
 Response Time (90%): Typically less than 10 sec
 Linearity: +/- 0.1% O2

Description: FTIR Analyzer
 Manufacturer: MKS Instruments
 Model: 2030
 Serial Number: 017978321
 Technology Type: FTIR Spectrometry
 Range: between 10ppb and 100% full scale
 Spectral Resolution: 0.5-128 1/cm
 Scan Speed: 1/sec @ 0.5 1/cm
 Detector Type: LN2-cooled MCT


Manufacturer: Teledyne
 Model: T700
 Serial Number: 1364
 Technology Type: Mass Flow Controller
 MFC's: 0LPM, 2LPM, and 200ccm
 Flow Measurement Accuracy: +/-1.0% of Full Scale
 Repeatability of Flow Control: +/-0.2% of full Scale
 Linearity of Flow Measurement: +/-0.5% of Full Scale
 Flow Range of Diluent Air: 0 to 10 SLPM
 Optional Ranges: 0 to 5 SLPM; 0 to 20 SLPM
 Flow Range of Cylinder Gasses: 0 to 100 cc/min
 Optional Ranges: 0 to 50 cc/min; 0 to 200 cc/min
 Zero Air Required: 10 SLPM @ 30 PSIG
 Optional: 20 SLPM @ 30 PSIG
 CAL Gas Input Ports: 4 (configurable)
 Diluent Gas Input Ports: 1
 Response Time: 60 Seconds (98%)

Description: Flame Ionization Analyzer
 Manufacturer: J.U.M. Engineering
 Model: 1440C
 Serial Number: 6NB05009
 Outputs: 0-10V, 4 - 20mA.
 Detection Method: Flame Ionization Detector.

Detection Limit:	1ppm CH4 at full scale.
Ranges:	0-10, 0-100, 0-1,000, 0-10,000, 0-100,000ppm.
Response Time:	0.2 sec.
Sample Flow Rate:	2.5 L/min.
Drift:	Span (24 hours): <1%. Zero (24 hours): <1%.
Linearity:	within 1% of full scale

Description of Sampling Location

Physical Duct Parameters



D =	10	in	Duct Diameter
L =	4	in	Port Length
A =	144	in	Distance to Downstream Disturbance
B =	132	in	Distance to Upstream Disturbance
H =	30	ft	Approximate Height Above Grade
	14.4	D	Distance to Downstream Disturbance (A)
	0.5	D	EPA M1 Requirement
	TRUE		EPA M1 Requirement Met?
	13.2	D	Distance to Upstream Disturbance (B)
	2.0	D	EPA M1 Requirement
	TRUE		EPA M1 Requirement Met?
	TRUE		EPA M1 Requirements Met for Distances to Up/Downstream Disturbances

EPA JJJJ/ZZZZ Sampling Point Requirements

<u>Duct Diameter</u>	<u>Ports</u>
D ≤ 6 inches	N/A
6 < D ≤ 12 inches	N/A
D > 12 inches	M1 Ports
D > 12 inches	no M1 Ports

Sampling Strategy

Single Point Located at Duct Centroid
 3 Traverse Points (16.7, 50.0, and 83.3%) across the duct
 3 Traverse Points (16.7, 50.0, and 83.3%) across the duct
 Stratification Check Required

REQUIRED SAMPLING STRATEGY:

- 8.3 in
- 5.0 in
- 1.7 in
- 12.3 in
- 9.0 in
- 5.7 in

3 Traverse Points (16.7, 50.0, and 83.3%) across the duct
 Point 1
 Point 2
 Point 3
 Point 1 Probe Mark (includes port length)
 Point 2 Probe Mark (includes port length)
 Point 3 Probe Mark (includes port length)

STRATIFICATION CHECK REQUIREMENTS

For every point (where Da=Deviation from Average (%) for a given point.)

- Da < 5 %
- 5% ≤ Da < 10 %
- Otherwise

Single Point Located at Duct Centroid
 3 Traverse Points (16.7, 50.0, and 83.3%) across the duct
 Full M1 Points Required

STRATIFICATION CHECK RESULTS

	<u>Point 1</u>	<u>Point 2</u>	<u>Point 3</u>
	8.69	8.21	8.58
	8.56	8.21	8.50
	8.63	8.17	8.59
	8.50	8.18	8.56
	8.63	8.20	8.60
	8.57	8.17	8.57
	8.60	8.17	8.62
	8.51	8.11	8.43
	8.12	8.15	8.10
	8.24	8.29	8.22
	8.25	8.74	8.16
	8.25	8.57	8.17

Point Average (% O2)	8.46	8.26	8.43
Point Deviation from Average (%)	0.94	- 1.43	0.49
Point Deviation from Average (% O2)	0.08	- 0.12	0.04
Average of Point Averages (% O2)	8.38		

STRATIFICATION CHECK RESULTANT STRATEGY

Single Point Located at Duct Centroid