

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

**FCE Summary Report**

<b>Facility :</b> Buckeye Terminals, LLC - Flint Terminal	<b>SRN :</b> B9081
<b>Location :</b> G-5340 N DORT HWY	<b>District :</b> Lansing
	<b>County :</b> GENESEE
<b>City :</b> FLINT <b>State:</b> MI <b>Zip Code :</b> 48505	<b>Compliance Status :</b> Compliance
<b>Source Class :</b> SM OPT OUT	<b>Staff :</b> Daniel McGeen
<b>FCE Begin Date :</b> 9/30/2021	<b>FCE Completion Date :</b> 9/30/2022
<b>Comments :</b>	

**List of Partial Compliance Evaluations :**

Activity Date	Activity Type	Compliance Status	Comments
09/30/2022	MACT (Part 63)	Compliance	Received timely and complete on 8/6/2021. Tanks 10 & 15 complying with Kb, and 1 and 4 complying with GACT-modified Kb, and no leaks not repaired within 15 days. No loading of gasoline cargo tanks without vapor testing tightness documentation. For flare & alternative CMS, no CMS downtime, no excess emissions, no parameter exceedances, or excursions reported. For CEMs, no excess emissions, and no monitor downtime. No malfunctions reported.
09/30/2022	MACT (Part 63)	Compliance	Received timely and complete on 8/16/2022. Tanks 10 & 15 complying with Kb, and 1 and 4 complying with GACT-modified Kb, and no leaks not repaired within 15 days. No loading of gasoline cargo tanks without vapor testing tightness documentation. For flare & alternative CMS, no CMS downtime, no excess emissions, no parameter exceedances, or excursions. For CEMs, no excess emissions, but CMS downtime was 0.23%. No malfunctions reported.

Activity Date	Activity Type	Compliance Status	Comments
06/01/2022	MAERS	Compliance	2021 MAERS received electronically. Detailed emission inventory attached to MAERS report. Passes audit.
04/11/2022	On-site Inspection	Compliance	PCE activities, conducted as part of a FCE: 1. Unannounced, scheduled joint inspection with EPA Region 9 and AQD, and 2. Review of facility recordkeeping.
12/07/2021	Stack Test	Compliance	VCU and VRU test reports from 10/27 and 10/28/2021, respectively. VCU results were 3.85 mg/L, and VRU results were 0.33 mg/L, both well below the VOC limit of 30 mg/L of product loaded.
10/28/2021	Stack Test Observation	Compliance	Observation of VRU stack testing, with TPU's Trevor Drost also onsite.
10/27/2021	Stack Test Observation	Compliance	Observation of stack test of vapor combustion unit (VCU), with TPU's Trevor Drost also onsite.

Name: 

Date: 9/30/2022

Supervisor: RB