

# FINAL REPORT



RECEIVED

FEB 21 2019

AIR QUALITY DIVISION

## DETROIT RENEWABLE POWER

DETROIT, MICHIGAN

### 2018 SOURCE TESTING PROGRAM (BOILER 11)

RWDI #1804672

February 15, 2019

#### SUBMITTED TO

**Mr. Jeff Korniski**  
Asst. District Supervisor | AQ Division  
korniskij@michigan.gov

**Michigan Department of Environmental Quality**  
Cadillac Place | 3058 West Grand Blvd | Suite 2-300  
Detroit, Michigan 48202-6058

**Ms. Karen Kajiya-Mills**  
Dept. of Environmental Quality | ADQ  
kajiya-millsk@michigan.gov

**Michigan Department of Environmental Quality**  
Constitution Hall | 3 North  
525 West Allegan  
Lansing, Michigan 48909-7760

**Detroit Renewable Power**  
Mark Fletcher  
Director, EHS  
mfletcher@detroitrenewable.com

#### SUBMITTED BY

**Brad Bergeron, A.Sc.T., d.E.T.**  
Senior Project Manager | Principal  
Brad.Bergeron@rwdi.com | ext. 2428

**Matthew Lantz, B.Sc., C.Tech., QSTI**  
Project Manager | Senior Scientist  
Matt.Lantz@rwdi.com | ext. 2345

**RWDI AIR Inc.**  
**Consulting Engineers & Scientists**  
4510 Rhodes Drive | Suite 530  
Windsor, Ontario N8W 5K5

T: 519.823.1311  
F: 519.823.1316



## EXECUTIVE SUMMARY

RWDI AIR Inc. (RWDI) was retained by Detroit Renewable Power to conduct emission sampling on the exhaust of Boiler 11 (EUBOILER011) at their facility located at 5700 Russell Street, Detroit, Michigan. The test program was conducted in order to fulfill the requirements of the Michigan Department of Environmental Quality (MDEQ) Title V Renewable Operating Permit (ROP) # MI-ROP-M4148-2011a dated August 19, 2011.

The Sampling Plan for this testing program was submitted August 2, 2018 to the Michigan Department of Environmental Quality (MDEQ). Approval for the testing program was granted by the MDEQ on September 13, 2018. The 2018 sampling program on Boiler 11 (EUBOILER011) was completed from December 17<sup>th</sup> to December 19<sup>th</sup>, 2018. A copy of the MDEQ approval letter can be found in **Appendix B**.

The following table represents a summary of the stack testing results and compares the testing results to the limits set out in Detroit Renewable Power's Renewable Operating Permit.

**Table Execute Summary:** Renewable Operating Permit (ROP) Limit Comparisons

Parameter	Stack Testing Results <sup>[1]</sup>	ROP Limit <sup>[1][3]</sup>
<b>Limits from ROP: MI-ROP-M4148-2011a</b>		<b>EUBOILER011</b>
Particulate Matter (PM)	0.0011	0.010 gr/dscf
Cadmium	< 0.26	37 µg/dscm
Hexavalent Chromium	0.14	4.2 µg/dscm
Total Chromium	2.20	200 µg/dscm
Lead	0.002	0.440 mg/dscm
Mercury	< 1.10	80 µg/dscm
Dioxins/Furans (CDD/CDF)	25	30 ng/dscm
Hydrogen Chloride (HCl)	3.7	25 ppmv
Sulfur Dioxide (SO <sub>2</sub> )	11	29 ppmv
Total Fluoride	0.22	5 ppmv
Carbon Monoxide (CO)	114	200 ppmv
Volatile Organic Compounds (VOC)	8.3	65 ppmv
Nitrogen Oxides (NO <sub>x</sub> ) <sup>[2]</sup>	198	247 ppmv

**Notes:**

[1] Concentration values are expressed at 101.3 kPa, 68 °F, and 7% oxygen

[2] NO<sub>x</sub> based on 1-Hr average excluding start up and shutdown

[3] Refer to **Appendix A** for Renewable Operating Permit: MI-ROP-M4148-2011a

The results of the testing indicate that all parameters are in compliance with respect to the ROP limits. A summary of all testing results can be found in the **Tables** section of the report with detailed sampling results in the Appendices.



# TABLE OF CONTENTS

<b>1</b>	<b>INTRODUCTION .....</b>	<b>1</b>
<b>2</b>	<b>SOURCE DESCRIPTION.....</b>	<b>2</b>
2.1	Facility Description .....	2
2.2	Process Description .....	2
<b>3</b>	<b>SAMPLING LOCATION .....</b>	<b>3</b>
3.1	Compliance Source Sample Location Description .....	3
<b>4</b>	<b>SAMPLING METHODOLOGY.....</b>	<b>5</b>
4.1	Stack Velocity, Temperature, and Volumetric Flow Rate Determination.....	5
4.2	Sampling for Filterable Particulate Matter (PM) and Metals.....	5
4.3	Sampling for Total Fluorides and Hexavalent Chromium.....	6
4.4	Sampling for Dioxins (PCDD) and Furans (PCDF).....	7
4.5	Sampling for Hydrogen Chloride .....	7
4.6	Sampling for Total Hydrocarbons (as Methane).....	8
4.7	Sampling for Gases (Continuous Emissions Monitoring).....	8
4.8	Sampling for Opacity.....	9
4.9	Quality Assurance/ Quality Control Activities.....	9
<b>5</b>	<b>RESULTS .....</b>	<b>10</b>
5.1	Discussion of Results.....	10
<b>6</b>	<b>OPERATING CONDITIONS.....</b>	<b>11</b>
<b>7</b>	<b>CONCLUSIONS.....</b>	<b>11</b>



## LIST OF TABLES

### Tables Found within the Report:

<b>Table 1.0:</b>	Test Personnel.....	1
<b>Table 3.1:</b>	Summary of Sampling Program - EUBOILER011.....	3
<b>Table 5.0:</b>	Summary of Table & Appendix IDs for Corresponding Test Parameter.....	10

### Tables Found Following the Report:

<b>Table 1:</b>	Summary of Sampling Parameters and Methodology
<b>Table 2:</b>	Sampling Summary and Sample Log
<b>Table 3:</b>	Sampling Summary - Flow Characteristics
<b>Table 4:</b>	Filterable Particulate Matter and Metals - Averaged Results
<b>Table 5:</b>	Dioxins and Furans - Averaged Results
<b>Table 6:</b>	Total Fluoride and Hexavalent Chromium - Averaged Results
<b>Table 7:</b>	Hydrogen Chloride - Averaged Results
<b>Table 8:</b>	Opacity- Averaged Results
<b>Table 9:</b>	RWDI CEM - Averaged Results
<b>Table 10:</b>	24 Hour Averaged CEM Data
<b>Table 11:</b>	Renewable Operating Permit (ROP) Limit Comparisons

## LIST OF FIGURES

### Figures Found within the Report:

<b>Figure 2.2:</b>	Process Flow Diagram.....	2
<b>Figure 3.1a:</b>	Diagram of Flow Disturbance Distance and Stack Diameters for EUBOILERS011, 012, and 013.....	4
<b>Figure 3.1b:</b>	Photo of Stack Exit Point for EUBOILERS011, 012 and 013.....	4



## LIST OF APPENDICES

<b>Appendix A:</b>	Source Testing Plan & Renewable Operating Permit
<b>Appendix B:</b>	Approval Letter
<b>Appendix C:</b>	Filterable Particulate Matter and Metals Sampling
<b>Appendix D:</b>	Dioxins and Furans Sampling
<b>Appendix E:</b>	Total Fluoride and Hexavalent Chromium Sampling
<b>Appendix F:</b>	Hydrogen Chloride Sampling
<b>Appendix G:</b>	Opacity
<b>Appendix H:</b>	Continuous Emission Monitoring (Gaseous Pollutants)
Appendix H1:	DRP CEMS Data
Appendix H2:	RWDI CEMS Data
Appendix H3:	RWDI THC Data
<b>Appendix I:</b>	Field Notes
Appendix I1:	PM & Metals Field Notes
Appendix I2:	Dioxin & Furan Field Notes
Appendix I3:	Total Fluoride & Hexavalent Chromium Field Notes
Appendix I4:	Hydrogen Chloride Field Notes
Appendix I5:	CEM Field Notes
<b>Appendix J:</b>	Equipment Calibrations
<b>Appendix K:</b>	Laboratory Results
Appendix K1:	PM & Metals Laboratory Report
Appendix K2:	Dioxins & Furan Laboratory Report
Appendix K3:	Total Fluoride and Hexavalent Chromium Laboratory Report
Appendix K4:	Hydrogen Chloride Laboratory Report
Appendix K5:	Audit Sample Laboratory Report
<b>Appendix L:</b>	Boiler Process Information
<b>Appendix M:</b>	Sample Calculations



# 1 INTRODUCTION

RWDI AIR Inc. (RWDI) was retained by Detroit Renewable Power to conduct emission sampling on the exhaust of Boiler 11 (EUBOILER011) at their facility located at 5700 Russell Street, Detroit, Michigan. The test program was conducted in order to fulfill the requirements of the Michigan Department of Environmental Quality (MDEQ) Title V Renewable Operating Permit (ROP) # MI-ROP-M4148-2011a dated August 19, 2011.

The Sampling Plan for this testing program was submitted August 2, 2018 to the Michigan Department of Environmental Quality (MDEQ) Approval for the testing program was granted by the MDEQ on September 13, 2018. The 2018 sampling program for Boiler 11 was completed between December 17<sup>th</sup>, 2018 and December 19<sup>th</sup>, 2018. A copy of the MDEQ approval letter can be found in **Appendix B**.

This stack testing study consisted of the following parameters:

- Filterable particulate matter (PM);
- Velocity, flow rate and temperature;
- Metals;
- Dioxins and furans (PCDDs and PCDFs);
- Total Fluoride;
- Hexavalent Chromium;
- Hydrogen chloride (HCl);
- Nitrogen oxides (NO<sub>x</sub>);
- Sulfur dioxide (SO<sub>2</sub>);
- Oxygen (O<sub>2</sub>);
- Carbon dioxide (CO<sub>2</sub>);
- Carbon monoxide (CO); and
- Total Hydrocarbons (THC).

The following lists personnel on site during testing:

**Table 1.0:** Test Personnel

Company	Position	Individual
RWDI	Supervising Engineer	Mark Vanderheyden
RWDI	Project Manager Field Technician	Brad Bergeron Matt Lantz
RWDI	Field Technician	Alec Smith Derek Ottens Thomas Langille
Detroit Renewable Power	Detroit Renewable Power	Mark Fletcher
Michigan Department of Environmental Quality	Test Observer	Mark Dziadosz Todd Zynda Regina Hines



## 2 SOURCE DESCRIPTION

### 2.1 Facility Description

Detroit Renewable Power is a refuse-derived fuel (RDF) plant that began commercial operation in October 1991. The facility is permitted to receive up to 20,000 tons of municipal solid waste (MSW) per week. The MSW is processed into RDF, which is then combusted in the furnaces, producing a maximum 362,800 pounds of steam per hour per unit. The steam is used to generate up to 68 megawatts of electricity and supply export steam at a rate of up to 550,000 pounds per hour. The energy products are sold to DTE Corporation and Detroit Thermal.


### 2.2 Process Description

Detroit Renewable Power is located in Detroit, Michigan. The facility consists of three (3) identical Combustion Engineering (VU40) refuse derived fuel (RDF) fired boilers or municipal waste combustors (MWC). Normal operation of the facility consists of two (2) boilers on-line with one boiler in stand-by mode.

Refuse is prepared and purged of non-processible and non-combustible materials through a series of conveyors and shredders. Waste is then combusted in furnaces at temperatures exceeding 1,800 degrees Fahrenheit and reduced to an inert ash residue.

Flue gases pass through each MWC unit pollution control system before exhausting through a separate flue stack in a common stack. The air pollution equipment for each independent train includes lime injection dry flue gas scrubbers for controlling acid gases and fabric filter baghouses for particulate removal. Each unit is also equipped with a continuous emission monitoring system to demonstrate compliance and to provide feedback on the effectiveness of the air pollution control (APC) equipment.

Figure 2.2: Process Flow Diagram





### 3 SAMPLING LOCATION

#### 3.1 Compliance Source Sample Location Description

The outlet sampling locations for each stack are identical for EUBOILERS011, 012 and 013. Each stack had an inside diameter of 92 inches. Each flue had two sampling ports, 90 degrees apart and 4 inches in diameter. The sampling ports were located 9 duct diameters upstream from the ID fan and 19.8 duct diameters downstream before the stack outlet.

**Table 3.1:** Summary of Sampling Program – EUBOILER011

Boiler 11-(EUBOILER011)	
<b>Emission Unit Description</b> [Including Process Equipment & Control Device(s)]	EUBOILERS011, 012 & 013 consisted of three (3) identical Refused Derived Fuel (RDF) fired spreader-stoker boilers rated at 520 MMBTU/hr heat input, 390,000 lb/hr steam at 900 psig and 825°F. The units operated an electric generator with a nameplate capacity of 68 MWe to convert unsold steam into power for internal consumption and for sale to the grid. Air emissions were controlled using a lime slurry injection from the top of each unit followed by a baghouse fabric filter system.
<b>Parameter Tested</b>	Particulate matter, hydrogen chloride, mercury, lead, cadmium, total chromium, hexavalent chromium, dioxins/furans, sulfur dioxide, carbon monoxide, carbon dioxide, oxygen, total fluorides, nitrogen oxides, volatile organic compounds (VOCs), opacity, in addition to stack gas velocity, stack gas composition, and moisture.
<b>Operating Conditions / Stack Dimensions</b>	320°F / 92 inches
<b>Testing Monitoring Methods</b>	Refer to Section 4.0
<b>Testing Schedule</b>	Refer to <b>Table 2</b> of the Tables Section

Figure 3.1a: Diagram of Flow Disturbance Distance and Stack Diameters for EUBOILERS011, 012, and 013





Figure 3.1b: Photo of Stack Exit Point for EUBOILERS011, 012 and 013





## 4 SAMPLING METHODOLOGY

The following section provides an overview of the sampling methodologies used in this program. **Table 1**, located in the **Tables** section, summarizes the testing parameters and corresponding methodologies.

### 4.1 Stack Velocity, Temperature, and Volumetric Flow Rate Determination

The exhaust velocities and flow rates were determined following the US EPA Method 2, "Determination of Stack Gas Velocity and Flow Rate (Type S Pitot Tube)". Velocity measurements were taken with a pre-calibrated S-Type pitot tube and incline manometer. Volumetric flow rates were determined following the equal area method as outlined in US EPA Method 1. Temperature measurements were made simultaneously with the velocity measurements and were conducted using a chromel-alumel type "k" thermocouple in conjunction with a digital temperature indicator.

The dry molecular weight of the stack gas was determined following calculations outlined in US EPA Method 3, "Determination of Molecular Weight of Dry Stack Gas". Stack moisture content was determined through direct condensation and according to US EPA Method 4, "Determination of Moisture Content of Stack Gas".

### 4.2 Sampling for Filterable Particulate Matter (PM) and Metals

Sampling for PM in the exhaust stacks was performed in accordance with US EPA Method 5, "Determination of Particulate Matter from Stationary Sources". Sampling was conducted using an Environmental Supply C-5000 Source Sampling System. Triplicate sampling runs were conducted for each stack. Particulate matter concentrations and emission rates were determined utilizing EPA Method 5. Mercury, lead, chromium, and cadmium concentrations and emission rates were determined utilizing Method 29. Particulate and metals were sampled using combined trains as follows:

The combined sample train consisted of a glass nozzle, a heated glass probe, a heated tared quartz filter, two chilled impingers each with 100 mL of 5% HNO<sub>3</sub>/10% H<sub>2</sub>O<sub>2</sub>, an empty impinger, two chilled impingers each with 100 mL of 4% KMnO<sub>4</sub>/10% H<sub>2</sub>SO<sub>4</sub>, an impinger with 200 grams of silica gel, and a dry gas metering console. The temperature of the filter and probe was monitored and controlled to 248 ± 25°F.

At the end of each test run, the nozzle, probe, and filter front half were first rinsed and brushed with acetone into a sample jar. The nozzle, probe, and filter front half were then rinsed with 100 mL of 0.1 N nitric acid into a second sample jar. The filter was then recovered into the original labeled petri dish.

The contents of the 5% HNO<sub>3</sub>/10% H<sub>2</sub>O<sub>2</sub> impinger were poured back into the original reagent jar. Any condensate in the empty impinger was poured into a sample jar. The 4% KMnO<sub>4</sub>/10% H<sub>2</sub>SO<sub>4</sub> impingers were then recovered into another sample jar.



The moisture catch was then determined gravimetrically. The filter back half and 5% HNO<sub>3</sub>/10% H<sub>2</sub>O<sub>2</sub> impingers were rinsed with 100 mL of 0.1 N nitric acid into a sample jar.

The empty impinger was rinsed with 100 mL of 0.1 nitric acid into a sample jar. The 4% KMnO<sub>4</sub>/10% H<sub>2</sub>SO<sub>4</sub> impingers were then rinsed with 100 mL 4% KMnO<sub>4</sub>/10% H<sub>2</sub>SO<sub>4</sub> and 100 mL of DI water into the jar containing the 4% KMnO<sub>4</sub>/10% H<sub>2</sub>SO<sub>4</sub> reagent. The 4% KMnO<sub>4</sub>/10% H<sub>2</sub>SO<sub>4</sub> impingers and connecting glassware were rinsed with 25 mL of 8 N HCl if any brown residue remained. This HCl rinse was added to a jar containing 200 mL of DI water.

Samples were then packaged for transport to ALS Global Laboratories in Burlington, Ontario for analysis.

On December 19, 2018 the second metals/particulate tests failed the final leak check. This test was thrown out and not used for emissions calculations. The field sheets are labelled test 1,3 and 4.

### 4.3 Sampling for Total Fluorides and Hexavalent Chromium

Total fluorides and hexavalent chromium concentrations and emission rates were determined utilizing a combined EPA Method 13B and CARB Method 425 sampling train. The sampling train consisted of a glass nozzle, a heated glass probe, a heated filter (with stainless steel frit), and two chilled impingers each with 100mL of 0.5N NaOH, an empty impinger, an impinger with 200 grams of silica gel, and a dry gas metering console. The equipment was operated in accordance with EPA Method 13B and CARB Method 425.

At the end of each test run, the contents of the first three impingers were collected into a sample jar. The moisture catch was then determined gravimetrically. The nozzle, probe, filter holder, impingers, and connecting glassware were rinsed with DI into the sample jar. The filter was placed into the sample jar.

The samples were analyzed in accordance with EPA Method 13B for total fluorides. The samples were analyzed in accordance with CARB Method 425 for hexavalent chromium.

Samples were packaged for transport to Element One, Inc. in Wilmington, North Carolina for analysis.

Test 1 occurred on December 17<sup>th</sup>, test 2 and 3 occurred on December 19<sup>th</sup>. This is outside the standard 36 hour testing window to complete all three tests. Testing for other parameters occurred on December 18<sup>th</sup> and changes to the process did not occur during the sampling period. MDEQ approved this scenario on site.



#### **4.4 Sampling for Dioxins (PCDD) and Furans (PCDF)**

The concentrations and emissions rates of polychlorinated dibenzo-p-dioxins/polychlorinated dibenzofurans (PCDD/PCDF) or dioxins/furans) were determined utilizing EPA Method 23. The EPA Method 23 sampling train consisted of a glass nozzle, a heated glass probe, a heated glass filter, a condenser, an XAD resin trap, an empty impinger, two chilled impingers each with 100mL of DI water, an empty impinger, an impinger with 200 grams of silica gel, and a dry gas metering console.

Methylene chloride was not used for recovery, as per approval from MDEQ. At the end of each test run, the nozzle, probe and filter front half were rinsed with acetone into a sample jar. The filter was recovered dry into a glass petri dish. The filter backhalf, and condenser were rinsed with acetone into a sample jar. All of the components listed above up to the XAD resin trap were then rinsed again with toluene into a sample jar. The XAD resin trap was sealed and placed into a chilled ice chest. The contents of the first three impingers were poured back into the original reagent jar. The silica gel was poured back into its original container.

The moisture catch was then determined gravimetrically. The samples were analyzed in accordance with EPA Method 23 for dioxins/furans.

Samples were then packaged for transport to ALS Global Laboratories in Burlington, Ontario for analysis.

#### **4.5 Sampling for Hydrogen Chloride**

Hydrogen chloride concentrations and emission rates were determined utilizing EPA Method 26 modified to use large impingers. The EPA Method 26 sampling train consisted of a heated glass probe, a heated quartz filter, and two chilled impingers each with 100mL of 0.1N H<sub>2</sub>SO<sub>4</sub>, one empty impinger, an impinger with 200 grams of silica gel, and a dry gas metering console.

At the end of each test run, the contents of the impingers were poured into a sample jar. The silica gel was returned to its original container. The moisture catch in the train components was then determined gravimetrically. The filter backhalf and H<sub>2</sub>SO<sub>4</sub> impingers were rinsed with DI water into the H<sub>2</sub>SO<sub>4</sub> reagent jar.

Samples were then packaged for transport to ALS Global Laboratories in Burlington, Ontario for analysis.

The H<sub>2</sub>SO<sub>4</sub> portion of the sample was analyzed in accordance with EPA Method 26 for hydrogen chloride.



## 4.6 Sampling for Total Hydrocarbons (as Methane)

Testing for THC (as methane) was accomplished using continuous emission monitors (CEM). The exhaust gas sample was drawn from a single point at the center of the stack using a stainless steel probe. The sample then proceeded to a heated filter, where particulate matter was removed, and then transferred via a heated Teflon line that was set to 320°F to prevent any condensation. The stack gas was routed through a manifold system and introduced to the CEM's for measurement.

Prior to testing, sample system bias checks and instrument linearity checks (calibration error) were conducted. In addition, the analyzers were calibrated (zeroed and span checked) at the completion of each run. Data acquisition was provided using a data logger system that generates one-minute averages concentrations.

## 4.7 Sampling for Gases (Continuous Emissions Monitoring)

RWDI operated continuous emission monitors for oxygen and carbon dioxide in accordance with the applicable US EPA reference method. Prior to testing, a 3-point analyzer calibration error check was conducted using US EPA protocol gases. The calibration error check was performed by introducing zero; mid and high level calibration gases directly into the analyzer. The calibration error check was performed to confirm that the analyzer response was within  $\pm 2\%$  of the certified calibration gas introduced. Prior to each test run, a system-bias test was performed where known concentrations of calibration gases were introduced at the probe tip to measure if the analyzers response was within  $\pm 5\%$  of the introduced calibration gas concentrations. At the conclusion of each test run a system-bias check was performed to evaluate the percent drift from pre and post-test system bias checks. The system bias checks confirmed that the analyzer did not drift greater than  $\pm 3\%$  throughout a test run.

Data acquisition was provided using a data logger system programmed to collect and record data at one second intervals. Average one-minute concentrations were calculated from the one second measurements.

RWDI recorded data is presented in the **tables** section and appendices. DRP's CEM data was recorded for NO<sub>x</sub>, SO<sub>2</sub>, O<sub>2</sub>, CO<sub>2</sub> and CO. For comparison with the facilities permit the DRP CEMs data was used.

RECEIVED  
FEB 21 2019



AIR QUALITY DIVISION

#### 4.8 Sampling for Opacity

Opacity (visible emissions) data was collected by the facility Continuous Opacity Monitors (COMs) in lieu of Method 9 observations.

#### 4.9 Quality Assurance/Quality Control Activities

Applicable quality assurance measures were implemented during the sampling program to ensure the integrity of the results. These measures included detailed documentation of field data, equipment calibrations for all measured parameters, completion of Chain of Custody forms when submitting laboratory samples, and submission of field blank samples to the laboratories. **Table 2** presents a sample log and summarizes the sampling times, sample IDs, filter IDs, and XAD trap IDs.

Stationary Source Audit Samples (SSAS) were provided from ERA and sent to ALS Global Laboratories for analysis. All results were deemed acceptable. The final report of the SSAS program is provided in **Appendix K**.

Quality control procedures specific to the CEM monitoring included linearity checks, to determine the instrument performance, and reproducibility checks prior to its use in the field. Regular performance checks on the analyzer were also carried out during the testing program by performing hourly zero checks and span calibration checks using primary gas standards. Sample system bias checks were also done. These checks were used to verify the ongoing accuracy of the monitor and sampling system over time. Pollutant-free (zero) air was introduced to perform the zero checks, followed by a known calibration (span) gas into the monitor. The response of the monitor to pollutant-free air and the corresponding sensitivity to the span gas were recorded regularly during the tests.

Leak checks were performed on the Method 5 sampling train by plugging the sample inlet and pulling a representative vacuum. This check was done before and after each test. Similar leak check procedures for Pitot tube and pressure lines were also conducted. Daily temperature sensor audits were completed by noting the ambient temperature, as measured by a reference thermometer, and comparing these values to those obtained from the stack sensor. This is available upon request. Leak checks for each test were documented on the field data sheets presented in the applicable appendices for each sample parameter.



## 5 RESULTS

The average emission results for this study are presented in the **Tables** section of this report. **Table 2** presents a summary of test dates and times. A minimum of three (3) tests on the stack was performed for all of the parameters tested in the study. Detailed information regarding each test run can be found in the corresponding Appendix. Below is a summary of the applicable Table and Appendix ID with corresponding test parameter.

**Table 5.0:** Summary of Table & Appendix IDs with Corresponding Test Parameter

Parameter	Table	Appendix
Stack Gas Characteristics	3	C/D/E
Particulate Matter and Selected Metals	4	C
Dioxins and Furans	5	D
Total Fluoride and Hexavalent Chromium	6	E
Hydrogen chloride	7	F
Opacity	8	G
Continuous Emission Monitoring	9/10	H
ROP Limit Comparison	11	-

All calibration information for the equipment used for this study is included in **Appendix J**. All laboratory results are included in **Appendix K**.

### 5.1 Discussion of Results

Results for Boiler 11 indicated that all parameters are in compliance with respect to the ROP limits.

When the laboratory reported values less than their method detection limit for a specific component, the respective concentration and emission rates were calculated using this method detection limit. This method is a conservative approach when calculating the emissions.

**Table 11** shows a comparison of the sampling results to the incinerator performance limits defined in the ROP.



## 6 OPERATING CONDITIONS

Operating conditions during the sampling were monitored by Detroit Renewable Power personnel. All equipment was operated under normal maximum operating conditions.

Radio contact was kept between the process operators and the sampling team. A member of the RWDI sampling team contacted the operator before each test, to ensure that the process was at normal operating conditions.

**Appendix L** contains the process information supplied by Detroit Renewable Power.

## 7 CONCLUSIONS

Testing was successfully completed from December 17<sup>th</sup> to December 19<sup>th</sup>, 2018 on Boiler 11. All sources were tested in accordance with referenced methodologies following the MDEQ approved Sampling Plan submitted August 2, 2018. Results for Boiler 11 indicate that all parameters are in compliance with respect to the ROP limits.

# TABLES



**Table 1: Summary of Sampling Parameters and Methodology**

Source Location	No. of Tests per Stack	Sampling Parameter	Sampling Method
Boiler 11	9	Velocity, Temperature and Flow Rate	U.S. EPA <sup>[2]</sup> Methods 1-4
	3	Total Particulate Matter	U.S. EPA <sup>[2]</sup> Method 5
	3	Metals	U.S. EPA <sup>[2]</sup> Method 29
	3	4-8 PCDD/PCDF	U.S. EPA <sup>[2]</sup> Method 23
	3	Fluoride	U.S. EPA <sup>[2]</sup> Method 13B
	3	CR <sup>+6</sup> Hexavalent Chromium	CARB <sup>[1]</sup> Method 425
	3	Hydrogen Chloride	U.S. EPA <sup>[2]</sup> Method 26
	3	Sulfur Dioxide	U.S. EPA <sup>[2]</sup> Method 6C (CEM)
	3	Total Oxides of Nitrogen	U.S. EPA <sup>[2]</sup> Method 7E (CEM)
	3	Oxygen	U.S. EPA <sup>[2]</sup> Method 3A (CEM)
	3	Carbon Dioxide	U.S. EPA <sup>[2]</sup> Method 3A (CEM)
	3	Carbon Monoxide	U.S. EPA <sup>[2]</sup> Method 10 (CEM)
	3	Total Hydrocarbons (THC)	U.S. EPA <sup>[2]</sup> Method 25A (CEM)

**Notes:**

[1] CARB- California Air Resource Board

[2] U.S. EPA - United States Environmental Protection Agency

**Table 2: Sampling Summary and Sample Log  
Boiler #11**

Source and Test #	Sampling Date	Start Time	End Time	Filter ID / Trap ID	Lab Sample ID
<b>Velocity / Total Particulate / Metals</b>					
Blank	Dec. 19, 2018	--	--		L2192492-4
Test #1	Dec. 18, 2018	12:45 PM	2:55 PM	QZ5737	L2192492-1
Test #3	Dec. 19, 2018	12:35 PM	2:50 PM	QZ5738	L2192492-2
Test #4	Dec. 19, 2018	4:02 PM	6:05 PM	QZ5739	L2192492-3
<b>Velocity / Dioxins and Furans</b>					
Blank	Dec. 18, 2018	--	--	#8	L2213695-4
Test #1	Dec. 17, 2018	8:52 AM	1:13 PM	#16	L2213695-1
Test #2	Dec. 17, 2018	2:10 PM	6:19 PM	#13	L2213695-2
Test #3	Dec. 18, 2018	8:17 AM	12:30 PM	#17	L2213695-3
<b>Hydrogen Chloride</b>					
Blank	Dec. 17, 2018	--	--	N/A	L2213699-4
Test #1	Dec. 17, 2018	9:25 AM	10:25 AM	N/A	L2213699-1
Test #2	Dec. 17, 2018	11:35 AM	12:35 PM	N/A	L2213699-2
Test #3	Dec. 17, 2018	1:37 PM	2:37 PM	N/A	L2213699-3
<b>Velocity/ Fluoride/ Hexavalent Chromium</b>					
Blank	Dec. 19, 2018	--	--	N/A	e32249-4
Test #1	Dec. 17, 2018	3:14 PM	5:25 PM	N/A	e32249-1
Test #2	Dec. 19, 2018	8:17 AM	10:27 AM	N/A	e32249-2
Test #3	Dec. 19, 2018	12:53 PM	3:20 PM	N/A	e32249-3

**RECEIVED**  
**FEB 21 2019**  
**AIR QUALITY DIVISION**

**Table 5: Dioxins and Furans - Average Results**

Boiler #11	Concentration @ Actual O <sub>2</sub>	Concentration @ 7% O <sub>2</sub>	Emission Rate
Parameter	(pg/m <sup>3</sup> )	(ng/m <sup>3</sup> )	(ng/s)
1,2,3,4,6,7,8,9-Octa CDD *	914	1.36	88
Total Tetra CDD*	1130	1.70	110
Total Penta CDD*	1880	2.83	180
Total Hexa CDD*	2290	3.45	220
Total Hepta CDD*	1400	2.12	130
1,2,3,4,6,7,8,9-Octa CDF **	130	0.189	12
Total Tetra CDF*	3200	4.88	310
Total Penta CDF*	2900	4.36	280
Total Hexa CDF*	1700	2.53	160
Total Hepta CDF*	1200	1.81	120
<b>Total =</b>		<b>25</b>	

**Notes:**

[1] Sampling followed U.S. EPA Method 23; average of three tests

[2] Concentration values are expressed at 101.3 kPa, 68 °F, and at 7 % oxygen

\*CDD = chlorodibenzo-p-dioxin

\*\*CDF = chlorodibenzo-p-furan

Detailed sampling results including individual test results can be found in Appendix D

**Table 8: Opacity- Averaged Results**

Boiler #11	Opacity			Average Opacity
	17-Dec-18	18-Dec-18	19-Dec-18	
Parameter	(%)	(%)	(%)	(%)
Opacity	3	3	3	3

**Notes:**

[1] Values from Detroit Renewable Power Opacity Meter

Detailed sampling results including individual test results can be found in Appendix G

**Table 9 - RWDI CEM - Averaged Results**

Boiler #11	Average Test Concentration				Emission Rate
	Reference Conditions --> Units -->	68°F and actual O <sub>2</sub> (ppm)	68°F and actual O <sub>2</sub> (mg/m <sup>3</sup> )	68°F and 7% O <sub>2</sub> (ppm)	
Total Hydrocarbons (expressed as Methane)		5.7	3.8	8.3	0.36
	%				
Oxygen (O <sub>2</sub> )	11.5 (DRP)	11.6 (RWDI, All 3 days)		-	-
Carbon Dioxide (CO <sub>2</sub> )	8.5	-	-	-	-

**Notes:**

[1] Sampling followed U.S. EPA Method 3 (O<sub>2</sub> and CO<sub>2</sub>), and Method 25A (THC)

[2] Average of three tests

[3] Emissions rate calculated based on average dry volumetric flow rate of all isokinetic tests

[4] Average O<sub>2</sub> value was taken from DRP CEMs data from testing periods

[5] Corrected O<sub>2</sub> to 7% equation  $a * ((20.9 - 7) / (20.9 - b))$  a = concentration @ original O<sub>2</sub> b = original O<sub>2</sub> %

Detailed sampling results including individual test results can be found in Appendix H

DRP O<sub>2</sub> Data (%)

THC Test 1: 11.3  
 THC Test 2: 11.5  
 THC Test 3: 11.3

**Table 10: 24 Hour Averaged CEM Data**

<b>Boiler #11</b>	<b>17-Dec-18</b>	<b>18-Dec-18</b>	<b>19-Dec-18</b>	<b>Average</b>
<b>Parameter</b>	<b>(ppm)</b>	<b>(ppm)</b>	<b>(ppm)</b>	<b>(ppm)</b>
Nitrogen Oxides (NO <sub>x</sub> ) <sup>[1]</sup>	184	207	204	198
Sulfur Dioxide (SO <sub>2</sub> ) <sup>[1]</sup>	14	11	7	11
Carbon Monoxide (CO) <sup>[1]</sup>	146	118	78	114
Oxygen (O <sub>2</sub> ) <sup>[1]</sup>	11.5	11.8	11.3	11.5

**Notes:**

[1] Data from Detroit Renewable Power Continuous Emissions Monitors, corrected to 7% O<sub>2</sub> where applicable

Detailed sampling results including individual test results can be found in Appendix H

**Table 11: Renewable Operating Permit (ROP) Limit Comparisons**

Parameter	Stack Testing Results <sup>[1]</sup>	ROP Limit <sup>[2]</sup>
<b>Limits from ROP: MI-ROP-M4148-2011a</b>	<b>EUBOILER011</b>	
Particulate Matter (PM)	0.0011	0.010 gr/dscf
Cadmium	< 0.26	37 µg/dscm
Hexavalent Chromium	0.14	4.2 µg/dscm
Total Chromium	2.20	200 µg/dscm
Lead	0.002	0.440 mg/dscm
Mercury	< 1.10	80 µg/dscm
Dioxins/Furans (CDD/CDF)	25	30 ng/dscm
Hydrogen Chloride (HCl)	3.7	25 ppmv
Sulfur Dioxide (SO <sub>2</sub> )- 24 hour average	11	29 ppmv
Total Fluoride	0.22	5 ppmv
Carbon Monoxide (CO)- 24 hour average	114	200 ppmv
Volatile Organic Compounds (VOC)	8.3	65 ppmv
Nitrogen Oxides (NOx)	198	247 ppmv

**Notes:**

[1] Concentration values are expressed at 101.3 kPa, 68 °F, and 7% oxygen

[2] Refer to Appendix A for Renewable Operating Permit: MI-ROP-M4148-2011a