



RICK SNYDER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF ENVIRONMENTAL QUALITY  
DETROIT



DAN WYANT  
DIRECTOR

June 29, 2015

Mr. Linwood Bubar  
Detroit Renewable Power  
5700 Russell St.  
Detroit, MI 48211

SRN: M4148, Wayne County

Dear Mr. Bubar:

**VIOLATION NOTICE**

On April 23, 2015, the Department of Environmental Quality (DEQ), Air Quality Division (AQD), received the Quarterly Excess Emission and Monitoring Systems Performance Report (first quarter of 2015) of Detroit Renewable Power, located at 5700 Russell St., Detroit, Michigan. During the review of the report, staff observed the following:

Process Description	Rule/Permit Condition Violated	Comments
Refuse-derived fuel (RDF) fired boiler #11	ROP No. MI-ROP-M4148-2011, Table FGBOILERS011-013, Condition I. 9.	The sulfur dioxide (SO <sub>2</sub> ) emission based on a 24-hour geometric mean average exceeded 29 ppmv on 3/1/15 & 3/14/15.
RDF fired boiler #12	ROP No. MI-ROP-M4148-2011, Table FGBOILERS011-013, Condition I. 9.	The sulfur dioxide (SO <sub>2</sub> ) emission based on a 24-hour geometric mean average exceeded 29 ppmv on 3/1/2015.

Please initiate actions necessary to correct the cited violations and submit a written response to this Violation Notice by July 20, 2015 (which coincides with 21 calendar days from the date of this letter). Although in your email of 6/17, you provided some of the explanation of the cause of the violation, the written response should include: an explanation of the causes of the violations if you identified additional causes; a summary of the actions that have been taken and are proposed to be taken to correct the violations and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

If Detroit Renewable Power believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Mr. Linwood Bubar  
Page 2  
June 29, 2015

Thank you for your attention to resolving the violations cited above. If you have any questions regarding the violations or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,

A handwritten signature in blue ink that reads "Joyce Zhu". The signature is fluid and cursive, with a long horizontal flourish extending to the right.

Joyce Zhu  
Senior Environmental Engineer  
Air Quality Division  
586-753-3748

cc: Ms. LaReina Wheeler, City of Detroit  
Mr. Alan Greenberg, DRP  
cc/via e-mail: Ms. Lynn Fiedler, DEQ  
Ms. Mary Ann Dolehanty, DEQ  
Ms. Barb Rosenbaum, DEQ  
Ms. Teresa Seidel, DEQ  
Mr. Thomas Hess, DEQ  
Ms. Wilhemina McLemore, DEQ  
Mr. Jeff Korniski, DEQ