

DEPARTMENT OF ENVIRONMENTAL QUALITY  
AIR QUALITY DIVISION

**FCE Summary Report**

Facility : BAY CITY ELECTRIC LIGHT & POWER	SRN : N3195
Location : 619 S HENRY ST	District : Saginaw Bay
	County : BAY
City : BAY CITY      State: MI      Zip Code : 48708	Compliance Status : Compliance
Source Class : SM OPT OUT	Staff : Gina McCann
FCE Begin Date : 1/1/2014	FCE Completion Date : 1/14/2016
Comments : FCE starting 01/01/2014 through 01/14/2016	

**List of Partial Compliance Evaluations :**

Activity Date	Activity Type	Compliance Status	Comments
01/07/2016	Scheduled Inspection	Compliance	Inspection of SM-Opt Out 823-91B.
08/13/2014	Stack Test	Compliance	MACT ZZZZ Carbon monoxide test to demonstrate >70% reduction efficiency. Engine #3 avg 89.65% reduction, Engine #4 86.34% reduction
07/30/2014	Reg. Applicability Determination	Compliance	Rule 208a determination if Major or True Minor. PTI 823-91A limits fuel use & hours. Per permit application review notes, NOx expected is 71.187 Ton/year
05/01/2014	208A Registration	Compliance	208a Annual Renewal Registration

Name:  Date: 1/14/2016 Supervisor: 