

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report

Facility : Consumers Energy - White Pigeon Compressor Station	SRN : N5573
Location : 68536 A ROAD, ROUTE 1	District : Kalamazoo
	County : SAINT JOSEPH
City : WHITE PIGEON State: MI Zip Code : 49099	Compliance Status : Compliance
Source Class : MAJOR	Staff : Jared Edgerton
FCE Begin Date : 4/1/2022	FCE Completion Date : 6/13/2024
Comments : FCE Report. Facility appears compliant.	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
06/13/2024	On-site Inspection	Compliance	Unannounced Air Quality Inspection to determine compliance with ROP No. MI-ROP-N5573-2018 and federal air pollution control regulations 40 CFR Part63 Subpart ZZZZ and 40 CFR Part 60 Subpart JJJJ.
05/16/2024	Stack Test	Compliance	4 RICE tested (EUENGINE1-4) for compliance with the emission limits of NSPS 40 CFR Part 60, Subpart JJJJ, NESHAP 40 CFR Part 63, Subpart ZZZZ, and ROP MI-ROP-N5573-2018. All units appear to be in compliance with NOx, CO, VOC, and O2 limits at this time.
03/26/2024	Stack Test Observation	Compliance	EUENGINE1 - EUENGINE4 stack test for NOx, CO, and VOC
03/14/2024	MACT (Part 63)	Compliance	40 CFR Part 63, Subpart ZZZZ Semiannual CPMS Compliance Report. Site states no deviations occurred.
09/22/2023	MACT (Part 63)	Compliance	40 CFR Part 63, Subpart ZZZZ Semiannual CPMS Compliance Report. Site states no deviations occurred.

Activity Date	Activity Type	Compliance Status	Comments
08/04/2023	Release Reports	Unknown	The facility reported the planned emergent flaring of 12 miles of 26" transmission pipeline to support a pipeline outage. Total amount to be flared is 9.98 MMCF of natural gas. The facility will also contact PEAS to report the release as required by Rule 336.1285(2)(mm) (iv).
06/01/2023	Stack Test	Compliance	Test Report for FGENGINE1, EUENGINE2, EUENGINE2 & EUENGINE4). Facility reports to be in compliance.
05/18/2023	Stack Test	Compliance	Test Report for EUEMERGGEN. Test results appear to be in compliance.
05/18/2023	Annual Emissions Report (or MAERS)	Compliance	2022 MAERS Submittal (electronic). 2022 SCT Spreadsheet (electronic).
05/18/2023	ROP Annual Cert	Compliance	ROP Annual Certification. No deviations reported.
05/18/2023	ROP SEMI 2 CERT	Compliance	ROP Semi 2 Certification. No deviations reported.
05/18/2023	MACT (Part 63)	Compliance	40 CFR Part 63, Subpart ZZZZ Semiannual CPMS Compliance report. No deviations reported.
09/22/2022	ROP Semi 1 Cert	Compliance	ROP Semi 1 Certification. Report states there were deviations, supporting documentation shows there were no deviations.
09/22/2022	MACT (Part 63)	Compliance	40 CFR Part 63, Subpart ZZZZ Semiannual CPMS Compliance Report
09/08/2022	Stack Test	Compliance	Stack Test report for EUENGINE2. Appears to be in compliance.
08/11/2022	ROP R215 Notification	Compliance	Brent Keskin, Sr Field Leader is the Authorized Representative for the White Pigeon Compressor Station.
06/30/2022	Stack Test	Compliance	Test Report for EUENGINE1, EUENGINE3 & EUENGINE4
04/19/2022	On-site Inspection	Compliance	Scheduled Inspection for FCE
04/07/2022	Annual Emissions Report (or MAERS)	Compliance	ROP certification report for MAERS and the 2021 Supplemental Control Information submitted to MAERS on 3/21/22

Name:



Date:

9-26-24

Supervisor:

