

RECEIVED

MAR 18 2019

AIR QUALITY DIVISION

March 14, 2019

Mr. Scott Miller  
Air Quality Division  
Michigan Department of Environmental Quality  
301 E. Louis B Glick Highway  
Jackson, MI 49201

-- transmitted via FedEx --

**Subject: Submittal of Emissions Test Report:  
EURICE1, EURICE2, EURICE3  
DTE Willow Run Compressor Station – PTI 44-16A  
Ypsilanti, MI**

Dear Mr. Miller:

N7421

Enclosed find the report for emissions testing conducted on three (3) new RICE engines at the DTE – Willow Run Compressor Station. The testing was conducted on January 15-16, 2019. The testing was conducted by Montrose Air Quality Services.

The attached report details the results of nitrogen oxides (NO<sub>x</sub>) testing in the emissions from each of the three engines referenced above. Only NO<sub>x</sub> was tested at that time. CO destruction efficiency testing was not conducted, and will need to be conducted a not yet determined date. The previously submitted **Request for a Test Deadline Extension**, dated January 17, 2019, explains why CO destruction could not be tested at that time.

what about  
had?

If you have any questions about this report or would like to discuss plans for completing the CO destruction efficiency testing, please contact me at (313) 897-0298 or thomas.durham@dteenergy.com.

Sincerely,  
DTE ENERGY CORPORATE SERVICES, LLC

Thomas Durham  
Manager, Environmental Field Services  
Environmental Management & Resources (EM&R)

enc Emission Test Report – EURICE1, EURICE2, EURICE3

cc Karen Kajiya-Mills – MDEQ (with enc)

**EXECUTIVE SUMMARY**

Montrose Air Quality Services (MAQS) was retained by DTE Energy Corporate Services (DTE) to evaluate nitrogen oxides (NOx) emission rates from three engines while operating at 90% load or greater at the Willow Run Compressor Station located in Ypsilanti, Michigan. The emissions test program was conducted on January 15<sup>th</sup>-16<sup>th</sup>, 2019.

Testing of engines consisted of triplicate 60-minute test runs while each unit was operating at 90% load or greater. The emissions test program was required by MDEQ Air Quality Division Permit to Install No. 44-16A. Permitted emissions limits for all three engines were met. The results of the emission test program are summarized by Table I.

**Table I  
Overall Emission Summary  
Test Date: January 15<sup>th</sup>-16<sup>th</sup>, 2019**

<b>Engine 2100 (EURICE 1)</b>		
<b>Pollutant</b>	<b>Average Emission Rate</b>	<b>Emission Limit</b>
NOx	27 ppmvd <sup>1</sup>	82 ppmvd <sup>1</sup>
NOx	3.49 lb/hr	5.51 lb/hr
<b>Engine 2200 (EURICE 2)</b>		
<b>Pollutant</b>	<b>Average Emission Rate</b>	<b>Emission Limit</b>
NOx	32 ppmvd <sup>1</sup>	82 ppmvd <sup>1</sup>
NOx	2.05 lb/hr	2.76 lb/hr
<b>Engine 2300 (EURICE 3)</b>		
<b>Pollutant</b>	<b>Average Emission Rate</b>	<b>Emission Limit</b>
NOx	34 ppmvd <sup>1</sup>	82 ppmvd <sup>1</sup>
NOx	2.00 lb/hr	2.76 lb/hr

**RECEIVED**  
 MAR 18 2019  
 AIR QUALITY DIVISION

<sup>1</sup> NOx ppmvd corrected to 15% O<sub>2</sub>

**TABLE OF CONTENTS**

**1. INTRODUCTION .....5**

    1.A IDENTIFICATION, LOCATION, AND DATES OF TEST .....5

    1.B PURPOSE OF TESTING.....5

    1.C SOURCE DESCRIPTION .....5

    1.D TEST PROGRAM CONTACTS .....6

**2. SUMMARY OF RESULTS .....6**

    2.A OPERATING DATA.....7

    2.B APPLICABLE PERMIT.....7

    2.C RESULTS .....7

**3. SOURCE DESCRIPTION.....7**

    3.A PROCESS DESCRIPTION .....7

    3.B PROCESS FLOW DIAGRAM .....7

    3.C RAW AND FINISHED MATERIALS .....7

    3.D PROCESS CAPACITY .....7

    3.E PROCESS INSTRUMENTATION.....7

**4. SAMPLING AND ANALYTICAL PROCEDURES .....7**

    4.A SAMPLING TRAIN AND FIELD PROCEDURES .....8

    4.B RECOVERY AND ANALYTICAL PROCEDURES .....8

    4.C SAMPLING PORTS.....8

    4.D TRAVERSE POINTS .....9

**5. TEST RESULTS AND DISCUSSION .....9**

    5.A RESULTS TABULATION .....9

    5.B DISCUSSION OF RESULTS .....9

    5.C SAMPLING PROCEDURE VARIATIONS .....9

    5.D PROCESS OR CONTROL DEVICE UPSETS .....10

    5.E CONTROL DEVICE MAINTENANCE .....10

    5.F RE-TEST .....10

    5.G AUDIT SAMPLE ANALYSES .....10

    5.H CALIBRATION SHEETS.....10

    5.I SAMPLE CALCULATIONS.....10

    5.J FIELD DATA SHEETS.....10

    5.K LABORATORY DATA .....10

## **TABLE OF CONTENTS (continued)**

### **SUMMARY TABLES**

Table 1	Emission Limitations
Table 2	Test Personnel Summary
Table 3	Overall Emissions Summary
Table 4	Engine 2100 (EURICE1) Detailed Emission Test Results Summary
Table 5	Engine 2200 (EURICE2) Detailed Emission Test Results Summary
Table 6	Engine 2300 (EURICE3) Detailed Emission Test Results Summary

### **FIGURES**

Figure 1 – USEPA Methods 3A and 7E Sampling Diagram

### **APPENDIX**

Appendix A	Field and Computer Generated Raw Data and Field Notes
Appendix B	Equipment Calibration and Span Gas Documents
Appendix C	Example Calculations
Appendix D	Raw CEM Data
Appendix E	Process Data

## 1. Introduction

Montrose Air Quality Services (MAQS) was retained by DTE Energy Corporate Services (DTE) to evaluate nitrogen oxides (NOx) emission rates from three engines while operating at 90% load or greater at the Willow Run Compressor Station located in Ypsilanti, Michigan. The emissions test program was conducted on January 15<sup>th</sup>-16<sup>th</sup>, 2019.

Michigan Department of Environmental Quality – Air Quality Division has published a guidance document entitled “Format for Submittal of Source Emission Test Plans and Reports” (March 2018). The following is a summary of the emissions test program and results in the format suggested by the aforementioned document.

### 1.a Identification, Location, and Dates of Test

Sampling and analysis for the emission test program was conducted on January 15<sup>th</sup>-16<sup>th</sup>, 2019 at the Willow Run Compressor Station located in Ypsilanti, Michigan. The test program included evaluation of NOx and O<sub>2</sub> emissions from Engines 2100, 2200, and 2300.

### 1.b Purpose of Testing

AQD issued PTI 44-16A to DTE. This permit limits emissions from each engine as summarized by Table 1.

**Table 1**  
**NOx Emission Limitations**  
**DTE Willow Run**

Engine	NOx Emission Limits
2100 (EURICE1)	82 ppmvd*
	5.51 lbs/hr**
2200 (EURICE2) and 2300 (EURICE3)	82 ppmvd*
	2.76 lbs/hr**

\*Corrected to 15% O<sub>2</sub>

\*\* Per Method 19

### 1.c Source Description

The Willow Run Compressor Station located at 3020 East Michigan Ave, Ypsilanti, Michigan, employs the use of three non-emergency natural gas-fired reciprocating internal combustion engines (RICE). The engines are identified as EURICE1, EURICE2, and EURICE3 in PTI 44-16A. EURICE2 and EURICE3 are rated at 2,500 HP and EURICE1 are rated at 5,000 HP.

## 1.d Test Program Contacts

The contacts for the source and test report are:

Mr. Chris Conley  
Manager, Transmission & Storage Operations  
DTE GAS  
3515 Childs Lake Rd  
Milford, MI 48381  
(248) 685-9606

Mr. Thomas Durham  
Manager, Environmental Field Services  
DTE Energy  
7940 Livernois Ave., WSC, H-136  
Detroit, MI 49210  
(313) 897-0298

Names and affiliations for personnel who were present during the testing program are summarized by Table 2.

**Table 2**  
**Test Personnel**

<b>Name and Title</b>	<b>Affiliation</b>	<b>Telephone</b>
Mr. Brad Piontek	DTE Gas Compressor Station Willow Run 3020 East Michigan Ave Ypsilanti, MI	(248) 217-7355
Mr. Steven Smith Field Project Manager	MAQS 4949 Fernlee Royal Oak, MI 48073	(248) 548-8070
Mr. Mike Nummer Field Technician	MAQS 4949 Fernlee Royal Oak, MI 48073	(248) 548-8070
Mr. Tom Gasoli	MDEQ Air Quality Division	(517) 402-6315

## 2. Summary of Results

Sections 2.a through 2.d summarize the results of the emissions compliance test program.

## **2.a Operating Data**

Operating parameters used to regulate the engines include speed & torque (BHp), fuel flow, inlet & exhaust temperature & pressure, and timing.

## **2.b Applicable Permit**

The applicable permit for this emissions test program is PTI 44-16A.

## **2.c Results**

The overall results of the emission test program are summarized by Table 3 (see Section 5.a). NOx emissions from each engine were below the corresponding limit of 5.51 lb/hr for engine 2100 and 2.76 lb/hr for engine 2200 and 2300.

## **3. Source Description**

Sections 3.a through 3.e provide a detailed description of the process.

### **3.a Process Description**

Each of the three compressor engines operate on an as needed basis providing pipeline pressure. Each engine was tested at 100% (+/- 10%) rated capacity.

### **3.b Process Flow Diagram**

Due to the simplicity of the natural gas engine, a process flow diagram is not necessary.

### **3.c Raw and Finished Materials**

The engines are natural gas-fired units. Fuel consumption varies with operating parameters and will be measured throughout the emissions test.

### **3.d Process Capacity**

Engine 2100 is rated at 5,000 HP and engines 2200 and 2300 are rated at 2,500 HP. The engines were tested at loads over 90% capacity.

### **3.e Process Instrumentation**

Operating parameters used to regulate the engines include speed & torque (BHp), fuel flow, inlet & exhaust temperature & pressure, and timing. Operating parameters were documented during each run.

## **4. Sampling and Analytical Procedures**

Sections 4.a through 4.d provide a summary of the sampling and analytical procedures used.

#### **4.a Sampling Train and Field Procedures**

Engine exhaust NO<sub>x</sub> content was measured using a Teledyne Model T-200H NO<sub>x</sub> gas analyzer and the O<sub>2</sub> content was measured using a Servomex 4100 O<sub>2</sub>/CO<sub>2</sub> gas analyzer. A sample of the gas stream was drawn through an insulated stainless-steel probe with an in-line glass fiber filter to remove any particulate, a heated Teflon<sup>®</sup> sample line, and through an electronic sample conditioner to remove the moisture from the sample before it enters the analyzer. Data was recorded at 4-second intervals on a PC equipped with data acquisition software.

For analyzer calibrations, calibration gases were mixed to desired concentrations using an Environics Series 4040 Computerized Gas Dilution System. The Series 4040 consists of a single chassis with four mass flow controllers. The mass flow controllers are factory-calibrated using a primary flow standard traceable to the United State's National Institute of Standards and Technology (NIST). Each flow controller utilizes an 11-point calibration table with linear interpolation, to increase accuracy and reduce flow controller nonlinearity. A schematic of the sampling train is provided as Figure 1.

Sampling and analysis procedures utilized the following test methods codified at Title 40, Part 60, Appendix A of the Code of Federal Regulations (40 CFR 60, Appendix A):

- Method 3A, "*Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources*", was used to measure the O<sub>2</sub> concentration of the exhaust gas.
- Method 7E, "*Determination of Nitrogen Oxide Emissions from Stationary Sources*", was used to measure the NO<sub>x</sub> concentration of the exhaust gas.
- Method 19, "*Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide, and Nitrogen Oxide Emission Rates*", was used to calculate the exhaust gas flowrates.

The accuracy of the gas dilution system was verified using the procedures detailed by Method 205 and the NO<sub>x</sub> converter efficiency was verified as specified by Method 7E.

#### **4.b Recovery and Analytical Procedures**

This test program did not include laboratory samples, consequently, sample recovery and analysis is not applicable to this test program.

#### **4.c Sampling Ports**

A single outlet port was used for sampling at three traverse points.

#### 4.d Traverse Points

Three traverse points were used for sampling each run.

#### 5. Test Results and Discussion

Sections 5.a through 5.k provide a summary of the test results.

##### 5.a Results Tabulation

The overall results of the emissions test program are summarized by Table 3. Detailed results for the emissions test program are summarized by Tables 4-6.

**Table 3**  
**Overall Emission Summary**  
**Test Date: January 15<sup>th</sup>-16<sup>th</sup>, 2019**

<b>Engine 2100 (EURICE 1)</b>		
<b>Pollutant</b>	<b>Average Emission Rate</b>	<b>Emission Limit</b>
NOx	27 ppmvd <sup>1</sup>	82 ppmvd <sup>1</sup>
NOx	3.49 lb/hr	5.51 lb/hr
<b>Engine 2200 (EURICE 2)</b>		
<b>Pollutant</b>	<b>Average Emission Rate</b>	<b>Emission Limit</b>
NOx	32 ppmvd <sup>1</sup>	82 ppmvd <sup>1</sup>
NOx	2.05 lb/hr	2.76 lb/hr
<b>Engine 2300 (EURICE 3)</b>		
<b>Pollutant</b>	<b>Average Emission Rate</b>	<b>Emission Limit</b>
NOx	34 ppmvd <sup>1</sup>	82 ppmvd <sup>1</sup>
NOx	2.00 lb/hr	2.76 lb/hr

<sup>1</sup> NOx ppmvd corrected to 15% O<sub>2</sub>

##### 5.b Discussion of Results

NOx emissions from each engine were below the corresponding limit of 5.51 lb/hr for engine 2100 and 2.76 lb/hr for engine 2200 and 2300.

##### 5.c Sampling Procedure Variations

There were no sampling variations used during the emission compliance test program.

**5.d Process or Control Device Upsets**

No upset conditions occurred during testing.

**5.e Control Device Maintenance**

There was no control equipment maintenance performed during the emissions test program.

**5.f Re-Test**

The emissions test program was not a re-test.

**5.g Audit Sample Analyses**

No audit samples were collected as part of the test program.

**5.h Calibration Sheets**

Relevant equipment calibration documents are provided in Appendix B.

**5.i Sample Calculations**

Sample calculations are provided in Appendix C.

**5.j Field Data Sheets**

Field documents relevant to the emissions test program are presented in Appendix A.

**5.k Laboratory Data**

There are no laboratory results for this test program. Raw CEM data is provided electronically in Appendix D.

**MEASUREMENT UNCERTAINTY STATEMENT**


Both qualitative and quantitative factors contribute to field measurement uncertainty and should be taken into consideration when interpreting the results contained within this report. Whenever possible, Montrose Air Quality Services, LLC, (MAQS) personnel reduce the impact of these uncertainty factors through the use of approved and validated test methods. In addition, MAQS personnel perform routine instrument and equipment

calibrations and ensure that the calibration standards, instruments, and equipment used during test events meet, at a minimum, test method specifications as well as the specifications of our Quality Manual and ASTM D 7036-04. The limitations of the various methods, instruments, equipment, and materials utilized during this test have been reasonably considered, but the ultimate impact of the cumulative uncertainty of this project is not fully identified within the results of this report.

**Limitations**

All testing performed was done in conformance to the ASTM D7036-04 standard. The information and opinions rendered in this report are exclusively for use by DTE Energy. MAQS will not distribute or publish this report without DTE Energy's consent except as required by law or court order. MAQS accepts responsibility for the competent performance of its duties in executing the assignment and preparing reports in accordance with the normal standards of the profession, but disclaims any responsibility for consequential damages.

This report was prepared by:   
Steven Smith  
Client Project Manager

This report was reviewed by:   
Matt Young  
Client Project Manager

# Tables

**Table 4**  
**Engine 2100 Nox Emission Rates**  
**DTE Willow Run**  
**Ypsilanti, Michigan**  
**MAQS Project Number 049AS-549969**  
**Sampling Dates: January 15, 2019**

Parameter	Run 1	Run 2	Run 3	Average
Test Run Date	1/15/2019	1/15/2019	1/15/2019	
Test Run Time	17:32-18:32	18:42-19:42	19:52-20:52	
Gas flowrate (scfm)	33,727	33,741	33,778	33,749
Oxygen Concentration (%)	10.9	10.9	10.9	10.9
Oxygen Concentration (% , drift corrected as per USEPA 7E)	11.2	11.2	11.1	11.2
Outlet Oxides of Nitrogen Concentration (ppmv)	44.4	44.5	45.3	44.7
Outlet NOx Concentration (ppmv, corrected as per USEPA 7E)	44.3	44.3	45.4	44.7
Outlet NOx Concentration (ppmv, corrected to 15% O <sub>2</sub> )	26.9	26.9	27.4	27.1
Outlet NOx (lb/mmbtu)	0.099	0.099	0.101	0.100
NOx Emission Rate (lb/hr) (corrected as per USEPA 7E) Method-19	3.47	3.47	3.49	3.49

O <sub>2</sub> Correction			
Co	0.00	0.00	0.00
Cma	10.08	10.08	10.08
Cm	9.85	9.82	9.87

NOx Correction			
Co	1.07	0.96	0.92
Cma	100	100	100
Cm	98.82	99.13	98.61

Natural gas BTU = 1038

scfm = standard cubic feet per minute

dscfm = dry standard cubic feet per minute

ppmv = parts per million on a volume-to-volume basis

lb/hr = pounds per hour

MW = molecular weight (CO = 28.01, NOx = 46.01, SO<sub>2</sub> = 64.05, C<sub>3</sub>H<sub>8</sub> = 44.10, carbon = 12.01)

24.14 = molar volume of air at standard conditions (70°F, 29.92" Hg)

35.31 = ft<sup>3</sup> per m<sup>3</sup>

453600 = mg per lb

Co = Average of initial and final zero gases

Cma = Actual concentration of the calibration gas

Cm = Average of initial and final calibration gases

<sup>1</sup>emission rate calculated on dry basis

<sup>2</sup>emission rate calculated on wet basis

**Equations**

$$\text{lb/hr} = \text{ppmv} * \text{MW}/24.14 * 1/35.31 * 1/453,600 * \text{dscfm} * 60$$

$$\text{Conc}_{\text{O}_2=15\%} = \text{Conc} * (20.9 - 15)/(20.9 - \%O_2)$$

RECEIVED  
 MAR 18 2019  
 AIR QUALITY DIVISION

**Table 5**  
**Engine 2200 Nox Emission Rates**  
**DTE Willow Run**  
**Ypsilanti, Michigan**  
**MAQS Project Number 049AS-549969**  
**Sampling Dates: January 15, 2019**

Parameter	Run 1	Run 2	Run 3	Average
Test Run Date	1/15/2019	1/15/2019	1/15/2019	
Test Run Time	13:05-14:05	14:15-15:16	15:27-16:27	
Gas flowrate (scfh)	16,912	16,904	16,860	16,892
Oxygen Concentration (%)	11.1	11.1	11.0	11.1
Oxygen Concentration (% , drift corrected as per USEPA 7E)	11.3	11.3	11.2	11.3
Outlet Oxides of Nitrogen Concentration (ppmv)	50.8	51.4	52.2	51.5
Outlet NOx Concentration (ppmv, corrected as per USEPA 7E)	51.3	51.5	53.0	51.9
Outlet NOx Concentration (ppmv, corrected to 15% O <sub>2</sub> )	31.3	31.5	32.4	31.7
Outlet NOx (lb/mmbtu)	0.115	0.116	0.119	0.117
NOx Emission Rate (lb/hr) (corrected as per USEPA 7E) Method-19	2.03	2.04	2.09	2.05

O <sub>2</sub> Correction			
Co	0.00	0.00	0.00
Cma	10.08	10.08	10.08
Cm	9.95	9.91	9.89

NOx Correction			
Co	1.46	1.90	1.14
Cma	100	100	100
Cm	97.76	98.04	97.57

Natural gas BTU = 1038

scfm = standard cubic feet per minute

dscfm = dry standard cubic feet per minute

ppmv = parts per million on a volume-to-volume basis

lb/hr = pounds per hour

MW = molecular weight (CO = 28.01, NOx = 46.01, SO<sub>2</sub> = 64.05, C<sub>3</sub>H<sub>8</sub> = 44.10, carbon = 12.01)

24.14 = molar volume of air at standard conditions (70°F, 29.92" Hg)

35.31 = ft<sup>3</sup> per m<sup>3</sup>

453600 = mg per lb

Co = Average of initial and final zero gases

Cma = Actual concentration of the calibration gas

Cm = Average of initial and final calibration gases

<sup>1</sup>emission rate calculated on dry basis

<sup>2</sup>emission rate calculated on wet basis

**Equations**

$$\text{lb/hr} = \text{ppmv} * \text{MW}/24.14 * 1/35.31 * 1/453,600 * \text{dscfm} * 60$$

$$\text{Conc}_{@15\%O_2} = \text{Conc} * (20.9 - 15)/(20.9 - \%O_2)$$

**Table 6**  
**Engine 2300 Nox Emission Rates**  
**DTE Willow Run**  
**Ypsilanti, Michigan**  
**MAQS Project Number 049AS-549969**  
**Sampling Dates: January 16, 2019**

Parameter	Run 1	Run 2	Run 3	Average
Test Run Date	1/16/2019	1/16/2019	1/16/2019	
Test Run Time	9:20-10:20	10:28-11:28	11:38-12:38	
Gas flowrate (scfh)	15,156	15,761	15,915	<b>15,611</b>
Oxygen Concentration (%)	11.4	11.4	11.4	<b>11.4</b>
Oxygen Concentration (%; drift corrected as per USEPA 7E)	11.5	11.5	11.6	<b>11.5</b>
Outlet Oxides of Nitrogen Concentration (ppmv)	52.0	52.2	52.3	<b>52.2</b>
Outlet NOx Concentration (ppmv, corrected as per USEPA 7E)	53.2	53.1	53.3	<b>53.2</b>
Outlet NOx Concentration (ppmv, corrected to 15% O <sub>2</sub> )	33.4	33.5	33.6	<b>33.5</b>
Outlet NOx (lb/mmbtu)	0.123	0.123	0.124	<b>0.123</b>
NOx Emission Rate (lb/hr) (corrected as per USEPA 7E) Method-19	1.94	2.02	2.05	<b>2.00</b>

O <sub>2</sub> Correction			
Co	0.07	0.05	0.02
Cma	10.08	10.08	10.08
Cm	9.98	9.97	9.94

NOx Correction			
Co	0.26	0.63	0.80
Cma	100	100	100
Cm	97.46	97.87	97.57

Natural gas BTU = 1038

scfm = standard cubic feet per minute

dscfm = dry standard cubic feet per minute

ppmv = parts per million on a volume-to-volume basis

lb/hr = pounds per hour

MW = molecular weight (CO = 28.01, NOx = 46.01, SO<sub>2</sub> = 64.05, C<sub>3</sub>H<sub>8</sub> = 44.10, carbon = 12.01)

24.14 = molar volume of air at standard conditions (70°F, 29.92" Hg)

35.31 = ft<sup>3</sup> per m<sup>3</sup>

453600 = mg per lb

Co= Average of initial and final zero gases

Cma=Actual concentration of the calibration gas

Cm= Average of initial and final calibration gases


<sup>1</sup>emission rate calculated on dry basis

<sup>2</sup>emission rate calculated on wet basis

**Equations**

$$\text{lb/hr} = \text{ppmv} * \text{MW}/24.14 * 1/35.31 * 1/453,600 * \text{dscfm} * 60$$

$$\text{Conc}_{@15\%O_2} = \text{Conc} * (20.9 - 15)/(20.9 - \%O_2)$$



**Figure No. 1**

Site:  
USEPA Method 3A and 7E  
DTE Willow Run  
Ypsilanti, Michigan

Sampling Date:  
January 15-16, 2019

Montrose Air Quality Services  
4949 Fernlee Avenue  
Royal Oak, MI 48073