

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : Newberry Water & Light Board	SRN : P0008
Location : 307 E. McMillan Avenue	District : Upper Peninsula
	County : LUCE
City : NEWBERRY State: MI Zip Code : 49868	Compliance Status : Compliance
Source Class : SM OPT OUT	Staff : Ed Lancaster
FCE Begin Date : 12/1/2015	FCE Completion Date : 11/29/2016
Comments :	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
11/22/2016	Stack Test	Compliance	Stack Test was to show compliance of Generator Unit #1 with the RICE MACT, carbon monoxide destruction efficiency. Test results showed average destruction efficiency of 90.8%, well above the standard of 70%.
10/11/2016	Self Initiated Inspection	Compliance	Self-initiated inspection and stack test observation.

Name: Ed Lancaster Date: 11/29/16

Supervisor: 