

FORTISTAR Methane Group

C&C Energy LLC

19401 15 Mile Road ♦ Marshall, Michigan 49068

Tel. (269) 781-8044 ♦ Fax. (269) 781-8217

December 18, 2014

Mr. Matthew Deskins
Air Quality Division
Michigan Department of Environmental Quality
7953 Adobe Road
Kalamazoo, MI 49009

Subject: Engine #2 Retest, grams/bhp-hr Results
C&C Energy LLC
Marshall, Michigan (MI-ROP-P0222-2012)

Dear Mr. Deskins,

Following discussions with the source testing firm M3V LLC, C&C Energy LLC became aware that the MDEQ-AQD was looking for further information from M3V LLC concerning the Source Test Report submitted to your department on November 21, 2014. Please find attached the results for the CO grams/bhp-hr emission rate for Engine #2 calculated during the source test conducted by M3V, LLC on October 30, 2014. While the results indicate a slightly higher emission rate than the permitted limit (1.07% over permitted number), we would like the DAQ to note that the mass emission rates in lb/hr were under the permitted limits.

If you have any questions, please contact Suparna Chakladar at your convenience at (951)-833-4153.

Sincerely,



Anthony J. Falbo
Senior Vice President - Operations
FORTISTAR Methane Group
C&C Energy LLC

Enclosures

cc: Nathaniel Hude, Michigan DEQ
Suparna Chakladar, FMG

