



Consumers Energy

Count on Us[®]

40 CFR Part 60 Subpart JJJJ Continuous Compliance Test Report

EUENGINE1

Consumers Energy Company
Huron Compressor Station
3520 Bay Port Road,
Sebewaing, Michigan 48759
SRN: P0741

November 30, 2022

Test Date: November 2, 2022

Test Performed by the Consumers Energy Company
Regulatory Compliance Testing Section
Air Emissions Testing Body
Laboratory Services Section
Work Orders 39609770
Version No.: 1.0

TABLE OF CONTENTS

| | |
|--|-----------|
| EXECUTIVE SUMMARY | IV |
| 1.0 INTRODUCTION | 1 |
| 1.1 IDENTIFICATION, LOCATION, AND DATES OF TESTS..... | 1 |
| 1.2 PURPOSE OF TESTING..... | 1 |
| 1.3 BRIEF DESCRIPTION OF SOURCE | 2 |
| 2.0 SUMMARY OF RESULTS | 3 |
| 2.1 OPERATING DATA | 3 |
| 2.2 APPLICABLE PERMIT INFORMATION..... | 3 |
| 2.3 RESULTS | 3 |
| 3.0 SOURCE DESCRIPTION | 4 |
| 3.1 PROCESS..... | 4 |
| 3.2 PROCESS FLOW..... | 5 |
| 3.3 MATERIALS PROCESSED | 5 |
| 3.4 RATED CAPACITY | 5 |
| 3.5 PROCESS INSTRUMENTATION | 6 |
| 4.0 SAMPLING AND ANALYTICAL PROCEDURES..... | 6 |
| 4.1 DESCRIPTION OF SAMPLING TRAIN AND FIELD PROCEDURES | 6 |
| 4.2 SAMPLE LOCATION AND TRAVERSE POINTS (USEPA METHOD 1) | 7 |
| 4.3 MOISTURE CONTENT (USEPA ALT-008)..... | 8 |
| 4.4 O ₂ , NO _x , AND CO (USEPA METHODS 3A, 7E, AND 10) | 9 |
| 4.5 EMISSION RATES (USEPA METHOD 19) | 11 |
| 4.6 VOLATILE ORGANIC COMPOUNDS (USEPA METHODS 18 AND 25A)..... | 11 |
| 5.0 TEST RESULTS AND DISCUSSION | 12 |
| 5.1 TABULATION OF RESULTS..... | 12 |
| 5.2 SIGNIFICANCE OF RESULTS..... | 12 |
| 5.3 VARIATIONS FROM SAMPLING OR OPERATING CONDITIONS..... | 12 |
| 5.4 AIR POLLUTION CONTROL DEVICE MAINTENANCE | 12 |
| 5.5 RE-TEST DISCUSSION | 13 |
| 5.6 RESULTS OF AUDIT SAMPLES | 13 |
| 5.7 CALIBRATION SHEETS | 14 |
| 5.8 SAMPLE CALCULATIONS..... | 14 |
| 5.9 FIELD DATA SHEETS | 14 |
| 5.10 LABORATORY QUALITY ASSURANCE / QUALITY CONTROL PROCEDURES | 14 |
| 5.11 QA/QC BLANKS | 14 |

FIGURES

| | |
|--|----|
| FIGURE 3-1. FOUR-STROKE ENGINE PROCESS DIAGRAM..... | 5 |
| FIGURE 4-1. EUENGINE1 CATERPILLAR MODEL G3512B ENGINE DIAGRAM..... | 8 |
| FIGURE 4-2. SAMPLING PORT LOCATION..... | 8 |
| FIGURE 4-3. ALTERNATIVE METHOD 008 MOISTURE SAMPLE APPARATUS..... | 9 |
| FIGURE 4-4. USEPA METHODS 3A, 7E, AND 10 SAMPLING SYSTEM..... | 10 |
| FIGURE 4-5. USEPA METHOD 19 EMISSION FLOW RATE EQUATION..... | 11 |
| FIGURE 4-6. USEPA METHOD 25A SAMPLE APPARATUS..... | 12 |

TABLES

| | |
|---|----|
| TABLE E-1 SUMMARY OF TEST RESULTS..... | IV |
| TABLE 1-1 EUENGINE1 EMISSION LIMITS..... | 1 |
| TABLE 1-2 CONTACT INFORMATION..... | 2 |
| TABLE 2-1 SUMMARY OF TEST RESULTS..... | 3 |
| TABLE 3-1 SUMMARY OF ENGINE SPECIFICATIONS..... | 4 |
| TABLE 4-1 TEST METHODS..... | 6 |
| TABLE 4-2 TEST MATRIX..... | 7 |
| TABLE 5-1 QA/QC PROCEDURES..... | 13 |

APPENDICES

| | |
|----------------|---|
| Appendix Table | Table 1 - EUENGINE1 Emission Rates and Process Data |
| Appendix A | Sample Calculations |
| Appendix B | Field Data Sheets |
| Appendix C | Operating Data |
| Appendix D | Supporting Documentation |

EXECUTIVE SUMMARY

Consumers Energy Regulatory Compliance Testing Section (RCTS) conducted continuous compliance testing on EUENGINE1 at the Huron Compressor Station in Sebewaing, Michigan on November 2, 2022.

The engine is a natural gas-fired, 4-stroke lean-burn (4SLB), spark-ignited (SI), reciprocating internal combustion engine (RICE), >500 horsepower that powers a compressor used to maintain pressure in pipelines transporting natural gas from main lines to storage facilities located in Michigan or local distribution companies. The facility does not qualify as a major source of hazardous air pollutants (HAP). The engine is the only source of air emissions and does not require a Permit to Install (PTI) pursuant to Rule 201 based on exemptions provided at Rules 278a and 285(g).

The test program was conducted to satisfy performance test requirements and evaluate compliance with 40 CFR Part 60, Subpart JJJJ, "Standards of Performance for Stationary Spark Ignition Internal Combustion Engines," (aka NSPS SI ICE). The engine is also subject to 40 CFR Part 63, Subpart ZZZZ, *National Emissions Standards for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal Combustion Engines*, however the NESHAP requirements do not apply because the unit meets the *new or reconstructed stationary RICE located at an area source* criteria in 40 CFR Part 63, Subpart ZZZZ, § 63.6590(c)(1), and as evidenced in this report, is compliant with 40 CFR Part 60 Subpart JJJJ.

Three, 60-minute tests measuring exhaust emissions of nitrogen oxides (NO_x), carbon monoxide (CO), volatile organic compounds (VOC's), and oxygen (O₂) were conducted at the oxidation catalyst outlet following the procedures in United States Environmental Protection Agency (USEPA) Reference Methods (RM) 1, 3A, 4 (ALT-008), 7E, 10, 19, and 25A in 40 CFR Part 60, Appendix A. There were no deviations from the approved stack test protocol submitted on September 21, 2022, or associated USEPA RM, except the test date for EUENGINE1 which was postponed from October 25, 2022, to November 2, 2022, due to engine start-up delays.

The test results summarized in Table E-1 indicate EUENGINE1 is operating in compliance with 40 CFR Part 60, Subpart JJJJ. Detailed results are presented in Appendix Table 1. Sample calculations and field data sheets are presented in Appendices A and B. Engine operating data and supporting documentation are provided in Appendices C and D.

Table E-1
Summary of Test Results

| Parameter | Units | Result | 40 CFR Part 60, Subpart JJJJ Limit ¹ |
|--|-----------------------------|--------------|---|
| NO _x | g/HP-hr | 0.42 | 1.0 |
| | ppmvd at 15% O ₂ | 32.8 | 82 |
| CO | g/HP-hr | 0.054 | 2.0 |
| | ppmvd at 15% O ₂ | 7.1 | 270 |
| VOC (as NMOC) | g/HP-hr | 0.27 | 0.7 |
| | ppmvd at 15% O ₂ | 22.0 | 60 |
| NO _x nitrogen oxides CO carbon monoxide VOC (as NMOC) volatile organic compounds as non-methane organic compounds g/HP-hr grams per horsepower hour 1 Owners and operators of stationary non-certified SI engines may choose to comply with the emission standards in units of either g/HP-hr or ppmvd at 15 percent O ₂ . | | | |

1.0 SUMMARY OF RESULTS

This report summarizes compliance air emission test results from EUENGINE1 conducted November 2, 2022, at the Consumers Energy Huron Compressor Station (HCS) in Sebawaing, Michigan.

This document follows the Michigan Department of Environment, Great Lakes and Energy (EGLE) format described in the November 2019, Format for Submittal of Source Emission Test Plans and Reports. Reproducing only a portion of this report may omit critical substantiating documentation or cause information to be taken out of context. If any portion of this report is reproduced, please exercise due care in this regard.

1.1 IDENTIFICATION, LOCATION, AND DATES OF TESTS

Consumers Energy Regulatory Compliance Testing Section (RCTS) conducted nitrogen oxides (NO_x), carbon monoxide (CO), and volatile organic compound (VOC) testing of a natural gas-fired 4-stroke lean burn (4SLB), Caterpillar Model G3512B reciprocating internal combustion engine (RICE) designated as EUENGINE1 at the Huron Compressor Station in Sebawaing, Michigan.

A test protocol outlining the proposed testing and data quality objectives was submitted to EGLE on September 21, 2022, and subsequently approved by Mr. Daniel Droste, Environmental Quality Analyst, in a letter dated October 3, 2022. There were no deviations from the approved stack test protocol or associated USEPA RM, except the test date for EUENGINE1 was postponed from October 25, 2022, to November 2, 2022, due to engine start-up delays.

1.2 PURPOSE OF TESTING

The test was conducted to satisfy performance test requirements and verify compliance with United States Environmental Protection Agency (USEPA) 40 CFR Part 60, Subpart JJJJ, *Standards of Performance for Stationary Spark Ignition Internal Combustion Engines*. EUENGINE1 is also subject to 40 CFR Part 63, Subpart ZZZZ, *National Emissions Standards for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal Combustion Engines*, however as a new stationary RICE located at an area source, 40 CFR 63 §63.6590(c)(1) states that NESHAP test requirements do not apply when the engine is meeting 40 CFR Part 60 Subpart JJJJ requirements. The applicable emission limits are shown in Table 1-1.

Table 1-1
EUENGINE1 Emission Limits

| Parameter | Emission Limit | Units | Applicable Requirement |
|--|----------------|-----------------------------|--|
| NO _x | 1.0 | g/BHP-hr | 40 CFR Part 60, Subpart JJJJ, Table 1 ^a |
| | 82 | ppmvd at 15% O ₂ | |
| CO | 2.0 | g/BHP-hr | |
| | 270 | ppmvd at 15% O ₂ | |
| VOC | 0.7 | g/BHP-hr | |
| | 60 | ppmvd at 15% O ₂ | |
| NO _x nitrogen oxides CO carbon monoxide VOC volatile organic compounds (non-methane organic compounds (NMOC)) g/BHP-hr grams per brake horsepower hour ^a Emission limit criteria must be met with the engine operating at or within ± 10 percent of 100 peak (or highest achievable) load. Owners and operators of stationary non—certified SI engines may choose to comply with the emission standards in units of either g/HP-hr or ppmvd at 15 percent O ₂ . | | | |

1.3 BRIEF DESCRIPTION OF SOURCE

EUENGINE1 is classified as a four-stroke lean burn natural gas-fired, spark-ignition reciprocating internal combustion engine, which is located and operating at the Huron Compressor Station in Sebewaing, Michigan. The engine qualifies for a State of Michigan Permit to Install (PTI) exemption due to the Caterpillar Model G3512B engine ratings and specifications, and because it is the only air emission source at Huron Compressor Station.

Table 1-2 presents contact information of personnel involved in the test program.

**Table 1-2
Contact Information**

| Program Role | Contact | Address |
|----------------------------------|--|---|
| EPA Regional Contact | Compliance Tracker, Air Enforcement and Compliance Assurance Branch | U.S. EPA Region 5 77 W. Jackson Blvd. (AE-17J) Chicago, Illinois 60604 |
| Regulatory Agency Representative | Mr. Jeremiah Brown Technical Programs Unit Supervisor 517-599-7825 BrownJ9@michigan.gov | EGLE Technical Programs Unit 525 W. Allegan, Constitution Hall, 2nd Floor S Lansing, Michigan 48933-1502 |
| State Regulatory Inspector | Mr. Chris Hare Supervisor 989-280-4733 harec@michigan.gov | EGLE – Air Quality Division Saginaw Bay District 401 Ketchum Street, Suite B Bay City, Michigan 48708 |
| State Field Operations Section | Mr. Daniel Droste Environmental Quality Analyst 989-280-4733 DrosteD3@michigan.gov | EGLE – Air Quality Division Saginaw Bay District 401 Ketchum Street, Suite B Bay City, Michigan 48708 |
| Responsible Official | Mr. Avelock Robinson Director of Gas Compression Operations 586-716-3326 avelock.robinson@cmsenergy.com | Consumers Energy Company St. Clair Compressor Station 10021 Marine City Highway Ira, Michigan 48023 |
| Corporate Air Quality Contact | Ms. Amy Kapuga Senior Engineer 517-788-2201 amy.kapuga@cmsenergy.com | Consumers Energy Company Environmental Services Department 1945 West Parnall Road Jackson, Michigan 49201 |
| Field Environmental Coordinator | Mr. Thomas Fox Senior Engineer 989-667-5153 Thomas.fox@cmsenergy.com | Consumers Energy Company South Monroe Customer Service Center 7116 Crabb Road Temperance, MI 48182 |
| Test Facility | Dominic Tomasino Sr. Field Leader 586-716-3337 Dominic.tomasino@cmsenergy.com | Consumers Energy Company St. Clair Compressor Station 10021 Marine City Highway Ira Township, Michigan 48023 |
| Test Facility | William Rosser Gas Field Leader III 989-791-5819 William.rosser@cmsenergy.com | Consumers Energy Company 2400 Weiss Street Saginaw, MI 48602 |
| Test Team Representative | Mr. Joe Gallagher Engineering Technical Analyst 231-720-4856 joseph.gallagher@cmsenergy.com | Consumers Energy Company L&D Training Center 17010 Croswell Street West Olive, Michigan 49460 |

2.0 SUMMARY OF RESULTS

2.1 OPERATING DATA

During the performance test the engine fired natural gas and operated within 10% of 100 percent peak (or the highest achievable) load. The performance testing was conducted with the engine operating at an average load >94% torque and >94% horsepower, based on the maximum manufacturer's design capacity at engine and compressor site conditions. Refer to Appendix D for detailed operating data.

2.2 APPLICABLE PERMIT INFORMATION

EUENGINE1 qualified for a State of Michigan Permit to Install (PTI) exemption due to the Caterpillar Model G3512B engine ratings and specifications, and because it is the only air emission source at Huron Compressor Station. EUENGINE1 operates in accordance with the *Standards of Performance for Stationary Spark Ignition Internal Combustion Engines*, 40 CFR Part 60, Subpart JJJJ.

2.3 RESULTS

The test results in Tables 2-1 indicate the engine complies with the applicable emission limits and associated operating requirements.

Detailed results are presented in Appendix Table 1. A discussion of the results is presented in Section 5.0. Sample calculations, field data sheets, and laboratory data sheets are presented in Appendices A, B, and C. Engine operating data and supporting documentation are provided in Appendices D and E.

Table 2-1
Summary of Test Results

| Parameter | Units | Result | 40 CFR Part 60, Subpart JJJJ Limit ¹ |
|--|-----------------------------|--------------|---|
| NO _x | g/HP-hr | 0.42 | 1.0 |
| | ppmvd at 15% O ₂ | 32.8 | 82 |
| CO | g/HP-hr | 0.054 | 2.0 |
| | ppmvd at 15% O ₂ | 7.1 | 270 |
| VOC (as NMOC) | g/HP-hr | 0.27 | 0.7 |
| | ppmvd at 15% O ₂ | 22.0 | 60 |
| NO _x nitrogen oxides CO carbon monoxide VOC (as NMOC) volatile organic compounds as non-methane organic compounds g/HP-hr grams per horsepower hour 1 Owners and operators of stationary non-certified SI engines may choose to comply with the emission standards in units of either g/HP-hr or ppmvd at 15 percent O ₂ . | | | |

3.0 SOURCE DESCRIPTION

EUENGINE1 is a natural gas fired RICE used to maintain pressure of natural gas along the pipeline system. A summary of the engine specifications from vendor data are provided in Table 3-1.

Table 3-1
Summary of Engine Specifications


| Parameter ¹ | EUENGINE1 |
|---|---|
| Make | Caterpillar |
| Model | G3512B |
| Output (brake-horsepower) | 1,035 |
| Heat Input, LHV (mmBtu/hr) | 7.86 |
| Exhaust Flow Rate (ACFM, wet) | 6,725 |
| Exhaust Gas Temp. (°F) | 975 |
| Engine Outlet O ₂ (Vol-%, dry) | 9.5 |
| Engine Outlet CO ₂ (g/bhp-hr) | 455 |
| CO, Uncontrolled (g/bhp-hr) | 2.75 |
| CO, Controlled ² (ppmv, dry) | 0.19 |
| 1 | Engine specifications are based upon vendor data for operation at 100% of rated engine capacity |
| 2 | The controlled CO concentrations are based upon the vendor not to exceed CO concentrations at 100% load, and a reduction of 93% by volume for the associated oxidation catalysts. |

3.1 PROCESS

EUENGINE1 is a natural gas-fired, spark ignited, 4SLB RICE installed in 2016 with initial startup on October 19, 2016. In the four-stroke engine, air is aspirated into the cylinder during the downward travel of the piston on the intake stroke. The fuel charge is injected with the piston near the bottom of the intake stroke and the intake valves close as the piston moves to the top of the cylinder, compressing the air/fuel mixture. A spark plug at the top of the cylinder ignites the air/fuel charge causing the charge to expand and initiate the downward movement of the piston, called the power stroke. As the piston reaches the bottom of the power stroke, valves open to exhaust combustion products from the cylinder as the piston travels upward. A new air-to-fuel charge is injected as the piston moves downward in a new intake stroke.

The engine provides mechanical shaft power for a gas compressor. The compressor is used to maintain pressure within the natural gas pipeline transmission and distribution system to consumers. Refer to Figure 3-1 for a four-stroke engine process diagram.

Figure 3-1. Four-Stroke Engine Process Diagram



3.2 PROCESS FLOW

Located in southwest Huron County, the Huron Compressor Station helps maintain natural gas pressures in the natural gas pipeline system. The main function of the station is to help ensure the ability to maintain required pressures within the natural gas distribution system.

EUENGINE1 is a natural gas reciprocating engine used to drive a two-stage compressor to maintain pressure and move natural gas through the pipeline system. Natural gas combustion by-products are controlled through parametric controls (i.e., timing and operating at a lean air-to-fuel ratio) and by post-combustion oxidizing catalysts installed on the engine exhaust system. The RICE oxidation catalysts are manufactured from proprietary materials to effectively match the CO and volatile organic compound oxidation temperatures to RICE engine exhaust temperatures. The catalyst vendor CO reduction efficiency guarantee is 93%, NO_x emissions are minimized using lean-burn combustion technology, defined as a high level of excess air (generally 50% to 100% relative to the stoichiometric amount) in the combustion chamber. Excess air absorbs heat from the combustion process, thereby reducing the combustion temperature and pressure, resulting in lower NO_x emissions. As carbon monoxide passes through the catalytic oxidation system, CO and volatile organic compounds are oxidized to CO₂ and water, while suppressing the conversion of NO to NO₂.

Detailed operating data are provided in Appendix C.

3.3 MATERIALS PROCESSED

The engine fuel is exclusively natural gas, as defined in 40 CFR §72.2. Recent natural gas sample analyses indicate a fuel composition of approximately 93% methane, 6% ethane, 0.5% nitrogen, and 0.4% carbon dioxide.

3.4 RATED CAPACITY

EUENGINE1 has a maximum output of approximately 1,035 horsepower. At this achievable output, the heat input rating is approximately 7.86 mmBtu/hr. However, the maximum achievable operating condition of the engine is constrained by site and pipeline specific conditions.

3.5 PROCESS INSTRUMENTATION

During testing, the following engine operating parameters were monitored and collected:

- Date and Time
- Fuel gas flow (scf/hr)
- Engine brake horsepower (HP)
- Engine speed (RPM)
- Engine Load as Compressor Torque (% max)
- Suction pressure (psi)
- Discharge pressure (psi)
- Total engine operating time (hr)
- Energy content of fuel (Btu)

During testing of EUENGINE1 the process data was recorded in 10-minute increments using manual readings of field instrumentation. Refer to Appendix C for this operating data.

4.0 SAMPLING AND ANALYTICAL PROCEDURES

Triplicate one-hour test runs for NO_x, CO, VOC, and O₂ concentrations were conducted using the USEPA test methods in Table 4-1. The sampling and analytical procedures associated with each parameter are described further in the following sections.

Table 4-1
Test Methods

| Parameter | Method | USEPA Title |
|--|-----------|--|
| Sample traverses | 1 | Sample and Velocity Traverses for Stationary Sources |
| Oxygen | 3A | Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure) |
| Moisture content | 4/Alt-008 | Determination of Moisture Content in Stack Gases |
| Nitrogen oxides | 7E | Determination of Nitrogen Oxides Emissions from Stationary Sources (Instrumental Analyzer Procedure) |
| Carbon monoxide | 10 | Determination of Carbon Monoxide Emissions from Stationary Sources (Instrumental Analyzer Procedure) |
| Methane (CH ₄) & Ethane (C ₂ H ₆) | 18 | Measurement of Gaseous Organic Compound Emissions by Gas Chromatography |
| Emission rates | 19 | Sulfur Dioxide Removal and Particulate, Sulfur Dioxide and Nitrogen Oxides from Electric Utility Steam Generators |
| Volatile organic compounds | 25A | Determination of Total Gaseous Organic Concentration Using a Flame Ionization Analyzer |

4.1 DESCRIPTION OF SAMPLING TRAIN AND FIELD PROCEDURES

The test matrix in Table 4-2 summarizes the sampling and analytical methods performed during this test program.

**Table 4-2
Test Matrix**

| Date (2022) | Run | Sample Type | Start Time (EST) | Stop Time (EST) | Test Duration (min) | EPA Test Method | Comment |
|------------------|-----|---|------------------|-----------------|---------------------|--|---|
| EUENGINE1 | | | | | | | |
| November 2 | 1 | O ₂ NO _x CO CH ₄ VOC | 10:10 | 11:09 | 60 | 1 3A 4(alt-008) 7E 10 18 19 25A | 3-points located in each duct at 16.7, 50.0 & 83.3 % of the measurement line were traversed |
| | 2 | | 11:30 | 12:29 | 60 | | |
| | 3 | | 12:45 | 13:44 | 60 | | |

4.2 SAMPLE LOCATION AND TRAVERSE POINTS (USEPA METHOD 1)

The number and location of traverse points for each engine was evaluated according to the requirements in Table 2 of 40 CFR Part 60, Subpart JJJJ, and USEPA Method 1, *Sample and Velocity Traverses for Stationary Sources*.

The engine is equipped with sample ports located downstream (Post) of the oxidation catalyst.

Post-catalyst Sampling Ports


Two test ports are in a 14-inch vertical exhaust stack exiting the engine and oxidation catalyst. The post-catalyst sampling ports are situated:

- Approximately 28-inches or 2.0 duct diameters downstream of a duct diameter change flow disturbance, and
- Approximately 7-inches or 0.5 duct diameters upstream of the stack exit to atmosphere.

The post-catalyst sample ports are 4-inches in diameter and sealed by a bolted blank flange approximately 4-inches outside the stack wall.


Because the ducts are >12 inches in diameter and the sampling port locations meet the two and half-diameter criterion of Section 11.1.1 of Method 1 of 40 CFR Part 60, Appendix A-1, the duct was sampled at 3 traverse points located at 16.7, 50.0, and 83.3% of the measurement line ('3-point long line'). The flue gas was sampled from the three traverse points at approximately equal intervals during the tests. Pre-catalyst and post-catalyst sampling port location images are presented as Figures 4-1 and 4-2.

Figure 4-1. EUENGINE1 Caterpillar Model G3512B Engine Diagram



Picture of Engine Design in Compressor Building

Figure 4-2. Sampling Port Location




4.3 MOISTURE CONTENT (USEPA ALT-008)

Exhaust gas moisture content was determined in accordance with USEPA ALT-008, *Alternative Moisture Measurement Method Midget Impingers*, an alternative method for correcting pollutant concentration data to appropriate moisture conditions (e.g., pollutant and/or air flow data on a dry or wet basis) validated May 19, 1993, by the USEPA Emission Measurement Branch. The procedure is incorporated into Method 6A of 40 CFR Part 60 and is based on field validation tests described in *An Alternative Method for Stack Gas Moisture Determination* (Jon Stanley, Peter Westlin, 1978, USEPA Emissions Measurement Branch).

The sample apparatus configuration follows the general guidelines contained in Figure 4-2 and § 8.2 of USEPA Method 4, *Determination of Moisture Content in Stack Gases*, and ALT-008 Figure 1 or 2. The flue gas is withdrawn from the stack at a constant rate through a heated sample probe, umbilical, four midget impingers, and a metering console with pump. The moisture is removed from the gas stream in the ice-bath chilled impingers and determined gravimetrically. Refer to Figure 4-3 for a figure of the Alternative Method 008 Moisture Sample Apparatus.

Figure 4-3. Alternative Method 008 Moisture Sample Apparatus



The silica gel tube depicted in this figure was replaced with a midget impinger (bubbler) with a straight tube insert, as allowed in ALT-008, §1

4.4 O₂, NO_x, AND CO (USEPA METHODS 3A, 7E, AND 10)


Oxygen, nitrogen oxides, and carbon monoxide concentrations were measured using the following sampling and analytical procedures:

- USEPA Method 3A, *Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure)*,
- USEPA Method 7E, *Determination of Nitrogen Oxides Emissions from Stationary Sources (Instrumental Analyzer Procedure)*, and
- USEPA Method 10, *Determination of Carbon Monoxide Emissions from Stationary Sources (Instrumental Analyzer Procedure)*.

Each cited method sampling is procedurally similar except for the analyzer and analytical technique used. Engine exhaust gas was extracted from the stack or ducts through a stainless-steel probe, heated Teflon® sample line, and through a gas conditioning system to remove water and dry the sample before entering a sample pump, flow control manifold, and gas analyzers.

Figure 4-4 depicts a drawing of the Methods 3A, 7E, and 10 sampling system.

Figure 4-4. USEPA Methods 3A, 7E, and 10 Sampling System



Prior to sampling engine exhaust gas, the analyzers are calibrated by performing a calibration error test where zero-, mid-, and high-level calibration gases are introduced directly to the back of the analyzers. The calibration error check is performed to evaluate if the analyzers response was within $\pm 2.0\%$ of the calibration gas span or high calibration gas concentration. An initial system-bias test is then performed where the zero- and mid- or high- calibration gases are introduced at the sample probe to measure the ability of the system to respond accurately to within $\pm 5.0\%$ of span.

A NO_2 to NO conversion efficiency test is performed on the NO_x analyzer prior to beginning the test program to evaluate the ability of the instrument to convert NO_2 to NO before analyzing for NO_x .

Upon successful completion of the calibration error and initial system bias tests, sample flow rate and component temperatures are verified, and the probes inserted into the ducts at the appropriate traverse point. After confirming the engine is operating at established conditions, the test run is initiated. Gas concentrations are recorded at 1-minute intervals throughout each 60-minute test run. Oxygen concentrations are measured to adjust the pollutant concentrations to 15% O_2 and calculate pollutant emission rates.

At the conclusion of each test run, a post-test system bias check is performed to compare analyzer bias and drift relative to pre-test system bias checks, ensuring analyzer bias is within $\pm 5.0\%$ of span and drift is within $\pm 3.0\%$. The analyzer response is also used to correct measured gas concentrations for analyzer drift.

For the analyzer calibration error tests, bias tests and drift checks, these evaluations are also passed if the standard criteria are not achieved, but the absolute difference between the analyzer responses and calibration gas is less than or equal to 0.5 ppmv for NO_x and CO or 0.5% for O_2 .

4.5 EMISSION RATES (USEPA METHOD 19)

USEPA Method 19, *Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide, and Nitrogen Oxide Emission Rates*, was used to calculate a fuel specific F factor and exhaust gas flowrate.

A fuel sample was collected during testing and analyzed by gas chromatography, ultraviolet fluorescence, and electronic sensing cells to obtain hydrocarbons, non-hydrocarbons, heating value, and other parameters of the natural gas samples. The results were used to calculate F_w and F_d factors (ratios of combustion gas volumes to heat inputs) using USEPA Method 19 Equations 19-13, 19-14, and 19-15. This F_d factor was then used to calculate the emission flow rate with the corresponding equation presented in Figure 4-5. The flow rate was used in calculations to present emissions in units of g/HP-hr.

Figure 4-5. USEPA Method 19 Emission Flow Rate Equation

$$Q_s = F_d H \frac{20.9}{20.9 - O_2}$$

Where:

- Q_s = stack flow rate (dscf/min)
- F_d = fuel-specific oxygen-based F factor, dry basis, from Method 19 (dscf/mmBtu)
- H = fuel heat input rate, (mmBtu/min), at the higher heating value (HHV) measured at engine fuel feed line, calculated as (fuel feed rate in ft³/min) x (fuel heat content in mmBtu/ft³)
- O_2 = stack oxygen concentration, dry basis (%)

4.6 VOLATILE ORGANIC COMPOUNDS (USEPA METHODS 18 AND 25A)

VOC concentrations were measured from each engine using a Thermo Model 55i Direct Methane and Non-methane Analyzer following the guidelines of USEPA Method 25A, *Determination of Total Gaseous Organic Concentration Using a Flame Ionization Analyzer (FIA)*. The instrument uses a flame ionization detector (FID) to measure the exhaust gas total hydrocarbon concentration in conjunction with a gas chromatography column that separates methane from other organic compounds.


The components of the extractive sample interface apparatus are constructed of Type 316 stainless steel and Teflon. Flue gas was sampled from the stack via a sample probe and heated sample line and into the analyzer, which communicates with data acquisition handling systems (DAHS) via output signal cables. The analyzer uses a rotary valve and gas chromatograph column to separate methane from hydrocarbons in the sample and quantifies these components using a flame ionization detector.

Sample gas is injected into the column and due to methane's low molecular weight and high volatility, the compound moves through the column more quickly than other organic compounds that may be present and is quantified by the FID. The column is then flushed with inert carrier gas and the remaining non-methane organic compounds are analyzed in the FID. This analytical technique allows separate measurements for methane and non-methane organic compounds via the use of a single FID. Refer to Figure 4-6 for a drawing of the USEPA Method 25A sampling apparatus.

The field VOC instrument was calibrated with zero air and three propane and methane in air calibration gases following USEPA Method 25A procedures at the zero level, low (25 to 35 percent of calibration span), mid (45 to 55 percent of calibration span) and high (equivalent

to 80 to 90 percent of instrument span). Note that the field VOC instrument measures on a wet basis, therefore measured exhaust gas moisture content was used to convert wet basis VOC concentrations to dry and calculate VOC mass emission rates.

Figure 4-6. USEPA Method 25A Sample Apparatus



5.0 TEST RESULTS AND DISCUSSION

The test program conducted November 2, 2022, satisfies the performance testing and compliance evaluation requirements in 40 CFR Part 60, Subpart JJJJ, "Standards of Performance for Stationary Spark Ignition Internal Combustion Engines."

5.1 TABULATION OF RESULTS

The results of the testing indicate EUENGINE1 is compliant with the applicable NO_x, CO, and VOC emissions limits and associated operating requirements as summarized in Table 2-1. Appendix Table 1 contains detailed tabulation of results, process operating conditions, and exhaust gas conditions.

5.2 SIGNIFICANCE OF RESULTS

The results of the testing indicate compliance with the applicable emission limits.

5.3 VARIATIONS FROM SAMPLING OR OPERATING CONDITIONS

No sampling or operating condition variations occurred during the test event.

5.4 AIR POLLUTION CONTROL DEVICE MAINTENANCE

Other than routine maintenance, no major air pollution control device maintenance was performed during the three-month period prior to the test event. Engine optimization is continuously performed to ensure lean-burn combustion and ongoing compliance with regulatory emission limits.

5.5 RE-TEST DISCUSSION

Based on the results of this test program, a re-test is not required. Subsequent air emissions testing on the engine will be performed:

- every 8,760 engine operating hours or 3 years (2025), whichever is first, thereafter, to evaluate compliance with NO_x, CO, and VOC emission limits in 40 CFR Part 60, Subpart JJJJ. The engine hours after the conclusion of testing were:
 - EUENGINE1: 69 hours

5.6 RESULTS OF AUDIT SAMPLES

Audit samples for the reference methods utilized during this test program are not available from USEPA Stationary Source Audit Sample Program providers. The USEPA reference methods performed state reliable results are obtained by persons equipped with a thorough knowledge of the techniques associated with each method. Factors with the potential to cause measurement errors are minimized by implementing quality control (QC) and assurance (QA) programs into the applicable components of field testing. QA/QC components were included in this test program. Table 5-1 summarizes the primary field quality assurance and quality control activities that were performed. Refer to Appendix E for supporting documentation.

Table 5-1
QA/QC Procedures

| QA/QC Activity | Purpose | Procedure | Frequency | Acceptance Criteria |
|--|--|--|------------------------|---|
| M1: Sampling Location | Evaluates suitability of sampling location | Measure distance from ports to downstream and upstream flow disturbances | Pre-test | ≥2 diameters downstream; ≥0.5 diameter upstream. |
| M1: Duct diameter/ dimensions | Verifies area of stack is accurately measured | Review as-built drawings and field measurement | Pre-test | Field measurement agreement with as-built drawings |
| M4/alt-008 | | | | |
| M3A, M7E, M10, M25A: Calibration gas standards | Ensures accurate calibration standards | Traceability protocol of calibration gases | Pre-test | Calibration gas uncertainty ≤2.0% |
| M3A, M7E, M10: Calibration Error | Evaluates analyzer operation | Calibration gases introduced directly into analyzers | Pre-test | ±2.0% of span or ≤0.5 ppmv or ≤0.5 % abs. difference |
| M3A, M7E, M10: System Bias and Analyzer Drift | Evaluates analyzer/sample system integrity and accuracy over test duration | Calibration gas introduced at sample probe tip, HSL, and into analyzers | Pre-test and Post-test | Bias: ±5.0% of span Drift: ±3.0% of span or ≤ 0.5 ppmv or 0.5% abs. difference |
| M7E: NO ₂ -NO converter efficiency | Evaluates NO ₂ -NO converter operation | NO ₂ gas introduced directly into analyzer | Pre-test or Post-test | NO _x response ≤2% drop from peak value observed |
| M25A: Calibration Error | Evaluates analyzer and sample system operation | Calibration gases introduced through sample system | Pre-test | ±5.0% of the calibration gas value |

Table 5-1
QA/QC Procedures

| QA/QC Activity | Purpose | Procedure | Frequency | Acceptance Criteria |
|----------------------------------|--|--|------------------------|--|
| M25A: Zero and Calibration Drift | Evaluates analyzer/sample system integrity and accuracy over test duration | Calibration gases introduced through sample system | Pre-test and Post-test | ±3.0% of the analyzer calibration span |

5.7 CALIBRATION SHEETS

Calibration sheets, including gas protocol sheets and analyzer quality control and assurance checks are presented in Appendix D.

5.8 SAMPLE CALCULATIONS

Sample calculations and formulas used to compute emissions data are presented in Appendix A.

5.9 FIELD DATA SHEETS

Field data sheets are presented in Appendix B.

5.10 LABORATORY QUALITY ASSURANCE / QUALITY CONTROL PROCEDURES

The method specific quality assurance and quality control procedures in each method employed during this test program were followed, without deviation. Refer to Appendix C for the laboratory data sheets associated with the natural gas fuel samples collected during the test program.

5.11 QA/QC BLANKS

The Method 3A, 7E, 10, and 25A calibration gases described in Table 5-1 above were the only QA/QC media employed during the test event. QA/QC data are shown in Appendix D.