



GRETCHEN WHITMER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF  
ENVIRONMENT, GREAT LAKES, AND ENERGY  
DETROIT DISTRICT OFFICE



PHILLIP D. ROOS  
DIRECTOR

September 10, 2024

Dan Raezer  
Norplas Industries, Inc.  
12200 Oakland Park Blvd  
Highland Park, MI 48203

SRN: P1491, Wayne County

Dear Dan Raezer:

**VIOLATION NOTICE**

On August 9, 2024, the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD), conducted an inspection of Norplas Industries, in particular the branch referred to as Magna Exteriors, located at 12200 Oakland Park Blvd, Highland Park, Michigan. The purpose of this inspection was to determine Norplas Industries compliance with the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451); and the Michigan Air Pollution Control Rules.

During the inspection, staff observed the following:

Process Description	Rule/Permit Condition Violated	Comments
Two Taylor TD1600 emergency generators rated at 2346 HP/1750 kW each	Rule 201	Two generators were installed at the facility and have been operated without a Permit to Install.

During this inspection, it was noted that Norplas Industries had installed and commenced operation of unpermitted equipment at this facility. The AQD staff advised Norplas Industries on August 9, 2024, that this is a violation of Rule 201 of the administrative rules promulgated under Act 451.

A program for compliance may include a completed PTI application for the emergency generators and the AQD acknowledges that Norplas Industries submitted a pending PTI application for these generators in June 2024.

Be advised that Rule 201 requires that a permit be obtained prior to installation, construction, operation, reconstruction, relocation, or alteration of any process or process equipment which may be a source of an air contaminant.

Norplas Industries' recent acquisition of the facility with the unpermitted generators along with the manufacturer date on each generator's nameplate provides an

Dan Raezer  
Norplas Industries Inc.  
Page 2  
September 10, 2024

explanation of the cause and duration of the violation. And as noted above, Norplas Industries has submitted a PTI application to the AQD for the unpermitted generators. Therefore, the AQD considers this information and activity to be an adequate written response to this Violation Notice.

If Norplas Industries believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position by October 1, 2024 (which coincides with 21 calendar days from the date of this letter).

Please submit any written response to Diana Serban at EGLE, AQD, Detroit District, at Cadillac Place, 3058 West Grand Boulevard, Suite 2-300, Detroit, Michigan 48202 or [serband@michigan.gov](mailto:serband@michigan.gov) and submit a copy to Jenine Camilleri, Enforcement Unit Supervisor at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760.

Thank you for your attention to resolving the violation cited above and for the cooperation that was extended to me during my inspection of Norplas Industries. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,

*Diana Serban*

Diana Serban  
Environmental Engineer  
Air Quality Division  
313-439-2436

cc: Annette Switzer, EGLE  
Christopher Ethridge, EGLE  
Brad Myott, EGLE  
Jenine Camilleri, EGLE  
Dr. April Wendling, EGLE  
Jeff Korniski, EGLE