

MICHIGAN DEPARTMENT OF PUBLIC HEALTH WATER WELL AND PUMP RECORD

TAX NO.:

PERMIT NO.:

1. LOCATION OF WELL


County: Lapeer Township Name: Arcadia Fraction: nw 1/4 nw 1/4 nw 1/4 Section No.: 31 Town No.: 8n Range No.: 11e

Distance and Direction from Road Intersection

Street Address & City of Well Location

Locate with 'x' in Section Below

Sketch Map



2. FORMATION DESCRIPTION

THICKNESS OF STRATUM DEPTH TO BOTTOM OF STRATUM

red sandy clay	12	12
clay	28	40
clay & stones	50	90
sandstone	70	160

3. OWNER OF WELL

Address: Don Redmond
3010 Haines Rd.
Lapeer, Mi

Address Same as Well Location Yes No

4. WELL DEPTH:

Date Completed: 1 / 22 / 96 New Well Replacement Well

5. Cable Tool Rotary Driven Dug
 Hollow Rod Auger/Bored Jetted

6. USE: Household Type I Public Type III Public
 Irrigation Type IIa Public Heat Pump
 Test Well Type IIb Public

7. CASING: Steel Threaded Plastic Welded
 Other _____ Height: Above/Below Surface: _____ ft

Diameter: 5 in. to 98 ft. depth _____ in. to _____ ft. depth Weight: _____ lbs./ft.

BORE HOLE: Diameter: 8 1/2 to 98 ft. depth 4 1/2 to 160 ft. depth Drive Shoe Shale Packer

8. SCREEN: Not Installed Gravel-Packed Type _____ Diameter _____ Slot/Gauze _____ Length: _____ Set Between _____ ft. and _____ ft.

FITTINGS: K-Packer Bremer Check Blank Above Screen _____ ft. Other _____

9. STATIC WATER LEVEL: grade ft. Below Land Surface Flowing

10. PUMPING LEVEL: Below Land Surface 160 ft. After 1 hrs. Pumping at 60 G.P.M. Plunger Bailor Air Test Pump

11. WELL HEAD COMPLETION: Pitless Adapter 12" Above Grade Basement Offset Well House

12. WELL GROUTED? No Yes From 0 to 98 ft. Neat Cement Bentonite Other Benseal pulmer &
No. of Bags _____ Additives _____

13. NEAREST SOURCE OF POSSIBLE CONTAMINATION: Type septic Distance 80 ft. Direction N
Type _____ Distance _____ ft. Direction _____

14. PUMP: Not Installed Pump Installation Only
Manufacturer's Name Myers
Model Number 2NPL-52-12 HP 1/2 Volts 230
Length of Drop Pipe 35 ft. Capacity 12 G.P.M.
TYPE: Submersible Jet Other _____

PRESSURE TANK:
Manufacturer's Name Well-Rite
Model Number WR120-04 Capacity 10.5 Gallons

15. ABANDONED WELL PLUGGED? Yes No
Casing Diameter _____ in. Depth _____ ft.
PLUGGING MATERIAL: Neat Cement Bentonite Slurry
 Cement/Bentonite Slurry Concrete Grout Bentonite Chips
No. of Bags _____ Casing Removed? Yes No

16. REMARKS: (Elevation, Source of Data, etc.)

17. DRILLING MACHINE OPERATOR:
 Employee Subcontractor
Name _____

15. WATER WELL CONTRACTOR'S CERTIFICATION:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
James C. Wilcox Well Drilling 44-0185
REGISTERED BUSINESS NAME REGISTRATION NO.
Address 4700 N. Lapeer Rd. Columbiaville, Mi
Signed James C. Wilcox Date 1/22/96
AUTHORIZED REPRESENTATIVE



WATER WELL RECORD
ACT 294 PA 1965

MICHIGAN DEPARTMENT
OF
PUBLIC HEALTH


1 LOCATION OF WELL

County <i>Oshtemo</i>	Township Name <i>Arcadia</i>	Fraction <i>SW 1/4 SW 1/4</i>	Section Number <i>31</i>	Town Number <i>8</i>	Range Number <i>11</i>	Elev. <i>EAH</i>
--------------------------	---------------------------------	----------------------------------	-----------------------------	-------------------------	---------------------------	---------------------

Distance And Direction from Road Intersection
*1/2 mile north of Bowers Rd on
Fair Lakes Rd*

Street address & City of Well Location

3 OWNER OF WELL: *Jack Bonarates*
Address *Bowling Green Rd*



4 WELL DEPTH: (completed) *160* ft. Date of Completion *11-6-84*

5 Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored

6 USE: Domestic Public Supply Industry
 Irrigation Air Conditioning Commercial
 Test Well

7 CASING: Threaded *Galvalume* Diam. _____ Height: Above ^{to}/_{below} Surface *1* ft.
Weight *sub 410* lbs./ft.
Drive Shoe? Yes No

5 in. to *120* ft. Depth
4 1/2 in. to *410* ft. Depth

2 FORMATION	THICKNESS OF STRATUM	DEPTH TO BOTTOM OF STRATUM
-------------	----------------------	----------------------------

<i>Red clay loam</i>	<i>10</i>	<i>10</i>
<i>sand yellow</i>	<i>20</i>	<i>30</i>
<i>Blue clay</i>	<i>25</i>	<i>55</i>
<i>sand w B</i>	<i>15</i>	<i>70</i>
<i>Blue clay</i>	<i>35</i>	<i>(105)</i>
<i>Blue shale</i>	<i>15</i>	<i>120</i>
<i>net peeps</i>		
<i>Blue shale</i>	<i>15</i>	<i>135</i>
<i>sand stone</i>	<i>25</i>	<i>160</i>

8 SCREEN:
Type: _____ Diam. _____
Slot/Gauze *none* Length _____
Set between _____ ft. and _____ ft.
Fittings: _____

9 STATIC WATER LEVEL
20 ft. below land surface

10 PUMPING LEVEL below land surface
40 ft. after *1/2* hrs. pumping *50* g.p.m.
40 ft. after *L* hrs. pumping *50* g.p.m.

11 WATER QUALITY in Parts Per Million:
Iron (Fe) _____ Chlorides (Cl) _____
Unknown
Hardness _____ Other _____

12 WELL HEAD COMPLETION: In Approved Pit
 Pitless Adapter 12" Above Grade

13 Well Grouted? Yes No
 Neat Cement Bentonite *Others*
Depth: From *head* ft. to *120* ft.

14 Nearest Source of possible contamination
50 feet *W* Direction *upter* Type _____
Well disinfected upon completion Yes No

15 PUMP: Not installed
Manufacturer's Name *Red Book*
Model Number _____ HP _____ Volts *25*
Length of Drop Pipe *60* ft. capacity *2 1/2* G.P.M.
Type: Submersible Jet Reciprocating

RECEIVED
Mich. Dept. of Public Health
OCT 1 1984
Bureau of Environmental & Occupational Health

16 Remarks, elevation, source of data, etc.

17 WATER WELL CONTRACTOR'S CERTIFICATION:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Bob Baynes REGISTERED BUSINESS NAME *WD 1023* REGISTRATION NO.
Address *3997 Horner Rd Attleboro*
Signed *Bob Baynes* Date *11-7-84*
AUTHORIZED REPRESENTATIVE

MICHIGAN DEPARTMENT OF PUBLIC HEALTH
WATER WELL AND PUMP RECORD

PERMIT NUMBER

PART 127 ACT 368, P.A. 1978

1 LOCATION OF WELL			3 OWNER OF WELL:																													
County Lapeer	Township Name Arcadia	Fraction NW 1/4 NW 1/4 NE 1/4	Section Number 31	Town Number BN N/S	Range Number 11E E/W																											
Distance And Direction From Road Intersection 300 ft. E. of Bearinger Rd. on Haines Rd.			Address Martin Wallo 3268 Haines Rd. Lapeer, Mi.																													
Street Address & City of Well Local on 3268 Haines Rd. Lapeer,			Address Same As Well Location? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																													
Locate with "X" in Section Below Sketch Map			4 WELL DEPTH: (completed) 147 ft. Date of Completion March 1, 1983																													
			5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Augur <input type="checkbox"/> Jettod <input type="checkbox"/>																													
			6 USE: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Type I Public <input type="checkbox"/> Type III Public <input type="checkbox"/> Irrigation <input type="checkbox"/> Type IIa Public <input type="checkbox"/> Heat pump <input type="checkbox"/> Test Well <input type="checkbox"/> Type IIb Public <input type="checkbox"/>																													
2 FORMATION DESCRIPTION <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:70%;">FORMATION DESCRIPTION</th> <th style="width:10%;">THICKNESS OF STRATUM</th> <th style="width:20%;">DEPTH TO BOTTOM OF STRATUM</th> </tr> </thead> <tbody> <tr><td>Red Clay</td><td>20</td><td>20</td></tr> <tr><td>Fine Sand</td><td>10</td><td>30</td></tr> <tr><td>Blue Clayed Gravel</td><td>5</td><td>35</td></tr> <tr><td>Stoney Clay</td><td>30</td><td>65</td></tr> <tr><td>Black Shale</td><td>10</td><td>75</td></tr> <tr><td>Blue Shale</td><td>10</td><td>85</td></tr> <tr><td>Brown Lime</td><td>5</td><td>90</td></tr> <tr><td>White Sandstone</td><td>57</td><td>147</td></tr> </tbody> </table>			FORMATION DESCRIPTION	THICKNESS OF STRATUM	DEPTH TO BOTTOM OF STRATUM	Red Clay	20	20	Fine Sand	10	30	Blue Clayed Gravel	5	35	Stoney Clay	30	65	Black Shale	10	75	Blue Shale	10	85	Brown Lime	5	90	White Sandstone	57	147	7 CASING: <input checked="" type="checkbox"/> Steel <input checked="" type="checkbox"/> Threaded <input type="checkbox"/> Plastic <input type="checkbox"/> Welded Diameter 2 in to 91 ft. depth Height: Above/Below Surface 1 ft Weight 3.75 lbs./ft Grouted Drill Hole Diameter 5 in to 91 ft. depth Drive Shoe <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			FORMATION DESCRIPTION	THICKNESS OF STRATUM	DEPTH TO BOTTOM OF STRATUM																											
			Red Clay	20	20																											
			Fine Sand	10	30																											
			Blue Clayed Gravel	5	35																											
			Stoney Clay	30	65																											
			Black Shale	10	75																											
			Blue Shale	10	85																											
			Brown Lime	5	90																											
			White Sandstone	57	147																											
8 SCREEN: <input checked="" type="checkbox"/> Not installed Type _____ Diameter _____ Slot/Gauze _____ Length _____ Set between _____ ft. and _____ ft. FITTINGS: <input type="checkbox"/> K-Packer <input type="checkbox"/> Lead Packer <input type="checkbox"/> Bremer Check <input type="checkbox"/> Blank above screen _____ ft. Other _____																																
9 STATIC WATER LEVEL: 5ft. 6in. ft. below land surface <input type="checkbox"/> Flow																																
10 PUMPING LEVEL: below land surface 147 ft. after 1 1/2 hrs. pumping at 30 G.P.M. _____ ft. after _____ hrs. pumping at _____ G.P.M.																																
11 WELL HEAD COMPLETION: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> 12" above grade <input type="checkbox"/> Basement offset <input type="checkbox"/> Approved pit																																
12 WELL GROUTED? <input type="checkbox"/> No <input checked="" type="checkbox"/> Yes From 0 to 91 ft. <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Other thick mud No. of bags of cement _____ Additives _____																																
13 Nearest source of possible contamination Type septic tank distance 75 ft. Direction W Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																																
14 PUMP: <input type="checkbox"/> Not Installed <input type="checkbox"/> Pump Installation Only Manufacturer's name Wayne Model number unknown HP 1/2 Volts 110 Length of Drop Pipe 26 ft. capacity 10 G.P.M. TYPE: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Jet PRESSURE TANK: Manufacturer's name X-trol Model number 202 Capacity 10 5 Gallons																																
15 PUMPING DATA, etc. *CORRECTED BY _____ **ADDITION BY _____ ELEVATION _____ DEPTH TO ROCK _____																																
16 WATER WELL CONTRACTOR'S CERTIFICATION: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Charles R. Wilcox Well Drilling REGISTRATION NO. 0377 Address 3838 N. Lapeer Rd. Lapeer, Mi. Signed Charles R. Wilcox Date March 1, 1983 AUTHORIZED REPRESENTATIVE																																

RECEIVED
 Mich. Dept. of Public Health
 NOV 4 1983
 Environmental and
 Occupational Health
 Administration


1 Location of Well		County LAPEER		Township Name ARCADIA		Fraction NW 1/4 NW 1/4 NE 1/4		Section Number 31		Town Number 8N N/S		Range Number 11E E/W	
Distance and Direction From Road Intersection 3369 HANES RD. ATTICA								3 Owner of Well HUBBELL, PAUL Address 11266 ORCHARD HILL CT. ROMEO MI 48065-					
Street Address and City of Well Location								Address Same as Well Location? No					
Sketch Map				4 Well Depth (Completed) 120 ft.				Date of Completion 10/28/99 New Well					
				5 Drilling Method MUD ROTARY									
				6 Proposed Use DOMESTIC									
2 FORMATION DESCRIPTION		Thickness of Stratum		Depth to Bottom of Stratum		7 Casing PLASTIC		5 in. to 80 ft. depth		Height Above Surface 1 ft.		Weight SDR 2 lbs./ft.	
CLAY		12		12		Bore Hole Diameter		8 in. to 80 ft. depth		Drive Shoe No			
WATER BEARING SAND & GRAVEL		8		20		4 in. to 120 ft. depth		Shale Packer Yes					
HARDPAN		40		60		8 Screen Not Installed		Gravel-packed? No					
SHALE		20		80									
BEDROCK		40		120									
								9 Static Water Level 15 Ft. Below Land Surface		Flow			
								10 Pumping Level Below Land Surface		ft. after .5 hrs. pumping at 20 G.P.M.		ft. after hrs. pumping at G.P.M.	
								Using AIR					
								11 Well Head Completion PITLESS ADAPTER					
								12 Well Grouted? Yes From 0 to 120 ft.		BENTONITE		No. of bags of cement 6 Additives EZ-MUD	
								13 Nearest Source of Possible Contamination		SEPTIC Distance 60 ft. Direction S		SEPTIC Distance ft. Direction	
15 Abandoned well plugged? No				Casing Diameter in. Depth ft.				14 Pump Installed Pump Installation Only? No					
Casing removed? No								Manufacturer's Name MEYERS					
								Model Number 2NFL52-12 HP 1/2 Volts 230					
								Length of Drop Pipe 80 ft. Capacity 9 G.P.M.					
								Type SUBMERSIBLE Jet NONE					
								Pressure tank:					
								Manufacturer's Name CHAMPION					
								Pressure Tank Model 42 GALLON Capacity 0 gal.					
17 Drilling machine operator:				18 Water Well Contractor's Certification:				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.					
Employee Name EDWARDS				Registered business name: B & B WELL DRILLING INC.				Registration number: 63-1837					
Authority: Act 368 PA 1978				Address: 4745 FOREST ST., LEONARD, MI 48367				Signed: <u>Blanka</u> Date 12-2-99					
Completion: Required.				IMPORTANT: File with deed.				(Authorized representative)					
Penalty: Conviction of violation of any provision is a misdemeanor.													

DEC 07 1999

Drinking Water...
WELL CONSTRUCTION UNIT

MICHIGAN DEPARTMENT OF PUBLIC HEALTH
WATER WELL AND PUMP RECORD

PERMIT NUMBER							

1 LOCATION OF WELL		
County Lapeer	Township Name Arcadia	Fraction SW 1/4 SE 1/4 SW 1/4
Section Number 31		Town Number 6N N/S
Range Number 11E		E/W E/W
Distance And Direction From Road Intersection 1/4 mi. E. of Five Lakes Rd. on Bowers Rd.		
Street Address & City of Well Location 3153 Bowers Rd. Attica, Mi.		
Locate with "X" in Section Below <div style="display: flex; align-items: center;">  <div style="margin-left: 20px;">Sketch Map:</div> </div>		
3 OWNER OF WELL: Hurley Mercer		
Address 3153 Bowers Rd. Attica, Mi.		
Address Same As Well Location? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
4 WELL DEPTH: 180 FT. Date Completed 9/10/87 <input checked="" type="checkbox"/> New Well <input type="checkbox"/> Replacement Well		
5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Auger <input type="checkbox"/> Jetted <input type="checkbox"/>		
6 USE: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Type I Public <input type="checkbox"/> Type III Public <input type="checkbox"/> Irrigation <input type="checkbox"/> Type IIa Public <input type="checkbox"/> Heat pump <input type="checkbox"/> Test Well <input type="checkbox"/> Type IIb Public <input type="checkbox"/>		
7 CASING: Diameter <input type="checkbox"/> Steel <input type="checkbox"/> Threaded <input checked="" type="checkbox"/> Plastic <input type="checkbox"/> Welded Height: Above/Below Surface 1 ft. Weight 3.75 lbs./ft. _____ in. to _____ ft. depth Grouted Drill Hole Diameter 7 7/8 to 115 ft. depth _____ in. to _____ ft. depth Drive Shoe <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
2 FORMATION DESCRIPTION		THICKNESS OF STRATUM
		DEPTH TO BOTTOM OF STRATUM
Red Clay		15
Blue Clayed Gravel		37
Dirty Gravel		16
Blue Clay		32
Stoney Clay		10
White Sandstone		10
Liney White Sandstone		35
White Sandstone		25
		110
8 SCREEN: <input checked="" type="checkbox"/> Not Installed Type _____ Diameter _____ Slot/Gauze _____ Length _____ Set between _____ ft. and _____ ft. FITTINGS: <input type="checkbox"/> K-Packer <input type="checkbox"/> Lead Packer <input type="checkbox"/> Bremer Check <input type="checkbox"/> Blank above screen _____ ft. Other _____		
9 STATIC WATER LEVEL: _____ ft. below land surface <input type="checkbox"/> Flow		
10 PUMPING LEVEL: below land surface _____ ft. after _____ hrs. pumping at _____ G.P.M. _____ ft. after _____ hrs. pumping at _____ G.P.M.		
11 WELL HEAD COMPLETION: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> 12" above grade <input type="checkbox"/> Basement offset <input type="checkbox"/> Approved pit		
12 WELL GROUTED? <input type="checkbox"/> No <input checked="" type="checkbox"/> Yes From 0 to 115 ft. <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Other thick mud No. of bags of cement _____ Additives _____		
13 Nearest source of possible contamination Type septic tank Distance 60 ft. Direction SW Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Was old well plugged? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
14 PUMP: <input type="checkbox"/> Not Installed <input type="checkbox"/> Pump Installation Only Manufacturer's name Red Jacket Model number 500NWT0950 HP 1/2 Volts 220 Length of Drop Pipe 46 ft. capacity _____ G.P.M. TYPE: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Jet PRESSURE TANK: Manufacturer's name X-trol Model number _____ Capacity 9 Gallons		
15. Remarks, elevation, source of data, etc.		
16. WATER WELL CONTRACTOR'S CERTIFICATION: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Charles R. Wilcox Well Drilling REGISTRATION NO. 0377 Address 3838 N. Lapeer Rd. Lapeer, Signed Charles R. Wilcox Date Sept. 10, 1987 AUTHORIZED REPRESENTATIVE		
17. Rig Operator's Name:		

RECEIVED
Mich. Dept. of Public Health
JAN 19 1988
Bureau of Environmental and Occupational Health - GWOS

USE A 2ND SHEET IF NEEDED

Authority: Act 388 PA 1978
Completion: Required
Penalty: Conviction of a violation of any provision is a misdemeanor.

OCT 09 1978

WATER WELL RECORD
ACT 294 PA 1965

MICHIGAN DEPARTMENT
OF
PUBLIC HEALTH


1 LOCATION OF WELL

County Lapeer	Township Name ARCADIA	Fraction $\frac{1}{4}$ SW $\frac{1}{4}$	Section Number 31	Town Number 8 N/B.	Range Number 11 E/W.
-------------------------	---------------------------------	---	-----------------------------	------------------------------	--------------------------------

Distance And Direction from Road Intersections
Millan Bowers Rd 3199

Street address & City of Well Location
Locate with "X" in section below Sketch Map:

3 OWNER OF WELL:
Hurley, Merian
Address **3199 Bowers Rd.**
Joplin, Mo 64446



4 WELL DEPTH: (completed) Date of Completion
160 ft. **Aug 12-78**

2 FORMATION

FORMATION	THICKNESS OF STRATUM	DEPTH TO BOTTOM OF STRATUM
Red Sand and clay	22	22
Clay loam	41	63
Boulders	48	111
Sand Stone cut out	49	160

5 Cable tool Rotary Driven Dug
 Hollow rod Jetted Borad

6 USE: Domestic Public Supply Industry
 Irrigation Air Conditioning Commercial
 Test Well

7 CASING: Threaded Welded Height: Above/Below Surface **1** ft.
Diam. **2** in. to **1 1/4** ft. Depth **3.75** lbs./ft.
Weight **3.75** lbs./ft. Drive Shoe? Yes No

8 SCREEN: Type: **None** Dia.: _____
Slot/Gauze _____ Length _____
Set between _____ ft. and _____ ft.
Fittings: _____

9 STATIC WATER LEVEL
17 ft. below land surface

10 PUMPING LEVEL below land surface
42 ft. after **1** hrs. pumping **12'** o.p.m.
_____ ft. after _____ hrs. pumping _____ o.p.m.

11 WATER QUALITY in Parts Per Million:
Iron (Fe) _____ Chlorides (Cl) _____
Hardness _____ Other _____

12 WELL HEAD COMPLETION: In Approved Pit
 Pitless Adapter 12" Above Grade

13 Well Grouted? Yes No
 Neat Cement Bentonite
Depth: From **0** ft. to **111** ft.

14 Nearest Source of possible contamination
65 feet Direction **TILLFIELD** Type _____
Well disinfected upon completion Yes No

15 PUMP: Not installed
Manufacturer's Name **FLINT and WALLING**
Model Number **CB 267-H 3** Volts **220**
Length of Drop Pipe **63** ft. capacity _____ G.P.M.
Type: Submersible Jet Reciprocating

16 Remarks, elevation, source of data, etc.

ADDED BY BY DRILLER, ITEM NO.
CORRECTED BY
ADDITION BY **CR**
ELEVATION
DEPTH TO ROCK

17 WATER WELL CONTRACTOR'S CERTIFICATION:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Raymond Dooling 0881
REGISTERED BUSINESS NAME REGISTRATION NO.
Address **1105 Alvin Drive Joplin**
Signed **Raymond Dooling** Date **Aug 12-78**
AUTHORIZED REPRESENTATIVE